CONGER FUELING LIFE LP GAS
congerlpgas.com

INVOICE / WORK ORDER NO. 133241

NAME Keith Beasley RT# ____ RT. SEQ. ____ ACCT # 1-07795 DATE 10/26/26 INT [illegible]

MAILING ADDRESS ____ CO. ____ CITY ____

ADDRESS 105 Davis ST. APT/LOT NO. ____

CITY TyTy STATE GA ZIP CODE 31795

NEW CUSTOMER INFORMATION
S.S. NO. ____ DELV ____
HOME PH ____ RENT ____
WORK PH ____ CREDIT ____
LITE PILOT ____ PC ____
EMPLOYER ____
DR. ____ USE ____ LEASE ____

SERVICE REQUESTED: ☐ CASH ☐ CHARGE DATE PROMISED ____

Purchase & install Rinnai

email: pkbeasley@att.net
cell # 229-392-2632
PAY BILL ONLINE @congerlpgas.com

DIRECTIONS:

TANK PICKUP/SET	TANK SIZE	SERIAL #	TANK %	TANK DESTINATION	DOT PERMANENTLY INSTALLED CONTAINERS				
					MANUFACTURED DATE	LAST TEST DATE	SIZE	SERIAL #	% FULL
	120	14326	Ø	ONSITE					

QTY	APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED	MODEL #	SERIAL NUMBER	UNIT PRICE	SALES AMOUNT
1	Rinnai #27519 REP160ep		PKUA-112500		1199 95
	Sediment Trap				50 00
1	1/2 copper				9 95
4	1/2 elbows				7 90
6	1/2 flare nuts				17 70
	misc supplies				15 93

WORK PERFOMED: Installed Rinnai, Hooked gas up.

REGULATION INFORMATION
MAKE: Rego MODEL: TR9
DATE CODE: 7D2026 VENT: DOWN

APPLIANCES/ EQUIP. SOLD	CODE	1199 95
PARTS/MAT. USED		85 55
TANK RENT		
		18 95
SALES TAX ____ %		96.00 1.52 6.84 1.27
LABOR		180 00
		15 93
GPC	GR	(400 00)
INV. TOTAL		1,406-01
AMOUNT RECEIVED		

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:

1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 ☐

2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A PAMPHLET NUMBER 54 ☐

I HAVE RECEIVED A SCRATCH AND SNIFF BROCHURE AND THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.

X ____
CUSTOMER SIGNATURE

LEAK AND PRESSURE TEST

HIGH:	1st Stage	2nd Stage	LOW
START LOCK-UP:	10 PSI	PSI	START LOCK-UP: W.C.
TANK OFF: PRESSURE	5 PSI	PSI	TANK OFF: PRESSURE W.C.
AFTER 10 MINUTES:	5 PSI	PSI	AFTER 10 MINUTES: W.C.
PRESSURE AS LEFT:	10 PSI	PSI	PRESSURE AS LEFT: W.C.

PIPING PRESSURE TEST
START PSIG FINISH PSIG

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE.

[signature] SERVICE REP. SIGNATURE 10/27/26 DATE X ____ CUSTOMER SIGNATURE

WHITE/FILE COPY; YELLOW/CUSTOMER COPY; PINK/POSTING COPY

11/2025