



HOME OWNED & OPERATED

INVOICE

No 11399 ✓

P.O. BOX 506 • BAXLEY, GEORGIA 31515
2174 HATCH PARKWAY SOUTH • BAXLEY, GEORGIA 31513 • Tel. (912) 367-1151

NAME	<u>John Weststeyn Cattle</u>	ACCOUNT NO.	
MAIL ADDRESS	<u>600 Damascus Church Rd.</u>	DATE ORDERED	
CITY/STATE/ZIP	<u>Mechan GA 31551</u>	DATE PROMISED	
PHONE	<u>912-316-1005</u>	DATE COMPLETED	<u>6-30-26</u>
LOCATION		TERMS	

INSTRUCTIONS

QTY.	TAG NO. AND DESCRIPTION OF APPLIANCE/MATERIAL	UNIT PRICE	SALES AMOUNT
1	Rheem G100-200 100 gallon water heater LP model # G100-200, serial # A232607370		6800 00

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER: 1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 ☐ 2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 ☐	SERVICES PERFORMED <u>Ran pressure check</u> <u>lit & checked out water heater</u>	TOTAL MATERIAL	
	TOTAL TIME _____ HOURS	LABOR	
THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.	SERVICES PERFORMED	SUBTOTAL	
X _____ CUSTOMER'S SIGNATURE	BY <u>Daniel Sikes</u>	SALES TAX	
		TOTAL DUE	<u>6800 00</u>

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

INSTALLATION OR TURN ON	REMOVAL OR TURN OFF	LEAK AND PRESSURE TEST	
		HIGH	LOW
SIZE:	SIZE	START LOCK UP:	START JACK UP:
S/N:	S/N:	TANK OFF PRESSURE:	TANK OFF PRESSURE:
GALLONS OR READING:	GALLONS OR READING:	AFTER 10 MINUTES:	AFTER 10 MINUTES:
		PRESSURE AS LEFT:	PRESSURE AS LEFT:

RECEIVED BY _____
DATE _____
SERVICES RECEIVED BY _____

WHITE/CUSTOMER'S COPY; YELLOW/POSTING COPY; PINK/FILE COPY

GASCheck - Gas Appliance System Check

Account Name _____ Invoice Number _____ Date 6/30/26
 Name John Weststagn Cattle Company Sikes Propane, Inc.
 Address 600 Damascus Church Hwy Call Taken By _____
 City Macon State GA Zip 31551 Telephone (Cell) 912-316-1005 (Home) _____

Appliance Check

Appliance	water heater	water heater	water heater			
Manufacturer	<u>Rheem</u>	<u>Rheem</u>	<u>Rheem</u>			
Model #	<u>G100-200</u>	<u>G100-200</u>	<u>G100-200</u>			
Serial #	<u>A2326073</u>	<u>A0516077</u>	<u>A2415146</u>			
	<u>70</u>	<u>58</u>	<u>40</u>			
BTU's	<u>199,900</u>	<u>199,900</u>	<u>199,900</u>			
Burner / Com. Chamber	<u>ok</u>	<u>ok</u>	<u>ok</u>			
Man. Shutoff / Sed. Trap	<u>existing</u>	<u>existing</u>	<u>existing</u>			
Control / Pilot Safety System	<u>ok</u>	<u>ok</u>	<u>ok</u>			
Venting System	<u>ok</u>	<u>ok</u>	<u>ok</u>			
Age	<u>new</u>	<u>9yrs.</u>	<u>10yrs.</u>			
Taken Out Of Service Or Operation						

Container Check

Size	Serial #	Manufacturer	MFR. Date	Location	Container Condition	Relief Valve	Fittings Leak Check
<u>1000</u>	<u>M77350</u>	<u>Dalta</u>	<u>1966</u>	<u>ok</u>	<u>ok</u>	<u>11-81</u>	<u>ok</u>

Pressure Test (If Applicable)

Start Pressure	End Pressure	Time Held	Pressure Held
<u>130psi.</u>	<u>130psi.</u>	<u>10min.</u>	<u>0</u>
			<u>0</u>
			<u>0</u>

Piping Check

Materials	Size	Cover / Protection
<u>poly</u>	<u>1"</u>	<u>ok</u>
<u>copper</u>	<u>5/8" & 1/2"</u>	<u>ok</u>

System Leak Check

Start Pressure	End Pressure	Time Held	Pressure Held
<u>9in.wc.</u>	<u>9in.wc.</u>	<u>10min.</u>	<u>0</u>
			<u>0</u>
			<u>0</u>

Regulator Check

Type	Manufacturer	Date / Model	Vent Position / Protection
<u>First</u>	<u>Rego</u>	<u>11D16 / LV4403TR9</u>	<u>u-c</u>
<u>Second</u>	<u>Rego</u>	<u>01A12 / LV4403B4</u>	<u>down</u>
<u>Second</u>	<u>Rego</u>	<u>04E16 / LV4403B4</u>	<u>down</u>

Safety Information Supplied:

Comments: Please note all repairs and corrections made along with any recommended actions.