11/9/2026 11:00:47 AM

# WORK ORDER

## Dusty Patterson

8256 Hwy 2
Epworth, GA 30541
(706) 455-2920

Customer #: 204575
Order #: 570937
Location #: 280373
Zone: B-005-TUE-
Terms: Net 30

**Tech:** _____

**Map Code:**
**Service Code:** Propane Service
**Description:** ~~11/24/26~~ final hook Connect stove, W/H, F/P run yard line Call 706-455-2575 or 706-632-6549 CCOF-CLT
11-18-26

| Date Ordered: 11/9/2026 | Scheduled Date: | Est. Completion: | Start: | Stop: |
|---|---|---|---|---|

**Name:**
**Contract:**
**Manufact:**
**Notes:**
**Instructions:**

**Last Service:** 9/3/2026
**SC Renewal:**
**Model:**

**Last Tune Up:**

**Service History:**

| Date | Invoice # | Tech | Problem Reported | Service Notes |
|---|---|---|---|---|

# PROPANE GAS PIPING SYSTEM CHECK

Customer Account #: 204575

Name: DUSTY PATTERSON

Address: 8256 HWY 2

EPWORTH, GA 30541

Date: 11/24/26

Instructions: FINAL HOOK. CC/STOVE, W/H/FP RUN YD LIN

CALL 706-455-2575 OR 706-632-6549

Order #: 570937

**Disclaimer:** This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

**Appliance Check:**

| Appliance | Furnace | W/H | Stove top | Log set | | |
|---|---|---|---|---|---|---|
| Manufacturer | Bryant | Rinnai | Kitchen aid | Empire | | |
| Model # | CUAV048210AEBAA | RE50-VC2528FEM0 | KGSK336SSS0 | VFSR30-4LP | | |
| Serial # | 3026517368 | PB,CA-02149T | DF3209963 | 2514P409630 | | |
| Burner/Combustion Chamber | ☑ Ok | ☐ Ok | ☑ Ok | ☑ Ok | ☐ Ok | ☐ Ok |
| Manual Shutoff | ☑ Ok ☐ N/A | ☐ Ok ☐ N/A | ☑ Ok ☐ N/A | ☑ Ok ☐ N/A | ☐ Ok ☐ N/A | ☐ Ok ☐ N/A |
| Sediment Trap | ☑ Ok | ☐ Ok | ☑ Ok | ☑ Ok | ☐ Ok | ☐ Ok |
| Pilot Safety System | ☑ Ok ☐ N/A | ☐ Ok ☐ N/A | ☑ Ok ☐ N/A | ☑ Ok ☐ N/A | ☐ Ok ☐ N/A | ☐ Ok ☐ N/A |
| Electronic Ignition System | ☑ Ok ☐ N/A | ☐ Ok ☐ N/A | ☑ Ok ☐ N/A | ☑ Ok ☐ N/A | ☐ Ok ☐ N/A | ☐ Ok ☐ N/A |
| Venting System | ☑ Ok ☐ N/A | ☐ Ok ☐ N/A | ☑ Ok ☐ N/A | ☑ Ok ☐ N/A | ☐ Ok ☐ N/A | ☐ Ok ☐ N/A |
| Combustion Air | ☑ Ok | ☐ Ok | ☑ Ok | ☑ Ok | ☐ Ok | ☐ Ok |
| Taken Out of Service | ☐ Yes ☑ No | ☐ Yes ☑ No | ☐ Yes ☑ No | ☐ Yes ☑ No | ☐ Yes ☐ No | ☐ Yes ☐ No |

**Container Check:**

| Size | Serial # | Container Fitting Leak Test | Manufacturer | Manufacture Date | Location | Tank Condition |
|---|---|---|---|---|---|---|
| 325 | 2SH016633 | Good | American | 1994 | AG | Good |
| | | | | | | |

**Regulator(s):**

| | Manufacturer | Model | Regulator Date | Regulator Venting | Flow/Delivery Pressure | Lock-Up Pressure |
|---|---|---|---|---|---|---|
| Twin | | | | ☐ Correct ☐ Incorrect | | |
| 1st | Reso | 3403TRG | 7-26 | ☑ Correct ☐ Incorrect | | |
| 2nd | Reso | 4463YM | 7-25 | ☑ Correct ☐ Incorrect | 11.3 | 13.6 |

**Piping System Leak Test:**

| Start Pressure | End Pressure | Time Held | Pass |
|---|---|---|---|
| 12 PSI / ____ WC | 12 PSI / ____ WC | 10 Mins / ____ Mins | ☑ Yes ☐ No |

**Pressure Test:**

| Start Pressure | End Pressure | Time Held | Pass |
|---|---|---|---|
| 15 PSI | 15 PSI | 10 Mins | ☑ Yes ☐ No |

Comments: No water hookup to test w/H plumber coming back to hook up water lines.

**Customer Acknowledgment:** I acknowledge, by checking each of the following items, that:

- ☐ I have informed the service technician of all gas-burning appliances, gas lines, and unused piping not connected to any gas appliance on my property.
- ☐ I have been informed of what deficiencies, repairs &/or alterations, if any, were made to my gas system or appliances.
- ☐ I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas supply off at the tank or cylinder.
- ☐ I have smelled propane gas and can detect its odor.
- ☐ I have been told to consider installing one or more gas detectors.
- ☐ I have received safety information and told to read it and share it with all family members.
- ☐ I am satisfied with the service work performed.

| Service Technician (Print) | Service Technician (Signature) | Date |
|---|---|---|
| [illegible] | [illegible] | 11-24-26 |
| Customer (Print) | Customer (Signature) | Date |
| Brenda Patterson | Brenda Patterson | |

FolgerGas PROPANE

www.folgergas.com

# RINNAI
# WORK ORDER

Customer Acct #: 204575
Name DUSTY PATTERSON
Address 8256 HWY 2
EPWORTH GA 30541

Date: 10/30/26
Instructions: DROP 325AG W/20G @ 2.499 CUSTOMER WILL MARK WHERE TANK IS TO BE DROPPED KPF
Order #: 563281

## DESCRIPTION OF WORK

**COMMENTS:**

**SERVICED BY:**

| DATE | START TIME | FINISH TIME | TOTAL TIME | LABOR RATE | AMOUNT |
|---|---|---|---|---|---|
| | | | | 100.00/hr | |
| | | | | 100.00/hr | |

**FOR OFFICE USE ONLY**

Performed leak check _____ Yes _____ No
Gas check attached _____ Yes _____ No
Leak check Initial _____

| Start Pressure | End Pressure | Time Held | System OK |
|---|---|---|---|
| | | | |

% in Tank

**AMOUNT REC'D**

$_____

☐ CASH ☐ CHECK #_____

☐ CREDIT CARD

#_____

EXP. DATE_____

* I have received the Consumer Safety information & material.
* I am satisfied with the work performed.
* Customer agrees to pay all costs of collection, agency fees, court costs, and reasonable attorney fees in the event of default on payment.
* Signing agrees to _____ year contract for discount.

_____
CUSTOMER SIGNATURE

| | Retail Price | Contract Price | |
|---|---|---|---|
| _____ Rinnai | $ | $ | |
| Standard Vent Kit | $ | $ | |
| Standard Install | $ | $ | |
| Total | $ | $ | |
| | | | |
| **Tank Set** | | **New Cust Special** | |
| L P Gas /Gal | 3.199 | L P Gas /Gal | 2.499 |
| Gallons | 20 | Gallons | 20 |
| FRCC | $9.79 | FRCC | $9.79 |
| Fuel Total | 63.98 | Fuel Total | 49.98 |
| Tank Lease/YR | 99.00 | 1st yr Lease | FREE |
| Total Materials | | | |
| Sub-Total | | | |
| Sales Tax | | | |
| Tank Set Fee | $250 | Tank Set Fee | 20.00 |
| Safety Inspection | $129.95 | | $29.95 |
| Total Labor | | | |
| Total charges | | | |
| Prepay Bal On Account | | | |

| | | 9.79 |
|---|---|---|
| | | 49.98 |
| | | FREE |
| | | 20.00 |
| | | 29.95 |
| Safe Appliance Savings | | 443.00 |
| Safe Appliance Rebate | | 450.00 |

**TOTAL BALANCE DUE**