10/29/2026 3:26:29 PM

WORK ORDER

John Schluter

268 Toccoa River Forest Ln
Mineral Bluff, GA 30559
(504) 421-3240

Customer #: 206804
Order #: 563442
Location #: 283146
Zone: B-014-WED-
Terms: Net 30

Tech:

Map Code:
Service Code: Propane Service
Description: 11/5/26 Hook up W/H Hook up FP Line to manifold. Call Jeremy 706-455-8211 CCOF-SLM

Date Ordered: 10/29/2026	Scheduled Date:	Est. Completion:	Start:	Stop:

Name:
Contract:
Manufact:
Notes:
Instructions:

Last Service: 10/15/2026
SC Renewal:
Model:

Last Tune Up:

Service History:

Date	Invoice #	Tech	Problem Reported	Service Notes

PROPANE GAS PIPING SYSTEM CHECK

Customer Account #: 206804

Name: JOHN SCHLUTER

Address: 268 TOCCOA RIVER FOREST LANE

MINERAL BLUFF GA 30559

Date: 11/5/26

Instructions: HOOK UP WH AND FP LINE TO MANIFOLD CALL JEREMY 706--455-8211 CCOF-SLM

Order #: 563442

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

Appliance Check:

Appliance	Log Set	Water Heater				
Manufacturer	Empire	Rinnai				
Model #	NV	RX199				
Serial #	NV	052021				
Burner/Combustion Chamber	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Manual Shutoff	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Sediment Trap	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Pilot Safety System	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Electronic Ignition System	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Venting System	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Combustion Air	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Taken Out of Service	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No

Container Check:

Size	Serial #	Container Fitting Leak Test	Manufacturer	Manufacture Date	Location	Tank Condition
250	25603B008	Good	American	NV	AG	Good

Regulator(s):

	Manufacturer	Model	Regulator Date	Regulator Venting	Flow/Delivery Pressure	Lock-Up Pressure
Twin				☐ Correct ☐ Incorrect		
1st	Rego	3403TR	Sep 2025	☒ Correct ☐ Incorrect		
2nd	Rego	4403 44	4/26	☒ Correct ☐ Incorrect		

Piping System Leak Test:

Start Pressure	End Pressure	Time Held	Pass
100 PSI / ____ WC	100 PSI / ____ WC	10 Mins / ____ Mins	☒ Yes ☐ No

Pressure Test:

Start Pressure	End Pressure	Time Held	Pass
15 PSI	15 PSI	10 Mins	☒ Yes ☐ No

Comments: _____

Customer Acknowledgment: I acknowledge, by checking each of the following items, that:

- ☐ I have informed the service technician of all gas-burning appliances, gas lines, and unused piping not connected to any gas appliance on my property.
- ☐ I have been informed of what deficiencies, repairs &/or alterations, if any, were made to my gas system or appliances.
- ☐ I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas supply off at the tank or cylinder.
- ☐ I have smelled propane gas and can detect its odor.
- ☐ I have been told to consider installing one or more gas detectors.
- ☐ I have received safety information and told to read it and share it with all family members.
- ☐ I am satisfied with the service work performed.

Service Technician (Print)	Service Technician (Signature)	Date
Customer (Print)	Customer (Signature)	Date

FolgerGas LLC PROPANE

www.folgergas.com

RINNAI WORK ORDER

Customer Acct #: 206804

Name JOHN SCHLUTER

Address 268 TOCCOA RIVER FOREST LN

MINERAL BLUFF GA 30559

Date: 10-15-26

Instructions: T/I 250 W/ 200G GO !ST RUN YARD LINE T/I GRILL TIMER AND 30" PONDEROSA W/ WALL TIMER T/I MONITOR CCOF SM

Order #: 548413

DESCRIPTION OF WORK

COMMENTS:

SERVICED BY:

DATE	START TIME	FINISH TIME	TOTAL TIME	LABOR RATE	AMOUNT
				100.00/hr	
				100.00/hr	

FOR OFFICE USE ONLY

Performed leak check _____ Yes _____ No

Gas check attached _____ Yes _____ No

Leak check Initial _____

Start Pressure	End Pressure	Time Held	System OK

% in Tank

AMOUNT REC'D

$_____

☐ CASH ☐ CHECK #_____

☐ CREDIT CARD

#_____

EXP. DATE_____

* I have received the Consumer Safety information & material.
* I am satisfied with the work performed.
* Customer agrees to pay all costs of collection, agency fees, court costs, and reasonable attorney fees in the event of default on payment.
* Signing agrees to _____ year contract for discount.

_____

CUSTOMER SIGNATURE

	Retail Price	Contract Price	
_____	Rinnai $	$	
	Standard Vent Kit $	$	
	Standard Install $	$	
	Total $	$	
Tank Set		**New Cust Special**	
L P Gas /Gal	2.999	L P Gas /Gal 2.499	
Gallons	200	Gallons 200	
FRCC	$9.79	FRCC $9.79	9.79
Fuel Total	599.80	Fuel Total 499.80	499.80
Tank Lease/YR	99.00	1st yr Lease FREE	FREE
Total Materials			
Sub-Total			
Sales Tax			
Tank Set Fee	$250	Tank Set Fee 20.00	20.00
Safety Inspection	$129.95	$29.95	29.95
Total Labor			
Total charges			
Prepay Bal On Account			
Safe Appliance Savings			529.00
Safe Appliance Rebate			200.00
TOTAL BALANCE DUE			