

✓ ckt

6/23/2026 10:29:42 AM

WORK ORDER

James "Xander" Pasley

361 HuckIEberry Lane
Mineral Bluff, GA 30559
(662) 594-4171

Customer #: 206012
Order #: 516457
Location #: 282165
Zone: B-014-WED-
Terms: Net 30

Tech: _____

Map Code:

Service Code: Propane Service

Description: 06/25/26 - CONNECT AND CONVERT STOVE KIT ON SITE.
CALL 229-834-2320 EMAIL RENOVATION SPOT - CT

Date Ordered: 6/23/2026	Scheduled Date:	Est. Completion:	Start:	Stop:
--------------------------------	------------------------	-------------------------	---------------	--------------

Name:	Last Service: 5/13/2026	Last Tune Up:
Contract:	SC Renewal:	
Manufact:	Model:	
Notes:		
Instructions:		

Service History:

Date	Invoice #	Tech	Problem Reported	Service Notes
------	-----------	------	------------------	---------------

✓



PROPANE GAS PIPING SYSTEM CHECK

Customer Account #: 206012

Date: 6/25/26

Name: **JAMES "XANDER" PASLEY**

Instructions: **CONNECT AND CONVERT STOVE. KIT ON SITE**

Address: 361 HUCKLEBERRY LANE

CALL **229-834-2320** EMAIL **RENOVATIO SPOT**

MINERAL BLUFF, GA 30559

Order #: 516457

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

Appliance Check:

Appliance	<u>STOVE</u>					
Manufacturer						
Model #	<u>45655030520</u>					
Serial #	<u>RF1415238</u>					
Burner/Combustion Chamber	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Manual Shutoff	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Sediment Trap	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Pilot Safety System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Electronic Ignition System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Venting System	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Combustion Air	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Taken Out of Service	☐ Yes ☒ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No

Container Check:

Size	Serial #	Container Fitting Leak Test	Manufacturer	Manufacture Date	Location	Tank Condition
<u>120</u>	<u>M0620849</u>	<u>Good</u>	<u>Trinity</u>	<u>2006</u>	<u>AG</u>	<u>Good</u>

Regulator(s):

Manufacturer		Model	Regulator Date	Regulator Venting		Flow/Delivery Pressure	Lock-Up Pressure
Twin	<u>Rego</u>	<u>404B34</u>	<u>12/24</u>	☒ Correct	☐ Incorrect	<u>11.2</u>	<u>12.4</u>
1st				☐ Correct	☐ Incorrect		
2nd				☐ Correct	☐ Incorrect		

Piping System Leak Test:

Pressure Test:

Start Pressure	End Pressure	Time Held	Pass	Start Pressure	End Pressure	Time Held	Pass
<u>100</u> PSI	<u>100</u> PSI	<u>10</u> Mins	☒ Yes	_____ PSI	_____ PSI	_____ Mins	☐ Yes
_____ WC	_____ WC	_____ Mins	☐ No				☐ No

Comments: _____

Customer Acknowledgment: I acknowledge, by checking each of the following items, that:

- ☐ I have informed the service technician of all gas-burning appliances, gas lines, and unused piping not connected to any gas appliance on my property.
- ☐ I have been informed of what deficiencies, repairs &/or alterations, if any, were made to my gas system or appliances.
- ☐ I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas supply off at the tank or cylinder.
- ☐ I have smelled propane gas and can detect its odor.
- ☐ I have been told to consider installing one or more gas detectors.
- ☐ I have received safety information and told to read it and share it with all family members.
- ☐ I am satisfied with the service work performed.

Service Technician (Print)	Service Technician (Signature) <u>[Signature]</u>	Date <u>6-25-26</u>
Customer (Print) <u>CNP</u>	Customer (Signature) <u>[Signature]</u>	Date _____

Cust Number 206012

Cust Name JAMES "XANDER" PASLEY

Date 6.25.26

	New	Replacement	Gas H/U
Furnace	<u> </u>	<u> </u>	<u> </u>
Water Htr	<u> </u>	<u> </u>	<u> </u>
Neither	<u> ✓ </u>		

Kristen Only:

Rebate Applied For



INVOICE

Customer #:	206012
Payment Terms:	Net 30
Invoice #:	516457
Invoice Date	2026-06-25
Total Due	\$100.00

James "Xander" Pasley
361 HuckIEberry Lane
Mineral Bluff, GA 30559

Make Check Payable to: Folger Gas, LLC

Amount Enclosed: \$

Remit To:
Folger Gas, LLC
PO BOX 2155
Blue Ridge, GA 30513

Customer Name		Delivery/Service Address		Cust #	Invoice #	Inv Date
James "Xander" Pasley		361 HuckIEberry Lane - Mineral Bluff, GA 30559		206012	516457	2026-06-25
Quantity	Item Number	Description		Unit Price		TOTAL
1.00	Labor	Labor		\$100.0000		\$100.00

Tank/Equipment: Heating System -

For Fuel or Service At:

361 HuckIEberry Lane - Mineral Bluff, GA 30559

Sub Total	\$100.00
Charges	\$0.00
Tax Total	\$0.00

ACCOUNT BALANCE	\$0.00	TOTAL DUE	\$100.00
-----------------	--------	-----------	----------

06/25/2026 - Technician: Alexander Cash - Work Performed: - Converted and connected stove with flex line already on site. Hooked twin stage regulator and tied into existing system. Leak check at 100 psi for 10 min. No leaks. AC/JC 80% in tank

Folger Gas, LLC
PO BOX 2155
Blue Ridge, GA 30513

706-632-7606

www.folgergas.com