

WORK ORDER

Timothy Callihan

1251 WEHUNT RD
BLUE RIDGE, GA 30513
(762) 210-8698

Customer #: 29610
Order #: 554348
Location #: 247115
Zone: B-005-TUE-
Terms: Net 30

Tech: _____

Map Code:

Service Code: Propane Service

Description: 10/8/26 Requested Alvin run lines to F/P and run line to upstairs
Call 762-210-8698 COD-CLT CLF

Date Ordered: 10/5/2026	Scheduled Date:	Est. Completion:	Start:	Stop:
--------------------------------	------------------------	-------------------------	---------------	--------------

Name: Heating System

Last Service: 2/26/2026

Last Tune Up:

Contract:

SC Renewal:

Manufact:

Model:

Notes:

Instructions:

Service History:

Date	Invoice #	Tech	Problem Reported	Service Notes
------	-----------	------	------------------	---------------



PROPANE GAS PIPING SYSTEM CHECK

Customer Account #: 29610

Date: 10/8/26

Name: TIMOTHY CALLIHAN

Instructions: RUN LINES TO F/P AND UPSTAIRS

Address: 1251 WEHUNT RD

REQUESTED ALVIN COD CLT

BLUE RIDGE GA 30513

Order #: 554348

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

Appliance Check:

Appliance	Fire Place	Stove				
Manufacturer	Pro flame	B.E				
Model #	FDF 400T-20	JCRS66RFK8SS				
Serial #	BC240004927	MD4140151D				
Burner/Combustion Chamber	☒ Ok	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Manual Shutoff	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Sediment Trap	☒ Ok	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Pilot Safety System	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Electronic Ignition System	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Venting System	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Combustion Air	☒ Ok	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Taken Out of Service	☐ Yes ☒ No	☐ Yes ☒ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No

Container Check:

Size	Serial #	Container Fitting Leak Test	Manufacturer	Manufacture Date	Location	Tank Condition
500	M2268385	Good	Across	2022	AC	Good

Regulator(s):

Manufacturer	Model	Regulator Date	Regulator Venting	Flow/Delivery Pressure	Lock-Up Pressure
Twin			☐ Correct ☐ Incorrect		
1st	Rego	3403TR	11-21	☒ Correct ☐ Incorrect	
2nd	MFC	1622	10-Dec-21	☒ Correct ☐ Incorrect	11.8
					13.3

Piping System Leak Test:

Pressure Test:

Start Pressure	End Pressure	Time Held	Pass	Start Pressure	End Pressure	Time Held	Pass
100 PSI	100 PSI	10 Mins	☒ Yes	15 PSI	15 PSI	10 Mins	☒ Yes
WC	WC	Mins	☐ No				☐ No

Comments:

Customer Acknowledgment: I acknowledge, by checking each of the following items, that:

- ☒ I have informed the service technician of all gas-burning appliances, gas lines, and unused piping not connected to any gas appliance on my property.
- ☒ I have been informed of what deficiencies, repairs &/or alterations, if any, were made to my gas system or appliances.
- ☒ I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas supply off at the tank or cylinder.
- ☒ I have smelled propane gas and can detect its odor.
- ☒ I have been told to consider installing one or more gas detectors.
- ☒ I have received safety information and told to read it and share it with all family members.
- ☒ I am satisfied with the service work performed.

Service Technician (Print)	Alvin Wilcox	Service Technician (Signature)	[Signature]	Date	10-8-26
Customer (Print)		Customer (Signature)	Timothy Callihan	Date	



www.folgergas.com

RINNAI WORK ORDER

Customer Acct #: 29610
Name Timothy Callihan
Address 1251 Wehunt Rd.
Blue Ridge, GA 30513

Date: 10-16-26
Instructions: T/I 250 w/200g @
2.999. Run yard line connect
Order #: 554642

DESCRIPTION OF WORK

COMMENTS:

SERVICED BY:

DATE	START TIME	FINISH TIME	TOTAL TIME	LABOR RATE	AMOUNT
				100.00/hr	
				100.00/hr	

FOR OFFICE USE ONLY

Performed leak check Yes No
Gas check attached Yes No
Leak check Initial

Start Pressure End Pressure Time Held System OK

% in Tank

AMOUNT REC'D

\$

☐ CASH ☐ CHECK #

☐ CREDIT CARD

EXP. DATE

- * I have received the Consumer Safety information & material.
- * I am satisfied with the work performed.
- * Customer agrees to pay all costs of collection, agency fees, court costs, and reasonable attorney fees in the event of default on payment.
- * Signing agrees to year contract for discount.

CUSTOMER SIGNATURE

Retail Price

Contract Price

_____ Rinnai \$	\$	
Standard Vent Kit \$	\$	
Standard Install \$	\$	
Total \$	\$	

Tank Set

New Cust Special

L.P. Gas /Gal <u>2.999</u>	L.P. Gas /Gal <u>2.499</u>	
Gallons <u>200</u>	Gallons <u>200</u>	
FRCC \$9.79	FRCC \$9.79	<u>9.79</u>
Fuel Total <u>599.80</u>	Fuel Total <u>499.80</u>	<u>499.80</u>
Tank Lease/YR <u>99.00</u>	1st yr Lease <u>Free</u>	<u>Free</u>
Total Materials		
Sub-Total		
Sales Tax		
Tank Set Fee \$250	Tank Set Fee <u>20.00</u>	<u>20.00</u>
Safety Inspection \$129.95	\$29.95	<u>29.95</u>
Total Labor		
Total charges		
Prepay Bal On Account		

Safe Appliance Savings 471.82
Safe Appliance Rebate 50.00

TOTAL BALANCE DUE