



INVOICE

11376

HOME OWNED & OPERATED

P.O. BOX 506 • BAXLEY, GEORGIA 31515
2174 HATCH PARKWAY SOUTH • BAXLEY, GEORGIA 31513 • Tel. (912) 367-1151

NAME	<u>Mack + Bridgette McDaniel</u>	ACCOUNT NO.	
MAIL ADDRESS	<u>1747 Azalea Rd.</u>	DATE ORDERED	
CITY/STATE/ZIP	<u>Baxley GA 31513</u>	C. TE PROMISED	
PHONE	<u>912-253-3341</u>	DATE COMPLETED	<u>6-26-26</u>
LOCATION		TERMS	

INSTRUCTIONS install 250 gallon AG/UG tank, do final hook up + install
all gas appliances

QTY.	TAG NO. AND DESCRIPTION OF APPLIANCE/MATERIAL	UNIT PRICE	SALES AMOUNT
1	Quality Steel 250 gallon AG/UG tank		2500 00
1	Anode bag		200 00
1	Rego LV4403TR9 high pressure regulator		69 95
1	Rego 30" dielectric pigtail		29 95
1	Rego LV4403Y4 2 psi regulator		79 95
1	Rego LV4403R66R second stage regulator		74 95
30'	1/2" coated copper tubing	3 99	119 70
20'	3/8" coated copper tubing	2 99	59 80
1	1/2" cut off valve		16 95
All	other gas fittings, h.p. gas hoses, thread sealant etc.		209 20

SERVICEMAN TO COMPLETE IN
PRESENCE OF CUSTOMER:1) STORAGE SYSTEM INSTALLED
IN COMPLIANCE WITH N.F.P.A.
PAMPHLET NUMBER 58 ☐2) ALL APPLIANCES INSTALLED IN
COMPLIANCE WITH N.F.P.A.
PAMPHLET NUMBER 54 ☐

SERVICES PERFORMED

installed 250 gallon
tank is ground, completed final install
reg pressure check, lit + checked out
appliancesTOTAL
MATERIAL

3360 45

TOTAL TIME _____ HOURS

LABOR

1300 00

THE ODOR CHARACTERISTICS HAVE
BEEN DEMONSTRATED TO ME.

SERVICES PERFORMED

BY Dr. / L.R.

SUBTOTAL

SALES TAX

268 84

TOTAL DUE

4929 29

CUSTOMER'S SIGNATURE

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

INSTALLATION OR TURN ON	REMOVAL OR TURN OFF	LEAK AND PRESSURE TEST	
		HIGH	LOW
SIZE: <u>250</u>	SIZE	START LOCK UP:	START LOCK UP:
S/N: <u>1524252</u>	S/N:	TANK OFF PRESSURE:	TANK OFF PRESSURE:
GALLONS OR READING: <u>200</u>	GALLONS OR READING:	AFTER 10 MINUTES:	AFTER 10 MINUTES:
		PRESSURE AS LEFT:	PRESSURE AS LEFT:

- GP&A rebate 400.00
RECEIVED \$ 4529.29

RECEIVED
BY _____
DATE _____
SERVICES RECEIVED
BY _____



INVOICE

11375

HOME OWNED & OPERATED

P.O. BOX 506 • BAXLEY, GEORGIA 31515
2174 HATCH PARKWAY SOUTH • BAXLEY, GEORGIA 31513 • Tel. (912) 367-1151

NAME	<u>Mark & Bridgette McDaniel</u>	ACCOUNT NO.	_____
MAIL ADDRESS	<u>1747 Azalea Rd.</u>	DATE ORDERED	_____
CITY/STATE/ZIP	<u>Baxley GA 31513</u>	C. TE PROMISED	_____
PHONE	<u>912-253-3341</u>	DATE COMPLETED	<u>6-26-26</u>
LOCATION	_____	TERMS	_____

INSTRUCTIONS

QTY.	TAG NO. AND DESCRIPTION OF APPLIANCE/MATERIAL	UNIT PRICE	SALES AMOUNT
1	True Flame AMD-RFR-15G refrigerator		1709 10
1	True Flame AMD-RTK-15-A ref. toasting kit		161 10
1	True Flame TFG-30L griddle		2159 10
1	True Flame TF-DC2-30-A 2-drawer + door combo		1007 10
1	True Flame TF-DR3-17-A triple drawers		1007 10
200	gallon of propane	2.89	578 00

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:

1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 ☐2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 ☐

SERVICES PERFORMED

delivered outdoor

TOTAL MATERIAL

4607 30Kitchen package, continued from inv #
11376

TOTAL TIME _____ HOURS

LABOR

THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.

SERVICES PERFORMED

BY

[Signature]

SUBTOTAL

SALES TAX

368 58

TOTAL DUE

4975 88

CUSTOMER'S SIGNATURE

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

INSTALLATION OR TURN ON	REMOVAL OR TURN OFF	LEAK AND PRESSURE TEST	
		HIGH	LOW
SIZE:	SIZE	START LOCK UP:	START LOCK UP:
S/N:	S/N:	TANK OFF PRESSURE:	TANK OFF PRESSURE:
GALLONS OR READING:	GALLONS OR READING:	AFTER 10 MINUTES:	AFTER 10 MINUTES:
		PRESSURE AS LEFT:	PRESSURE AS LEFT:

AMOUNT RECEIVED \$ _____

RECEIVED BY _____

DATE _____

SERVICES RECEIVED BY _____

WHITE/CUSTOMER'S COPY; YELLOW/POSTING COPY; PINK/FILE COPY



HOME OWNED & OPERATED

P.O. BOX 506 • BAXLEY, GEORGIA 31515

2174 HATCH PARKWAY SOUTH • BAXLEY, GEORGIA 31513 • Tel. (912) 367-1151

INVOICE
No. 10998

NAME	<u>Mark & Bridgette McDaniel</u>	ACCOUNT NO.	
MAIL ADDRESS	<u>1747 Azalea Rd</u>	DATE ORDERED	<u>10-30-25</u>
CITY/STATE/ZIP	<u>Baxley GA 31513</u>	DATE PROMISED	
PHONE	<u>912-353-3341</u>	DATE COMPLETED	<u>11-24-25</u>
LOCATION		TERMS	

INSTRUCTIONS

QTY	TAG NO. AND DESCRIPTION OF APPLIANCE/MATERIAL	UNIT PRICE	SALES AMOUNT
1	Empire roof/side vent kit		379.00
1	Rinnert RE180 tankless water heater w/valves valves - serial # TF.4A-083109		1285.00
1	Rinnert RE199 tankless water heater w/valves valves - serial # TB.4A-022492		1500.00
2	Rinnert RGRRE recess box	319.00	638.00
120	3/4" True pipe	6.59	790.80
45	1/2" True pipe	5.09	229.05
1	Gas Ox box		39.99
60	3/4" coated copper	2.79	167.40

SERVICEMAN TO COMPLETE IN
PRESENCE OF CUSTOMER:

1) STORAGE SYSTEM INSTALLED
IN COMPLIANCE WITH N.F.P.A.
PAMPHLET NUMBER 58 ☐

2) ALL APPLIANCES INSTALLED IN
COMPLIANCE WITH N.F.P.A.
PAMPHLET NUMBER 54 ☐

SERVICES PERFORMED

TOTAL
MATERIAL

5029.24

TOTAL TIME HOURS

LABOR

THE OOR CHARACTERISTICS HAVE
BEEN DEMONSTRATED TO ME.

SERVICES PERFORMED

SUBTOTAL

BY

SALES TAX

402.34

X
CUSTOMER'S SIGNATURE

TOTAL DUE

5431.58

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

INSTALLATION OR TURN ON	REMOVAL OR TURN OFF	LEAK AND PRESSURE TEST	
		HIGH	LOW
SIZE	SIZE	START LOCK UP:	START LOCK UP:
S/N	S/N	TANK OFF PRESSURE:	TANK OFF PRESSURE:
		AFTER 10 MINUTES:	AFTER 10 MINUTES:
	GALLONS OR READING:	PRESSURE AS LEFT:	PRESSURE AS LEFT:

AMOUNT
RECEIVED \$

RECEIVED
BY

DATE

SERVICES RECEIVED
BY

GASCheck - Gas Appliance System Check

Account Name _____ Invoice Number _____ Date 6/26/26
 Name Mark & Bridgette McDaniel Company Sikes Propane, Inc.
 Address 1747 Azalea Rd. Call Taken By _____
 City Baxley State GA Zip 31513 Telephone (Cell) 912-253-3341 (Home) _____

Appliance Check

Appliance	water heater	water heater	Range	Gas Logs	Generator	Gas Grill
Manufacturer	Rinnai	Rinnai	Forno	Empire	Generac	True Flame
Model #	RE199e	RE180e	FFSG66187-36		G00721010	
Serial #	TB.4A-022692	TF.4A-083109			3017982762	
BTU's	199,000	180,000			355,000	
Burner / Com. Chamber	ok	ok	ok	ok	ok	ok
Man. Shutoff / Sed. Trap	installed	installed	installed	installed	installed	installed
Control / Pilot Safety System	ok	ok	ok	ok	ok	ok
Venting System	ok	ok	ok	ok	ok	ok
Age	new	new	new	new	new	new
Taken Out Of Service Or Operation						

Container Check

Size	Serial #	Manufacturer	MFR. Date	Location	Container Condition	Relief Valve	Fittings Leak Check
250	1524852	Quality Steel	2024	ok	new	07E23	ok

Pressure Test (If Applicable)

Start Pressure	End Pressure	Time Held	Pressure Held
130psi.	130psi.	10min.	0 N Work Order 0 N

Piping Check

Materials	Size	Cover / Protection
Coated copper	1/2" & 3/8"	ok
Trac pipe	3/4" & 1/2"	ok

System Leak Check

Start Pressure	End Pressure	Time Held	Pressure Held
9 in. wc.	9 in. wc.	10min.	0 N Work Order 0 N

Regulator Check

Type	Manufacturer	Date / Model	Vent Position / Protection
First	Rego	09B2025 / LV4403TR9	u-c
second	Rego	10D2025 / LV4403B66R	down
second	Rego	04B2024 / LV4403Y4	down
second	Maxitrol	③-325-5L, ①-325-3L	horizontal

Safety Information Supplied:

Comments: Please note all repairs and corrections made along with any recommended actions.