



congerlpgas.com

127753

146 S. Ridge Ave.
Tifton, GA 31794
(229) 386-5574

306 S. Main St.
Sylvester, GA 31791
(229) 776-7336

604-B N. Broadfoot Blvd.
Vidalia, GA 30474
(912) 537-8722

3117 Veterans Parkway S.
Moultrie, GA 31788
(229) 985-6942

2310-B Highway 84 W
Valdosta, GA 31602
(229) 469-4250

NAME Lyn Martin RT# _____ RT. SEQ. _____ ACCT # 7-18120 DATE 9-30-26 INT _____

MAILING ADDRESS _____ CO. _____ CITY _____

ADDRESS 606 Pear Orchard LN APT/LOT NO. _____

CITY Statesboro STATE GA ZIP CODE 30458

SERVICE REQUESTED: ☐ CASH ☐ CHARGE DATE PROMISED _____

NEW CUSTOMER INFORMATION

S.S. NO. _____ DELV _____
HOME PH _____ RENT _____
WORK PH _____ CREDIT _____
LITE PILOT _____ PC _____
EMPLOYER _____
DR. _____ USE _____ LEASE _____

email: _____

cell # 912 687 6100

PAY BILL ONLINE @congerlpgas.com

DIRECTIONS:

TANK PICKUP/SET	TANK SIZE	SERIAL #	TANK %	TANK DESTINATION	DOT PERMANENTLY INSTALLED CONTAINERS				
					MANUFACTURED DATE	LAST TEST DATE	SIZE	SERIAL #	% FULL

QTY	APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED	MODEL #	SERIAL NUMBER	UNIT PRICE	SALES AMOUNT
1	Rel60		WC. 4A-027960	10.94 15	10.94 95
1	connecting cable			150.00	150.00
3	Big Pieces			3.95	11.85
2	V2 STA			39.95	79.90
1	1/2" JMC			24.95	24.95
3	1/2" JMC			7.85	23.55
1	3/4" UNIC			12.95	12.95

WORK PERFORMED: <u>Hang WRA & connect</u>	REGULATION INFORMATION	APPLIANCES/EQUIP. SOLD	CODE	10.94 15	95
<u>Gas, NO Leaks</u>	MAKE: <u>REGO</u>	PARTS/MAT. USED		311.40	95
	DATE CODE: <u>04016</u>	TANK RENT	<u>CR</u>	(200.00)	
SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE				<u>COMP</u>	18.95 1.7
SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:		LEAK AND PRESSURE TEST		SALES TAX	
1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 ☐	HIGH: 1st Stage 2nd Stage LOW			%	
2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 ☐	START LOCK-UP: 10 PSI	START LOCK-UP: W.C.	LABOR	200.00	
I HAVE RECEIVED A SCRATCH AND SNIFF BROCHURE AND THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.	TANK OFF: 6 PSI	TANK OFF: W.C.	MS	30.68	2.7
	AFTER 10 MINUTES: 6 PSI	AFTER 10 MINUTES: W.C.			
	PRESSURE AS LEFT: 10 PSI	PRESSURE AS LEFT: W.C.			
X	PIPING PRESSURE TEST		INV. TOTAL	1792.48	
CUSTOMER SIGNATURE	START PSIG	FINISH PSIG	AMOUNT RECEIVED		

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE.

Jackson Hudley
SERVICE REP. SIGNATURE

9/30/26
DATE

x

CUSTOMER SIGNATURE