11/3/2026 1:17:45 PM

WORK ORDER

Logan Fitts

973 Jolley Way
Epworth, GA 30541
(706) 851-4486

Customer #: 207086
Order #: 569696
Location #: 283487
Zone: B-005-TUE-
Terms: Net 30

Tech: _____

Map Code:
Service Code: Propane Service
Description: 11/12/2026 - GO 1ST! JOHNNY TO BURY - T/I 325UG W/260G@2.499G. RUN YARD LINE. T/I RXP160 W/3YR CONTRACT, RUN LINES AND HOOK UP, W/HEATER, HVAC, LOGS, AND C/C STOVE KIT ON SITE - CALL 706-851-4486 - EMAIL INVOICE - CT

Date Ordered: 11/3/2026	Scheduled Date:	Est. Completion:	Start:	Stop:

Name:
Contract:
Manufact:
Notes:
Instructions:

Last Service:
SC Renewal:
Model:

Last Tune Up:

Service History:

Date	Invoice #	Tech	Problem Reported	Service Notes

PROPANE GAS PIPING SYSTEM CHECK

FolgerGas PROPANE — GAS CHECK

Customer Account #: 207086

Name: LOGAN FITTS

Address: 973 JOLLEY WAY
EPWORTH, GA 30541

Date: 11/12/26

Instructions: GO1ST! JOHNNY TO BURY. T/I 325UGW/260@ 2.499G RUN YD LINE. T/I RXP160 W/3YR, RUN LINE TO AND HOOK UP HVAC, W/H, LOGS, AND C/C STOVE

Order #: 569696 KIT ON SITE EMAIL INVOICE

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

Appliance Check:

Appliance	W H	Stove	fireplace			
Manufacturer	Rinnai	Forna	linear			
Model #	RXP160i	24110272	VFLB60FP90			
Serial #	WC BA-034	FFSGS6244	N/A			
Burner/Combustion Chamber	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Manual Shutoff	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Sediment Trap	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Pilot Safety System	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Electronic Ignition System	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Venting System	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Combustion Air	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Taken Out of Service	☐ Yes ☑ No	☐ Yes ☑ No	☐ Yes ☑ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No

Container Check:

Size	Serial #	Container Fitting Leak Test	Manufacturer	Manufacture Date	Location	Tank Condition
320	M2542406	good	triarc	2025	Vg	good

Regulator(s):

	Manufacturer	Model	Regulator Date	Regulator Venting	Flow/Delivery Pressure	Lock-Up Pressure
Twin				☐ Correct ☐ Incorrect		
1st	Rego	3TR9	2026	☑ Correct ☐ Incorrect		
2nd	Rego	Y4	2025	☑ Correct ☐ Incorrect	11.6	13.6

Piping System Leak Test:

Start Pressure	End Pressure	Time Held	Pass
60 PSI ___ WC	60 PSI ___ WC	10 Mins ___ Mins	☑ Yes ☐ No

Pressure Test:

Start Pressure	End Pressure	Time Held	Pass
15 PSI	15 PSI	10 Mins	☑ Yes ☐ No

Comments: Could not test or convert WH. No power.

Customer Acknowledgment: I acknowledge, by checking each of the following items, that:

- ☐ I have informed the service technician of all gas-burning appliances, gas lines, and unused piping not connected to any gas appliance on my property.
- ☐ I have been informed of what deficiencies, repairs &/or alterations, if any, were made to my gas system or appliances.
- ☐ I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas supply off at the tank or cylinder.
- ☐ I have smelled propane gas and can detect its odor.
- ☐ I have been told to consider installing one or more gas detectors.
- ☐ I have received safety information and told to read it and share it with all family members.
- ☐ I am satisfied with the service work performed.

Service Technician (Print)	Service Technician (Signature)	Date
Brandon Payne		
Customer (Print)	Customer (Signature)	Date

FolgerGas LLC PROPANE

www.folgergas.com

RINNAI WORK ORDER

Customer Acct #: 207086

Name LOGAN FITTS

Address 973 JOLLEY WAY
EPWORTH, GO 30541

Date: 11/12/26

Instructions: GO 1ST! JOHNNY TO BURY. T/I 325UGW/ 260G@2.499G. T/I RXP160 W/3YR, RUN YD, RUN LINE TO AND HOOK UP HVAC, W/H, LOGS, AND C/C STOVE

Order # 569696 KIT ON SITE EMAIL INVOICE

DESCRIPTION OF WORK

COMMENTS:

SERVICED BY:

DATE	START TIME	FINISH TIME	TOTAL TIME	LABOR RATE	AMOUNT
11/12/26	9:30	2:30	1.5 HR	100.00/hr	INCLUDED IN CONTRACT PRICE
				100.00/hr	

FOR OFFICE USE ONLY

Performed leak check ✓ Yes ____ No

Gas check attached ✓ Yes ____ No

Leak check Initial BP

Start Pressure	End Pressure	Time Held	System OK
100	100	10	Yes

% in Tank

AMOUNT REC'D

$ ____

☐ CASH ☐ CHECK # ____

☐ CREDIT CARD

____

EXP. DATE ____

* I have received the Consumer Safety information & material.
* I am satisfied with the work performed.
* Customer agrees to pay all costs of collection, agency fees, court costs, and reasonable attorney fees in the event of default on payment.
* Signing agrees to 3 year contract for discount.

CUSTOMER SIGNATURE

	Retail Price	Contract Price	
RXP160innai	$2556.00	$2449.95	
Standard Vent Kit	$393.95	$0.00	
Standard Install	$400.00	$0.00	
Total	$3349.95	$2449.95	2449.95
Tank Set		**New Cust Special**	
L.P. Gas /Gal	3.199	L.P. Gas /Gal 2.499	
Gallons	260	Gallons 260	
FRCC	$9.79	FRCC $9.79	9.79
Fuel Total	639.90	Fuel Total 499.80	499.80
Tank Lease/YR	129.00	1st yr Lease FREE	FREE
Total Materials			
Sub-Total			
Sales Tax			
Tank Set Fee	$250	Tank Set Fee 20.00	20.00
Safety Inspection	$129.95	$29.95	29.95
Total Labor			
Total charges			
Prepay Bal On Account			
Safe Appliance Savings			1517.83
Safe Appliance Rebate			250.00
			1517.83

TOTAL BALANCE DUE