



congerlpgas.com

115073

146 S. Ridge Ave.
Tifton, GA 31794
(229) 386-5574306 S. Main St.
Sylvester, GA 31791
(229) 776-7336604-B N. Broadfoot Blvd.
Vidalia, GA 30474
(912) 537-87223117 Veterans Parkway S.
Moultrie, GA 31788
(229) 985-69422310-B Highway 84 W
Valdosta, GA 31602
(229) 469-4250NAME Lindsay Crews RT# _____ RT. SEQ. _____ ACCT # 7-02843 DATE 6-29-26 INT _____

MAILING ADDRESS _____ CO. _____ CITY _____

ADDRESS 820 Ben Roy Mcendon Rd APT/LOT NO. _____CITY Lyons STATE _____ ZIP CODE 30436SERVICE REQUESTED: ☐ CASH ☐ CHARGE DATE PROMISED _____look @ water heaters

DIRECTIONS: _____

NEW CUSTOMER INFORMATION

S.S. NO. _____ DELV _____
HOME PH _____ RENT _____
WORK PH _____ CREDIT _____
LITE PILOT _____ PC _____
EMPLOYER _____
DR. _____ USE _____ LEASE _____

email: _____

cell # 706 288 4672

PAY BILL ONLINE @congerlpgas.com

TANK PICKUP/SET	TANK SIZE	SERIAL #	TANK %	TANK DESTINATION	DOT PERMANENTLY INSTALLED CONTAINERS				
					MANUFACTURED DATE	LAST TEST DATE	SIZE	SERIAL #	% FULL

QTY	APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED	MODEL #	SERIAL NUMBER	UNIT PRICE	SALES AMOUNT
1	Rx130	Rx130i	WA-BA-012470		1599.99
2	vent pipe "2 in. PVC."				7.95

WORK PERFORMED: <u>Install new WIA</u>	REGULATION INFORMATION		APPLIANCES/ EQUIP. SOLD	CODE	1599.99
<u>To replace old one</u>	MAKE: <u>REGO</u>	MODEL: <u> </u>	PARTS/MAT. USED		7.95
<u>No leaks</u>	DATE CODE: <u>9-10</u>	VENT: <u>burn</u>	TANK RENT		

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:

- 1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 ☐
- 2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A PAMPHLET NUMBER 54 ☐

I HAVE RECEIVED A SCRATCH AND SNIFF BROCHURE AND THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.

X

CUSTOMER SIGNATURE

LEAK AND PRESSURE TEST				SALES TAX _____ %	LABOR		
HIGH:	1st Stage	2nd Stage	LOW				
START LOCK-UP:	PSI	PSI	START LOCK-UP:	12 W.C.		300.00	
TANK OFF: PRESSURE	PSI	PSI	TANK OFF: PRESSURE	6 W.C.	ms	12.48	
AFTER 10 MINUTES:	PSI	PSI	AFTER 10 MINUTES:	6 W.C.		(200.00)	
PRESSURE AS LEFT:	PSI	PSI	PRESSURE AS LEFT:	12 W.C.			
PIPING PRESSURE TEST				INV. TOTAL		1970.49	
START	PSIG	FINISH	PSIG	AMOUNT RECEIVED			

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE.

Jackson Hester
SERVICE REP. SIGNATURE7/1/26
DATE

X

CUSTOMER SIGNATURE