PARTNERS
Propane of GA, Inc.

PARTNERS PROPANE OF GA, INC.
PO BOX 277
BUTLER, GA 31006
(478) 862-4644

Cust ID BUCMIK
Account # 321
Invoice # S0014979
Invoice Date 11/3/2026

Sold To
MIKE BUCKNER
780 FIELDERS MILL RD
JUNCTION CITY, GA 31812-4618

Shipped To Location 3
MIKE BUCKNER
RENTAL HOUSE
3742 BUCKNER RD
JUNCTION CITY, GA 31812

Date 11/3/2026
Salesperson 7
PO #
Terms due upon receipt
Order Date
Ship Via

Quantity	Category	Description	Unit Price	Amount
4.00	40-8	1/2" Flare Nut	2.5000	$10.00
		REGULAR SALES TAXABLE		0.80
2.00	50-8-12	1/2"X3/4" Fl Fem Elbow	5.0000	$10.00
		REGULAR SALES TAXABLE		0.80
6.00	12R50	1/2" COPPER TUBING	4.0000	$24.00
		REGULAR SALES TAXABLE		1.92
2.00	38R50	3/8" COPPER TUBING	3.5000	$7.00
		REGULAR SALES TAXABLE		0.56
2.00	42-8	1/2" Flare Union	3.0000	$6.00
		REGULAR SALES TAXABLE		0.48
2.00	40-6	3/8" Flare Nut	2.0000	$4.00
		REGULAR SALES TAXABLE		0.32
1.00	42-6	3/8" Flare Union	2.3000	$2.30
		REGULAR SALES TAXABLE		0.17
1.00	45226	3/4 X Close Black Nipple	2.5000	$2.50
		REGULAR SALES TAXABLE		0.22
1.00	46-6-12	3/8"X3/4" Fl X Fem Conn	2.0000	$2.00
		REGULAR SALES TAXABLE		0.16
1.00	PROG40	Rheem 40 tall Water Heat	867.0000	$867.00
		REGULAR SALES TAXABLE		69.36
1.00		PERF REBATE	-200.0000	($200.00)
1.00		LABOR	125.0000	$125.00

Subtotal	$859.80
GA TALBOT CO TAX	$74.79
HEADER	
Invoice Total	$934.59
Total Due	$934.59

PARTNERS Propane of G-A Inc.

INTERRUPTION OF SERVICE

P3 PROPANE SAFETY

Account # 321 Name MIKE BUCKNER Address [3] RENTAL HOUSE 3742 BUCKNER RD City JUNCTION CITY

State GA Zip 31812 Phone 0 Date of Inspection 11/03/2026 Branch/Location Work Order #

REASON

☐ Leak and System Check ☐ Out of Gas ☐ Gas Leak/Odor Complaint ☐ Install New Gas Piping ☐ Put System/Appliance Back in Service
☐ Container Swap ☐ Container Drop-Off/Pick-Up ☐ Regulator Replacement ☒ Other: Install water heater

Equipment Type	Water Heater				
Manufacturer	Rheem				
Year Manufactured					
Model #	Prog40-32p rh62				
Serial #	q062628611				
Fuel	Propane				
BTUs (Maximum Input)	32,000				
Manual Shutoff Valve	OK				
Sediment Trap	NO				
Burner(s) Condition	OK				
Combustion Chamber Condition	OK				
Control/Pilot Safety System	OK Pilot				
Venting System	OK				
Combustion Air	Service Not Provided				
Taken Out of Svc or Operation (Tag #)	No				

System Type	System Leak Check ☒ Entire System						Pressure Test						System Operation Tests			
	Initial/Start Pressure		End Pressure		Start Time	End Time	Start Pressure		End Pressure		Start Time	End Time	Flow Pressure Test		Lock-Up Pressure Test	
Inte Stage	13 / 7	☒WC ☐PSI	7	☒WC ☐PSI	11:50	11:55	10	PSI	10	PSI	11:40	11:50	11	☒WC ☐PSI	13	☒WC ☐PSI
___Stage	/	☐WC ☐PSI		☐WC ☐PSI				PSI		PSI				☐WC ☐PSI		☐WC ☐PSI
___Stage	/	☐WC ☐PSI		☐WC ☐PSI				PSI		PSI				☐WC ☐PSI		☐WC ☐PSI
___Stage	/	☐WC ☐PSI		☐WC ☐PSI				PSI		PSI				☐WC ☐PSI		☐WC ☐PSI

PERFORMED SNIFF TEST ☒ Y ☐ N

COMMENTS:

Installed 40 gallon tank type water heater. Leak tested, lit and checked.
Equipment: Water Heater Serial# q062628611;

Tyler Robinson
Service Technician Name - Print

Service Technician Signature 11/03/2026 Date

MIKE BUCKNER
Customer Name - Print

Customer Signature 11/03/2026 Date

V2

© 2026 Boston Environmental, LLC