

WORK ORDER

Sarah Fervier

65 Horizon Lane
Epworth, GA 30541
(770) 656-8159

Customer #: 201993
Order #: 516491
Location #: 248009
Zone: B-005-TUE-
Terms: Net 30

Map Code:

Service Code: Propane Service

Description: 7/2/26 Convert and connect stove Kit on Site Call 770-363-4463
CCOF-CLT

Tech:

Date Ordered:	6/23/2026	Scheduled Date:	Est. Completion:	Start:	Stop:
---------------	-----------	-----------------	------------------	--------	-------

Name:	Heating System	Last Service:	10/30/2023	Last Tune Up:
Contract:		SC Renewal:		
Manufact:		Model:		
Notes:				
Instructions:				

Service History:

Date	Invoice #	Tech	Problem Reported	Service Notes
------	-----------	------	------------------	---------------



PROPANE GAS PIPING SYSTEM CHECK

Customer Account #: 201993

Date: 7/2/26

Name: SARAH FERVIER

Instructions: C/C STOVE KIT ON SITE CCOF-CLT

Address: 65 HORIZON LANE

EPWORTH GA 30541

Order #516491

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

Appliance Check:

Appliance	Stove					
Manufacturer	G.E.					
Model #	GG5500SV255					
Serial #	LD143490G					
Burner/Combustion Chamber	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Manual Shutoff	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Sediment Trap	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Pilot Safety System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Electronic Ignition System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Venting System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Combustion Air	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Taken Out of Service	☐ Yes ☒ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No

Container Check:

Size	Serial #	Container Fitting Leak Test	Manufacturer	Manufacture Date	Location	Tank Condition
250	25G051001	Good	American	2000	P.G.	Good

Regulator(s):

Manufacturer	Model	Regulator Date	Regulator Venting	Flow/Delivery Pressure	Lock-Up Pressure
Twin			☐ Correct ☐ Incorrect		
1st	Rego	113403TR9	N.V.	☒ Correct ☐ Incorrect	
2nd	Rego	3403B4	N.V.	☒ Correct ☐ Incorrect	11.3

Piping System Leak Test:

Pressure Test:

Start Pressure	End Pressure	Time Held	Pass	Start Pressure	End Pressure	Time Held	Pass
110 PSI	110 PSI	10 Mins	☒ Yes	15 PSI	15 PSI	10 Mins	☒ Yes
WC	WC	Mins	☐ No				☐ No

Comments:

Customer Acknowledgment:

I acknowledge, by checking each of the following items, that:

- ☐ I have informed the service technician of all gas-burning appliances, gas lines, and unused piping not connected to any gas appliance on my property.
- ☐ I have been informed of what deficiencies, repairs &/or alterations, if any, were made to my gas system or appliances.
- ☐ I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas supply off at the tank or cylinder.
- ☐ I have smelled propane gas and can detect its odor.
- ☐ I have been told to consider installing one or more gas detectors.
- ☐ I have received safety information and told to read it and share it with all family members.
- ☐ I am satisfied with the service work performed.

Service Technician (Print) Brandon Payne	Service Technician (Signature) Brandon Payne	Date 7-2-26
Customer (Print)	Customer (Signature)	Date



www.folgergas.com

RINNAI WORK ORDER

Customer Acct #: 201993
Name **SARAH FERVIER**
Address **65 HORIZON LN**
EPWORTH GA 30541

Date: 6-26-26
Instructions: T/I 250 W/ 200G @ 2.499 CONNECT
TO LINES ALREADY THERE CCOF SM
Order #: 516491

DESCRIPTION OF WORK
COMMENTS:
SERVICED BY:

DATE	START TIME	FINISH TIME	TOTAL TIME	LABOR RATE	AMOUNT
				100.00/hr	
				100.00/hr	

FOR OFFICE USE ONLY	
Performed leak check	Yes No
Gas check attached	Yes No
Leak check	Initial
Start Pressure	End Pressure Time Held System OK

% in Tank

AMOUNT REC'D
\$
☐ CASH ☐ CHECK #
☐ CREDIT CARD
#
EXP. DATE
* I have received the Consumer Safety information & material. * I am satisfied with the work performed. * Customer agrees to pay all costs of collection, agency fees, court costs, and reasonable attorney fees in the event of default on payment. * Signing agrees to year contract for discount.
CUSTOMER SIGNATURE

Retail Price		Contract Price
Rinnai	\$	\$
Standard Vent Kit	\$	
Standard Install	\$	
Total	\$	
Tank Set		New Cust Special
L.P. Gas /Gal	2.999	L.P. Gas /Gal 2.499
Gallons	200	Gallons 200
FRCC	\$9.79	FRCC \$9.79 9.79
Fuel Total	599.80	Fuel Total 499.80 499.80
Tank Lease/YR	99.00	1st yr Lease FREE FREE
Total Materials		
Sub-Total		
Sales Tax		
Tank Set Fee	\$250	Tank Set Fee 20.00 20.00
Safety Inspection	\$129.95	\$29.95 29.95
Total Labor		
Total charges		
Prepay Bal On Account		
Safe Appliance Savings		529.00
Safe Appliance Rebate		50.00
TOTAL BALANCE DUE		