

6/9/2026 9:53:26 AM

WORK ORDER

Scott Merritt

825 Oak Park Dr
Talking Rock, GA 30175
(678) 736-1461

Customer #: 206025
Order #: 514279
Location #: 282181
Zone:
Terms: Net 30

Tech: _____

Map Code:

Service Code: Propane Service

Description: ~~7/4/26~~ Final hook W/H - STOVE - GRILL - FURNACE run yd line
Per Mike Call (678) 736-1461 CCOF - CLT

Date Ordered: 6/9/2026	Scheduled Date:	Est. Completion:	Start:	Stop:
------------------------	-----------------	------------------	--------	-------

Name:

Contract:

Manufact:

Notes:

Instructions:

Last Service: 5/5/2026

SC Renewal:

Model:

Last Tune Up:

Service History:

Date	Invoice #	Tech	Problem Reported	Service Notes
------	-----------	------	------------------	---------------



PROPANE GAS PIPING SYSTEM CHECK

Customer Account #: 206025

Date: 7-1-26

Name: scott merritt

Instructions: FINAL HOOK UP W/H GRILL STOVE FURNACE
RUN YARD LINE CCOF CLT

Address: 825 OAK PARK DR
TALKING ROCK GA 30175

Order #: 514279

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

Appliance Check:

Appliance	Stove	Furnace	Furnace	W/H		logistics
Manufacturer	Zline	Sunair	Sunair	Brina		NV
Model #	RA48	CAPTAS62GB3AB	CAPTAS62GB3AB	IREU-NBP3237FF-45		NV
Serial #	RA48BE2603005CN-09	2511099758	2501334274	Im.BA-274628		NV
Burner/Combustion Chamber	☒ Ok	☒ Ok	☒ Ok	☒ Ok	☐ Ok	☒ Ok
Manual Shutoff	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☒ Ok ☐ N/A
Sediment Trap	☒ Ok	☒ Ok	☒ Ok	☒ Ok	☐ Ok	☒ Ok
Pilot Safety System	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☒ Ok ☐ N/A
Electronic Ignition System	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☒ Ok ☐ N/A
Venting System	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☒ Ok ☐ N/A
Combustion Air	☒ Ok	☒ Ok	☒ Ok	☒ Ok	☐ Ok	☒ Ok
Taken Out of Service	☐ Yes ☒ No	☐ Yes ☒ No	☐ Yes ☒ No	☐ Yes ☒ No	☐ Yes ☐ No	☐ Yes ☒ No

Container Check:

Size	Serial #	Container Fitting Leak Test	Manufacturer	Manufacture Date	Location	Tank Condition
500	m2600950	Good	Tricat	2026	UG	Good

Regulator(s):

Manufacturer	Model	Regulator Date	Regulator Venting	Flow/Delivery Pressure	Lock-Up Pressure
Twin			☐ Correct ☐ Incorrect		
1st	MEC	3-5-14-25	☒ Correct ☐ Incorrect		
2nd	IRE50	5-25	☒ Correct ☐ Incorrect	11.4	12.7

Piping System Leak Test:

Pressure Test:

Start Pressure	End Pressure	Time Held	Pass	Start Pressure	End Pressure	Time Held	Pass
110 PSI	110 PSI	10 Mins	☒ Yes	15 PSI	15 PSI	10 Mins	☒ Yes
WC	WC	Mins	☐ No				☐ No

Comments:

Customer Acknowledgment:

I acknowledge, by checking each of the following items, that:

- ☐ I have informed the service technician of all gas-burning appliances, gas lines, and unused piping not connected to any gas appliance on my property.
- ☐ I have been informed of what deficiencies, repairs &/or alterations, if any, were made to my gas system or appliances.
- ☐ I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas supply off at the tank or cylinder.
- ☐ I have smelled propane gas and can detect its odor.
- ☐ I have been told to consider installing one or more gas detectors.
- ☐ I have received safety information and told to read it and share it with all family members.
- ☐ I am satisfied with the service work performed.

Service Technician (Print)	Alvin Wilcox	Service Technician (Signature)	[Signature]	Date	7-6-2026
Customer (Print)	Customer not present	Customer (Signature)		Date	



www.folgergas.com

RINNAI WORK ORDER

Customer Acct #: 206025
Name SCOTT MERITT
Address 825 OAK PARK DR
TALIKING ROCK GA 30175

Date: 6-5-26
Instructions: T/I 500 W/400G @ 2.400 RUN YARD LI
LINE CCOF CLT
Order #: 498312

DESCRIPTION OF WORK

COMMENTS:

SERVICED BY:

DATE	START TIME	FINISH TIME	TOTAL TIME	LABOR RATE	AMOUNT
				100.00/hr	
				100.00/hr	

FOR OFFICE USE ONLY

Performed leak check Yes No
Gas check attached Yes No
Leak check Initial

Start Pressure End Pressure Time Held System OK

% in Tank

AMOUNT REC'D

\$

☐ CASH ☐ CHECK #

☐ CREDIT CARD

EXP. DATE

- * I have received the Consumer Safety information & material.
- * I am satisfied with the work performed.
- * Customer agrees to pay all costs of collection, agency fees, court costs, and reasonable attorney fees in the event of default on payment.
- * Signing agrees to year contract for discount.

CUSTOMER SIGNATURE

Retail Price

Contract Price

Rinnai	\$	\$
Standard Vent Kit	\$	\$
Standard Install	\$	\$
Total	\$	\$

Tank Set

New Cust Special

L.P. Gas /Gal	2.999	L.P. Gas /Gal	2.499
Gallons	400	Gallons	400
FRCC	\$9.79	FRCC	\$9.79
Fuel Total	1199.60	Fuel Total	1130.00
Tank Lease/YR	99.00	1st yr Lease	FREE

9.79

1130.00

FREE

Total Materials

Sub-Total

Sales Tax

Tank Set Fee \$250 Tank Set Fee 20.00 20.00

Safety Inspection \$129.95 \$29.95 29.95

Total Labor

Total charges

Prepay Bal On Account

Safe Appliance Savings 671.56

Safe Appliance Rebate 650.00

TOTAL BALANCE DUE