

129089

NAME Keith Knight-Linger RT# _____ RT. SEQ. _____ ACCT # 1-12837 DATE 6/16/26 INT 1/2

MAILING ADDRESS _____ CO. _____ CITY _____

ADDRESS 72 Edge water Dr. APT/LOT NO. _____

CITY Dillon STATE GA ZIP CODE 31783

NEW CUSTOMER INFORMATION

S.S. NO. _____ DELV _____
HOME PH _____ RENT _____
WORK PH _____ CREDIT _____
LITE PILOT _____ PC _____
EMPLOYER _____
DR. _____ USE _____ LEASE _____

email: kknight@uga.edu

cell # 229-402-0852

PAY BILL ONLINE @congerlpgas.com

SERVICE REQUESTED: ☐ CASH ☐ CHARGE DATE PROMISED _____

Try to complete before 7/9 if not
start after 7/13

DIRECTIONS:

TANK PICKUP/SET	TANK SIZE	SERIAL #	TANK %	TANK DESTINATION	DOT PERMANENTLY INSTALLED CONTAINERS				
					MANUFACTURED DATE	LAST TEST DATE	SIZE	SERIAL #	% FULL

QTY	APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED	MODEL #	SERIAL NUMBER	UNIT PRICE	SALES AMOUNT
21	Rinnia RE180CP	RE180CP	WDWA-040073		1199.95
1	Rinnia RE180CP	RE180CP	WDWA-040080		1199.95
150'	3/4" Tral			9.95	1,492.50
2	3/4" max. tral			105.95	211.90
1	446R Reg.				112.95
2	Sediment Trap's w/cutoff				99.90
5'	1/2" copper			7.95	39.75
2	1/2" flare nuts				5.90
1	3/4" wall flange				44.95

WORK PERFORMED:	REGULATION INFORMATION		APPLIANCES/EQUIP. SOLD	CODE	
	MAKE: <u>REGO</u>	MODEL: <u>JR9</u>	PARTS/MAT. USED	<u>WH</u>	1199.95
	DATE CODE: <u>07D1023</u>	VENT: <u>Down</u>	TANK-RENT	<u>mp</u>	2342.45
				<u>CF</u>	18.95

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:		LEAK AND PRESSURE TEST		SALES TAX	
1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 ☐		HIGH: 1st Stage 2nd Stage LOW		_____ %	
2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 ☐		START LOCK-UP: 9.2 PSI 2.0 PSI	START LOCK-UP: _____ W.C. LABOR		540.00
I HAVE RECEIVED A SCRATCH AND SNIFF BROCHURE AND THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.		TANK OFF: 6.0 PSI 1.5 PSI	TANK OFF: _____ W.C. GPC GR		(200.00)
		AFTER 10 MINUTES: 6.0 PSI 1.5 PSI	AFTER 10 MINUTES: _____ W.C. GPC GR		(200.00)
		PRESSURE AS LEFT: 9.0 PSI 6.0 PSI	PRESSURE AS LEFT: _____ W.C. MS		172.95
X _____ CUSTOMER SIGNATURE		PIPING PRESSURE TEST		Electrician <u>CB</u>	600.00
		START 6.0 PSIG FINISH 6.0 PSIG	In Total		6,069.01

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE.

Justin Seabolt
SERVICE REP. SIGNATURE

June 23rd 2026 x
DATE

CUSTOMER SIGNATURE