

6/29/2026 1:17:01 PM

WORK ORDER

Wally Stover

380 Utana Bluff Trail
Ellijay, GA 30540
(706) 273-6514

Customer #: 205920
Order #: 517169
Location #: 282031
Zone: B-042-TUE-
Terms: Net 30

Tech: _____

Map Code:

Service Code: Propane Service

Description: 7/01/26 - FINAL HOOK - HOUSE AND OUTDOOR PATIO AND
APPLIANCE - WILL NEED TO REG. 2 CALL WALLY
706-273-6514 - EMAIL INVOICE - CT

Date Ordered: 6/29/2026	Scheduled Date:	Est. Completion:	Start:	Stop:
-------------------------	-----------------	------------------	--------	-------

Name:

Last Service: 3/31/2026

Last Tune Up:

Contract:

SC Renewal:

Manufact:

Model:

Notes:

Instructions:

Service History:

Date	Invoice #	Tech	Problem Reported	Service Notes
------	-----------	------	------------------	---------------



PROPANE GAS PIPING SYSTEM CHECK

Customer Account #: 205920

Name: WALLY STOVER

Address: 380 UTANA BLUFF TRAIL

ELLIJAY, GA 30540

Date: 7/1/26

Instructions: FINAL HOOKE - HOUSE & OUTDOOR PATION A

APPLIANCE WILL NEED 2 REG CALL WALLY

706-273-6514 EMAIL INVOICE

Order #: 517169

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

Appliance Check:

Appliance	LOS Lighter	stove	furnace	generator		Water heater
Manufacturer	NV	GE	Lenox	Generac		navien
Model #	NV	R659304PFS	7021131BC	600721010		NPE-240A2CM
Serial #	NV	FD48B42P	N25062653419	3017255920		20870259057124
Burner/Combustion Chamber	☒ Ok	☒ Ok	☒ Ok	☒ Ok	☐ Ok	☒ Ok
Manual Shutoff	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☒ Ok ☐ N/A
Sediment Trap	☒ Ok	☒ Ok	☒ Ok	☒ Ok	☐ Ok	☒ Ok
Pilot Safety System	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☒ Ok ☐ N/A
Electronic Ignition System	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☒ Ok ☐ N/A
Venting System	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☒ Ok ☐ N/A
Combustion Air	☒ Ok	☒ Ok	☒ Ok	☒ Ok	☐ Ok	☒ Ok
Taken Out of Service	☐ Yes ☒ No	☐ Yes ☒ No	☐ Yes ☒ No	☐ Yes ☒ No	☐ Yes ☐ No	☐ Yes ☒ No

Container Check:

Size	Serial #	Container Fitting Leak Test	Manufacturer	Manufacture Date	Location	Tank Condition
1000	25fo 20598	Good	American	NV	UG	Good

Regulator(s):

Manufacturer	Model	Regulator Date	Regulator Venting	Flow/Delivery Pressure	Lock-Up Pressure
Twin			☐ Correct ☐ Incorrect		
1st	MEC	MEGR-122H 03J4125	☒ Correct ☐ Incorrect		
2nd	Rejo	3403B4 2023	☒ Correct ☐ Incorrect	11.1	13.2

Piping System Leak Test:

Pressure Test:

Start Pressure	End Pressure	Time Held	Pass	Start Pressure	End Pressure	Time Held	Pass
130 PSI	130 PSI	10 Mins	☒ Yes	15 PSI	15 PSI	10 Mins	☒ Yes
WC	WC	Mins	☐ No				☐ No

Comments:

Customer Acknowledgment: I acknowledge, by checking each of the following items, that:

- ☐ I have informed the service technician of all gas-burning appliances, gas lines, and unused piping not connected to any gas appliance on my property.
- ☐ I have been informed of what deficiencies, repairs &/or alterations, if any, were made to my gas system or appliances.
- ☐ I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas supply off at the tank or cylinder.
- ☐ I have smelled propane gas and can detect its odor.
- ☐ I have been told to consider installing one or more gas detectors.
- ☐ I have received safety information and told to read it and share it with all family members.
- ☐ I am satisfied with the service work performed.

Service Technician (Print)	Dillon Payne	Service Technician (Signature)	Dillon Payne	Date	7/1/26
Customer (Print)		Customer (Signature)		Date	

CNP



www.folgergas.com

RINNAI WORK ORDER

Customer Acct #: 205920

Date: 3/31/26

Name **WALLY STOVER**

Instructions: **DROP OFF 1000 UG W/50G@2.499**

Address **380 UTANA BLUFF TRAIL
ELLIJAT GA 30540**

GC TO BURY+2 ANODE BAGS TAKE 150FT YELLOW POLY-CLT

Order #: 488366

DESCRIPTION OF WORK

COMMENTS:

SERVICED BY:

DATE	START TIME	FINISH TIME	TOTAL TIME	LABOR RATE	AMOUNT
				100.00/hr	
				100.00/hr	

FOR OFFICE USE ONLY

Performed leak check Yes No
Gas check attached Yes No
Leak check Initial

Start Pressure End Pressure Time Held System OK

% in Tank

AMOUNT REC'D

\$

☐ CASH ☐ CHECK #

☐ CREDIT CARD

#

EXP. DATE

- * I have received the Consumer Safety information & material.
- * I am satisfied with the work performed.
- * Customer agrees to pay all costs of collection, agency fees, court costs, and reasonable attorney fees in the event of default on payment.
- * Signing agrees to year contract for discount.

CUSTOMER SIGNATURE

Retail Price

Contract Price

Rinnai \$	\$
Standard Vent Kit \$	\$
Standard Install \$	\$
Total \$	\$

Tank Set

New Cust Special

L P Gas /Gal 2.999	L P Gas /Gal 2.499	
Gallons 50	Gallons 50	
FRCC \$9.79	FRCC \$9.79	9.79
Fuel Total 149.95	Fuel Total 124.95	124.95
Tank Lease/YR 179.00	1st yr Lease FREE	FREE
Total Materials		
Sub-Total		
Sales Tax		
Tank Set Fee \$250	Tank Set Fee	20.00
Safety Inspection \$129.95	\$29.95	29.95
Total Labor		
Total charges		
Prepay Bal On Account		

Safe Appliance Savings 533.80

Safe Appliance Rebate 600.00

TOTAL BALANCE DUE