



INVOICE

No 11508

EQUIP OWNED & OPERATED

P.O. BOX 506 • BAXLEY, GEORGIA 31515

2174 HATCH PARKWAY SOUTH • BAXLEY, GEORGIA 31513 • Tel. (912) 367-1151

NAME	<u>Charity Lillard</u>	ACCOUNT NO.	
MAIL ADDRESS	<u>1200 Clifford Rogers Rd.</u>	DATE ORDERED	
CITY/STATE/ZIP	<u>Lyons GA 30436</u>	DATE PROMISED	
PHONE	<u>912-293-0272</u>	DATE COMPLETED	<u>10-8-26</u>
LOCATION		TERMS	

INSTRUCTIONS set 120 gallon tank, install tankless water heater

QTY.	TAG NO. AND DESCRIPTION OF APPLIANCE/MATERIAL	UNIT PRICE	SALES AMOUNT
1	Rinnai RL75e tankless water heater w/ T-pod + isolation valves, serial # PD-CA-069810		1285 00
100	gallon of propane	2 59	259 00
1	Rago LV3403B4 second stage regulator		59 95
30'	1/2" coated copper tubing	4 29	128 70
1	1/2" cut off valve		16 95
4	1/2" flare nut	1 90	7 60
2	1/2" x 1/2" male adapter	3 09	6 18
1	1/2" flare swivel		3 99
All	other gas fittings, flex, per fittings, thread sealant		27 20

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:

1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 ☐2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 ☐

SERVICES PERFORMED

set 120 gallon tank, can gas line, installed tankless water heater, can pressure check

TOTAL MATERIAL

1794 57

TOTAL TIME HOURS

LABOR

460 00

THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.

SERVICES PERFORMED

SUBTOTAL

BY Daniel Sikes

SALES TAX 143 57

X CUSTOMER'S SIGNATURE

TOTAL DUE 2398 14

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

INSTALLATION ☒ OR TURN ON	REMOVAL OR TURN OFF	LEAK AND PRESSURE TEST	
		HIGH	LOW
SIZE: <u>120</u>	SIZE	START LOCK UP:	START LOCK UP:
S/N: <u>25A028434</u>	S/N:	TANK OFF PRESSURE:	TANK OFF PRESSURE:
GALLONS OR READING: <u>100 gal</u>	GALLONS OR READING:	AFTER 10 MINUTES:	AFTER 10 MINUTES:
		PRESSURE AS LEFT:	PRESSURE AS LEFT:

GRPA rebate 200.00
AMOUNT
RECEIVED \$ 2198.14

RECEIVED BY _____
DATE _____
SERVICES RECEIVED BY _____

GASCheck - Gas Appliance System Check

Account Name _____ Invoice Number _____ Date 10/8/26
 Name Chasity Lillard Company Sikes Propane, Inc.
 Address 1200 Clifford Rogers Rd. Call Taken By _____
 City Lyons State GA Zip 30436 Telephone (Cell) 912-240-1569 (Home) Chasity Lillard 912-293-0272

Appliance Check

Appliance	<u>water heater</u>					
Manufacturer	<u>Rinnai</u>					
Model #	<u>RL75e</u>					
Serial #	<u>PD-CA-06 9810</u>					
BTL's	<u>180,000</u>					
Burner - Com. Chamber	<u>ok</u>					
Man. Shutoff - Sed. Trap	<u>installed</u>					
Control - Pilot Safety System	<u>ok</u>					
Venting System	<u>ok</u>					
Age	<u>new</u>					
Taken Out Of Service Or Operation						

Container Check

Size	Serial #	Manufacturer	MFR. Date	Location	Container Condition	Relief Valve	Fittings Leak Check
<u>120</u>	<u>2SA028434</u>	<u>American W.</u>	<u>1996</u>	<u>ok</u>	<u>ok</u>	<u>56%</u>	<u>ok</u>

Pressure Test (If Applicable)

Start Pressure	End Pressure	Time Held	Pressure Held
<u>120psi.</u>	<u>120psi.</u>	<u>10min.</u>	<u>0</u>
			Work Order: <u>0</u>

Piping Check

Materials	Size	Cover / Protection
<u>coated copper</u>	<u>1/2"</u>	<u>ok</u>

System Leak Check

Start Pressure	End Pressure	Time Held	Pressure Held
<u>9in. wc.</u>	<u>9in. wc.</u>	<u>10min.</u>	<u>0</u>
			Work Order: <u>0</u>

Regulator Check

Type	Manufacturer	Date / Model	Vent Position / Protection
<u>First</u>	<u>MEC</u>	<u>26 Mar 25 / MEGR-1222H-B6F</u>	<u>u-c</u>
<u>Second</u>	<u>Rago</u>	<u>07E2024 / LV3403B4</u>	<u>down</u>

Safety Information Supplied:

Comments: Please note all repairs and corrections made along with any recommended actions.