

6/22/2026 8:27:13 AM

WORK ORDER

JOSHUA HIRSCHHEIMER

242 WHISPHERWOOD TRAIL
MINERAL BLUFF, GA 30559
(914) 263-0586

Customer #: 30009
Order #: 516219
Location #: 271725
Zone: B-014-WED-
Terms: Net 30

Tech: _____

Map Code:

Service Code: Propane Service

Description: 06/25/26 - GO 1ST! JOHNNY TO BURY - 250UG
W/200G@2.999 CALL 914-263-0586 - CCOF - CT

Date Ordered:	Scheduled Date:	Est. Completion:	Start:	Stop:
---------------	-----------------	------------------	--------	-------

Name: Heating System

Last Service: 6/19/2026

Last Tune Up:

Contract:

SC Renewal:

Manufact:

Model:

Notes:

Instructions:

Service History:

Date	Invoice #	Tech	Problem Reported	Service Notes
------	-----------	------	------------------	---------------



PROPANE GAS PIPING SYSTEM CHECK

Customer Account #: 30009

Date: 6/25/26

Name: JOSHUA HIRSCCEIMER

Instructions: GO 1ST! JOHNNY TO BURY 250UG2/200G@

Address: 242 WHISPHERWOOD TRAIL

2.999G CALL 914-263-0586 CCOF

MINERAL BLUFF, GA 30559

Order #: 516219

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

Appliance Check:

Appliance	Furnace	Waterheater	Stove	log lighter	log lighter	
Manufacturer	Rheem	Navien	Sa.	N.V.	N.V.	
Model #	PCF74821ST	NPE-240S2	NY60A65115S	N.V.	N.V.	
Serial #	W422862P	J089E21Y	DJ4U7DATB0	N.V.	N.V.	
Burner/Combustion Chamber	☒ Ok	☒ Ok	☒ Ok	☒ Ok	☒ Ok	☐ Ok
Manual Shutoff	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A
Sediment Trap	☒ Ok	☒ Ok	☒ Ok	☒ Ok	☒ Ok	☐ Ok
Pilot Safety System	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A
Electronic Ignition System	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A
Venting System	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A
Combustion Air	☒ Ok	☒ Ok	☒ Ok	☒ Ok	☒ Ok	☐ Ok
Taken Out of Service	☐ Yes ☒ No	☐ Yes ☒ No	☐ Yes ☒ No	☐ Yes ☒ No	☐ Yes ☒ No	☐ Yes ☐ No

Container Check:

Size	Serial #	Container Fitting Leak Test	Manufacturer	Manufacture Date	Location	Tank Condition
250	M2601742	Good	T-brc	2026	U.G.	Good

Regulator(s):

Manufacturer	Model	Regulator Date	Regulator Venting	Flow/Delivery Pressure	Lock-Up Pressure
Twin			☐ Correct ☐ Incorrect		
1st	Rego	LV3403TR9 04-2026	☒ Correct ☐ Incorrect		
2nd	Rego	LV4403B46R 11-2021	☒ Correct ☐ Incorrect	11.3	13.0

Piping System Leak Test:

Pressure Test:

Start Pressure	End Pressure	Time Held	Pass	Start Pressure	End Pressure	Time Held	Pass
100 PSI	100 PSI	10 Mins	☒ Yes	15 PSI	15 PSI	10 Mins	☒ Yes
WC	WC	Mins	☐ No				☐ No

Comments:

Customer Acknowledgment: I acknowledge, by checking each of the following items, that:

- ☐ I have informed the service technician of all gas-burning appliances, gas lines, and unused piping not connected to any gas appliance on my property.
- ☐ I have been informed of what deficiencies, repairs &/or alterations, if any, were made to my gas system or appliances.
- ☐ I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas supply off at the tank or cylinder.
- ☐ I have smelled propane gas and can detect its odor.
- ☐ I have been told to consider installing one or more gas detectors.
- ☐ I have received safety information and told to read it and share it with all family members.
- ☐ I am satisfied with the service work performed.

Service Technician (Print)	Jeff Dillard	Service Technician (Signature)	<i>Jeff Dillard</i>	Date	6-25-26
Customer (Print)		Customer (Signature)		Date	



www.folgergas.com

RINNAI WORK ORDER

Customer Acct #: 30009

Date: 6/25/26

Name JOSHUA HIRSCHHEIMER

Instructions: GO 1ST! JOHNNY TO BURY 250UG2/200G
@2.999G. CALL 914-263-0586 CCOF

Address 242 WHISPERWOOD TRAIL

Order #: 516219

MINERAL BLUFF, GA 30559

DESCRIPTION OF WORK

COMMENTS:

SERVICED BY:

DATE	START TIME	FINISH TIME	TOTAL TIME	LABOR RATE	AMOUNT
				100.00/hr	
				100.00/hr	

FOR OFFICE USE ONLY

Performed leak check Yes No

Gas check attached Yes No

Leak check Initial

Start Pressure End Pressure Time Held System OK

% in Tank

AMOUNT REC'D

\$

☐ CASH ☐ CHECK #

☐ CREDIT CARD

#

EXP. DATE

- * I have received the Consumer Safety information & material.
- * I am satisfied with the work performed.
- * Customer agrees to pay all costs of collection, agency fees, court costs, and reasonable attorney fees in the event of default on payment.
- * Signing agrees to year contract for discount.

CUSTOMER SIGNATURE

Retail Price

Contract Price

Rinnai \$

\$

Standard Vent Kit \$

\$

Standard Install \$

\$

Total \$

\$

Tank Set

New Cust Special

L.P. Gas /Gal 2.999

L.P. Gas /Gal 2.999

Gallons 200

Gallons 200

FRCC \$9.79

FRCC \$9.79

9.79

Fuel Total 599.80

Fuel Total 599.80

599.80

Tank Lease/YR 129.00

1st yr Lease 129.00

129.00

Total Materials

Sub-Total

Sales Tax

Tank Set Fee \$250

Tank Set Fee FREE

FREE

Safety Inspection \$129.95

\$29.95

29.95

Total Labor

Total charges

Prepay Bal On Account

Safe Appliance Savings

350.00

Safe Appliance Rebate

400.00

TOTAL BALANCE DUE