

✓ Ckt

6/17/2026 3:39:53 PM

WORK ORDER

Steven Dart

331 Griffith Parkway
Blue Ridge, GA 30513
(717) 870-8700

Customer #: 206245
Order #: 515714
Location #: 282473
Zone: B-010-THU-
Terms: Net 30

Tech: _____

Map Code:

Service Code: Propane Service

Description: 6-24-26 T/I 250 w/ 200g @ 2.69 Run yard line. Move 120
Freeman tank aside. CCOF SM 717-870-8700

Date Ordered: 6/17/2026	Scheduled Date:	Est. Completion:	Start:	Stop:
-------------------------	-----------------	------------------	--------	-------

Name:

Contract:

Manufact:

Notes:

Instructions:

Last Service:

SC Renewal:

Model:

Last Tune Up:

Service History:

Date	Invoice #	Tech	Problem Reported	Service Notes
------	-----------	------	------------------	---------------



PROPANE GAS PIPING SYSTEM CHECK

Customer Account #: 206245

Date: 6-24-26

Name: STEVEN DART

Instructions: T/I 250 W/ 200G @ 2.599 RUN

Address: 331 GRIFFITH PARKWAY

LINE TO TANK. MOVE FREEMAN 120 OUT O

BLUE RIDGE GA 30513

OF WAY CCOF SM 717-870-8700

Order #: 515714

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

Appliance Check:

Appliance	Stove	logset	logset	logset		
Manufacturer	L.B.	Everwarm	Everwarm	Everwarm		
Model #	LSG4515BM	N.V.	N.V.	N.V.		
Serial #	811KMLK074	N.V.	N.V.	N.V.		
Burner/Combustion Chamber	☒ Ok	☒ Ok	☒ Ok	☒ Ok	☐ Ok	☐ Ok
Manual Shutoff	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Sediment Trap	☒ Ok	☒ Ok	☒ Ok	☒ Ok	☐ Ok	☐ Ok
Pilot Safety System	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Electronic Ignition System	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Venting System	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Combustion Air	☒ Ok	☒ Ok	☒ Ok	☒ Ok	☐ Ok	☐ Ok
Taken Out of Service	☐ Yes ☒ No	☐ Yes ☒ No	☐ Yes ☒ No	☐ Yes ☒ No	☐ Yes ☐ No	☐ Yes ☐ No

Container Check:

Size	Serial #	Container Fitting Leak Test	Manufacturer	Manufacture Date	Location	Tank Condition
250	M1318012	Good	Trinity	2011	AG	Good

Regulator(s):

Manufacturer		Model	Regulator Date	Regulator Venting		Flow/Delivery Pressure	Lock-Up Pressure
Twin	Rego	LV404Y9	05-2025	☒ Correct	☐ Incorrect	11.2	12.9
1st				☐ Correct	☐ Incorrect		
2nd				☐ Correct	☐ Incorrect		

Piping System Leak Test:

Start Pressure	End Pressure	Time Held	Pass	Start Pressure	End Pressure	Time Held	Pass
90 PSI	90 PSI	10 Mins	☒ Yes	15 PSI	15 PSI	10 Mins	☒ Yes
WC	WC	Mins	☐ No				☐ No

Pressure Test:

Comments:

Customer Acknowledgment:

I acknowledge, by checking each of the following items, that:

- ☐ I have informed the service technician of all gas-burning appliances, gas lines, and unused piping not connected to any gas appliance on my property.
- ☐ I have been informed of what deficiencies, repairs &/or alterations, if any, were made to my gas system or appliances.
- ☐ I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas supply off at the tank or cylinder.
- ☐ I have smelled propane gas and can detect its odor.
- ☐ I have been told to consider installing one or more gas detectors.
- ☐ I have received safety information and told to read it and share it with all family members.
- ☐ I am satisfied with the service work performed.

Service Technician (Print)	Jeff Dillard	Service Technician (Signature)	[Signature]	Date	6-24-26
Customer (Print)		Customer (Signature)	[Signature]	Date	



www.folgergas.com

RINNAI WORK ORDER

Customer Acct #: 206245
Name STEVEN DART
Address 331 GRIFFITH PARKWAY
BLUE RIDGE GA 30513

Date: 6-24-26
Instructions: T/I 250 W/ 200G @ 2.499 RUN
YARD LINE MOVE FREEMAN 120 ASIDE.
CCOF SM 717-870-8700
Order #: 515714

DESCRIPTION OF WORK

COMMENTS: _____

SERVICED BY: _____

DATE	START TIME	FINISH TIME	TOTAL TIME	LABOR RATE	AMOUNT
				100.00/hr	
				100.00/hr	

FOR OFFICE USE ONLY

Performed leak check ☐ Yes ☐ No
Gas check attached ☐ Yes ☐ No
Leak check Initial _____

Start Pressure _____ End Pressure _____ Time Held _____ System OK _____

% in Tank

AMOUNT REC'D

\$ _____

☐ CASH ☐ CHECK # _____

☐ CREDIT CARD

EXP. DATE _____

- * I have received the Consumer Safety information & material.
- * I am satisfied with the work performed.
- * Customer agrees to pay all costs of collection, agency fees, court costs, and reasonable attorney fees in the event of default on payment.
- * Signing agrees to _____ year contract for discount.

CUSTOMER SIGNATURE

Retail Price

_____ Rinnai \$

Standard Vent Kit \$

Standard Install \$

Total \$

Contract Price

\$

\$

\$

\$

Tank Set

L.P. Gas /Gal **2.999**

Gallons **200**

FRCC \$9.79

Fuel Total **599.80**

Tank Lease/YR **99.00**

Total Materials

Sub-Total

Sales Tax

Tank Set Fee \$250

Safety Inspection \$129.95

Total Labor

Total charges

Prepay Bal On Account

New Cust Special

L.P. Gas /Gal **2.499**

Gallons **200**

FRCC \$9.79

Fuel Total **499.80**

1st yr Lease **FREE**

Total Materials

Sub-Total

Sales Tax

Tank Set Fee **20.00**

Safety Inspection \$29.95

Total Labor

Total charges

Prepay Bal On Account

Safe Appliance Savings

Safe Appliance Rebate 50.00

TOTAL BALANCE DUE