

6/29/2026 3:22:48 PM

WORK ORDER

Bonnie Finnegan

3436 Whitepath Road
Ellijay, GA 30536
(762) 282-7429

Customer #: 206290
Order #: 517209
Location #: 260204
Zone: B-037-WED-
Terms: Net 30

Tech: _____

Map Code:

Service Code: Propane Service

Description: 7/7/26 T/I 250AG w/200G @ 2.999 Call 762-282-7429

CCOF-CLT *Possibly Run Lines*

Date Ordered: 6/29/2026

Scheduled Date:

Est. Completion:

Start:

Stop:

Name: Heating System

Last Service: 5/12/2026

Last Tune Up:

Contract:

SC Renewal:

Manufact:

Model:

Notes:

Instructions:

Service History:

Date	Invoice #	Tech	Problem Reported	Service Notes
------	-----------	------	------------------	---------------



PROPANE GAS PIPING SYSTEM CHECK

Customer Account #: 206290

Date: 7/7/26

Name: BONNIE FINNEGAN

Instructions: T/I 250AG @ 2.999 CCOF-CLT

Address: 3436 WHITEPATH ROAD

POSSIBLY RUN LINES

ELLIJAY GA 30536

Order #: 517209

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

Appliance Check:

Appliance	Water heater					
Manufacturer	haneh					
Model #	NRE-24052CNG					
Serial #	208932532538378					
Burner/Combustion Chamber	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Manual Shutoff	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Sediment Trap	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Pilot Safety System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Electronic Ignition System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Venting System	☒ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Combustion Air	☒ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☐ Ok
Taken Out of Service	☐ Yes ☒ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No

Container Check:

Size	Serial #	Container Fitting Leak Test	Manufacturer	Manufacture Date	Location	Tank Condition
250	541456	Good	Quality	1997	AS	Good

Regulator(s):

Manufacturer	Model	Regulator Date	Regulator Venting	Flow/Delivery Pressure	Lock-Up Pressure
Twin			☐ Correct ☐ Incorrect		
1st	Rejo	3403TH9	2026	☒ Correct ☐ Incorrect	
2nd	Rejo	3403B4	2025	☒ Correct ☐ Incorrect	11.2

Piping System Leak Test:

Pressure Test:

Start Pressure	End Pressure	Time Held	Pass	Start Pressure	End Pressure	Time Held	Pass
120 PSI	120 PSI	10 Mins	☒ Yes	A PSI	PSI	Mins	☐ Yes
WC	WC	Mins	☐ No				☐ No

Comments:

Customer Acknowledgment:

I acknowledge, by checking each of the following items, that:

- ☐ I have informed the service technician of all gas-burning appliances, gas lines, and unused piping not connected to any gas appliance on my property.
- ☐ I have been informed of what deficiencies, repairs &/or alterations, if any, were made to my gas system or appliances.
- ☐ I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas supply off at the tank or cylinder.
- ☐ I have smelled propane gas and can detect its odor.
- ☐ I have been told to consider installing one or more gas detectors.
- ☐ I have received safety information and told to read it and share it with all family members.
- ☐ I am satisfied with the service work performed.

Service Technician (Print)	Dillon Fern	Service Technician (Signature)	Dillon Fern	Date	7/7/26
Customer (Print)	Bonnie Jo Finnegan	Customer (Signature)	Bonnie Jo Finnegan	Date	7/7/26



www.folgergas.com

RINNAI WORK ORDER

Customer Acct #: 206290

Date: 7/7/26

Name _____

Instructions: T/I 250AG W/200G @ 2.999 CCOF-CLT

Address _____

Order #: _____

DESCRIPTION OF WORK	
COMMENTS: _____	
SERVICED BY: _____	

DATE	START TIME	FINISH TIME	TOTAL TIME	LABOR RATE	AMOUNT
				100.00/hr	
				100.00/hr	

FOR OFFICE USE ONLY			
Performed leak check	Yes	No	
Gas check attached	Yes	No	
Leak check	Initial _____		
Start Pressure	End Pressure	Time Held	System OK
_____	_____	_____	_____

% in Tank

AMOUNT REC'D
\$ _____
☐ CASH ☐ CHECK # _____
☐ CREDIT CARD

EXP. DATE _____

* I have received the Consumer Safety information & material.
* I am satisfied with the work performed.
* Customer agrees to pay all costs of collection, agency fees, court costs, and reasonable attorney fees in the event of default on payment.
* Signing agrees to _____ year contract for discount.

CUSTOMER SIGNATURE

Retail Price		Contract Price
_____ Rinnai	\$	\$
Standard Vent Kit	\$	\$
Standard Install	\$	\$
Total	\$	\$
Tank Set		New Cust Special
L.P. Gas /Gal	2.999	L.P. Gas /Gal 2.499
Gallons	200	Gallons 200
FRCC	\$9.79	FRCC \$9.79
Fuel Total	599.80	Fuel Total 499.80
Tank Lease/YR	99.00	1st yr Lease FREE
Total Materials		
Sub-Total		
Sales Tax		
Tank Set Fee	\$250	Tank Set Fee 20.00
Safety Inspection	\$129.95	\$29.95
Total Labor		
Total charges		
Prepay Bal On Account		
Safe Appliance Savings		462.68
Safe Appliance Rebate		200.00
TOTAL BALANCE DUE		