10/23/2026 7:12:24 AM

WORK ORDER

Michelle Williams

60 Knollwood Lane
Mineral Bluff, GA 30559
(404) 723-5515

Customer #: 206881
Order #: 561350
Location #: 283245
Zone: B-014-WED-
Terms: Net 30

Tech: _____

Map Code:
Service Code: Propane Service
Description: 10/28/2026 - T/I 250AG W/200G@2.499 LINES ARE THERE.
CONNECT W/H, FURNACE.CALL 404-723-5615 CCOF CLT/CT

Date Ordered: 10/23/2026	Scheduled Date:	Est. Completion:	Start:	Stop:

Name: **Last Service:** **Last Tune Up:**
Contract: **SC Renewal:**
Manufact: **Model:**
Notes:
Instructions:

Service History:

Date	Invoice #	Tech	Problem Reported	Service Notes

PROPANE GAS PIPING SYSTEM CHECK

FolgerGas PROPANE — GAS CHECK

Customer Account #: 206881

Date: 10/22/26

Name: MICHELLE WILLIAMS

Instructions: T.I 250AGW/100 G @ 2.499 LINES ARE CONNECT W/H AND LIGHT PILOTS CCOF CLT

Address: 60 KNOLLWOOD LANE
MINERAL BLUFF GA 30559

Order #: 557692

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

Appliance Check:

Appliance	waterheater	furnace	Generator			
Manufacturer	rinnaj	goodman	Generac			
Model #	REU-VC2025	FFU GPG1436	0058850			
Serial #	CA-089690	1602231810	6261399			
Burner/Combustion Chamber	☑ Ok	☑ Ok	☑ Ok	☐ Ok	☐ Ok	☐ Ok
Manual Shutoff	☑ Ok ☐ N/A	☑ Ok ☐ N/A	☑ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Sediment Trap	☑ Ok	☑ Ok	☑ Ok	☐ Ok	☐ Ok	☐ Ok
Pilot Safety System	☑ Ok ☐ N/A	☑ Ok ☐ N/A	☑ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Electronic Ignition System	☑ Ok ☐ N/A	☑ Ok ☐ N/A	☑ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Venting System	☑ Ok ☐ N/A	☑ Ok ☐ N/A	☑ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Combustion Air	☑ Ok	☑ Ok	☑ Ok	☐ Ok	☐ Ok	☐ Ok
Taken Out of Service	☐ Yes ☑ No	☐ Yes ☑ No	☐ Yes ☑ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No

Container Check:

Size	Serial #	Container Fitting Leak Test	Manufacturer	Manufacture Date	Location	Tank Condition
250	M2601120	Good	Triarc	2026	AG	Good

Regulator(s):

	Manufacturer	Model	Regulator Date	Regulator Venting	Flow/Delivery Pressure	Lock-Up Pressure
Twin				☐ Correct ☐ Incorrect		
1st	Rego	LV3403TR9		☑ Correct ☐ Incorrect		
2nd	Shirwood	NA	NA	☑ Correct ☐ Incorrect	11.6	13.7

Piping System Leak Test:

Start Pressure	End Pressure	Time Held	Pass
100 PSI	100 PSI	10 Mins	☑ Yes
____ WC	____ WC	____ Mins	☐ No

Pressure Test:

Start Pressure	End Pressure	Time Held	Pass
____ PSI	____ PSI	____ Mins	☐ Yes ☐ No

Comments:

Customer Acknowledgment: I acknowledge, by checking each of the following items, that:

- ☑ I have informed the service technician of all gas-burning appliances, gas lines, and unused piping not connected to any gas appliance on my property.
- ☑ I have been informed of what deficiencies, repairs &/or alterations, if any, were made to my gas system or appliances.
- ☑ I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas supply off at the tank or cylinder.
- ☑ I have smelled propane gas and can detect its odor.
- ☑ I have been told to consider installing one or more gas detectors.
- ☑ I have received safety information and told to read it and share it with all family members.
- ☑ I am satisfied with the service work performed.

Service Technician (Print) Brandon Payne	Service Technician (Signature) Brandon Payne	Date 10-28-26
Customer (Print)	Customer (Signature)	Date

FolgerGas LLC PROPANE

www.folgergas.com

RINNAI WORK ORDER

Customer Acct #: 206881

Name MICHELLE WILLIAMS

Address 60 KNOLLWOOD LANE

MINERAL BLUFF GA 30559

Date: 10/22/26

Instructions: T/I 250AG W/200G @ 2,499 LINES THERE CONNECT W/H RELIGHT PILOTS - CLT

Order #: 557692

DESCRIPTION OF WORK

COMMENTS:

SERVICED BY:

DATE	START TIME	FINISH TIME	TOTAL TIME	LABOR RATE	AMOUNT
				100.00/hr	
				100.00/hr	

FOR OFFICE USE ONLY

Performed leak check _____ Yes _____ No

Gas check attached _____ Yes _____ No

Leak check Initial _____

Start Pressure	End Pressure	Time Held	System OK

% in Tank

AMOUNT REC'D

$_____

☐ CASH ☐ CHECK #_____

☐ CREDIT CARD

#_____

EXP. DATE_____

* I have received the Consumer Safety information & material.
* I am satisfied with the work performed.
* Customer agrees to pay all costs of collection, agency fees, court costs, and reasonable attorney fees in the event of default on payment.
* Signing agrees to _____ year contract for discount.

_____

CUSTOMER SIGNATURE

Retail Price	Contract Price	
_____ Rinnai $	$	
Standard Vent Kit $	$	
Standard Install $	$	
Total $	$	
Tank Set	**New Cust Special**	
L.P. Gas /Gal 2.999	L.P. Gas /Gal 2.499	
Gallons 200	Gallons 200	
FRCC $9.79	FRCC $9.79	9.79
Fuel Total 599.80	Fuel Total 499.80	499.80
Tank Lease/YR 99.00	1st yr Lease FREE	FREE
Total Materials		
Sub-Total		
Sales Tax		
Tank Set Fee $250	Tank Set Fee 20.00	20.00
Safety Inspection $129.95	$29.95	29.95
Total Labor		
Total charges		
Prepay Bal On Account		
Safe Appliance Savings		538.16
Safe Appliance Rebate		600.00
TOTAL BALANCE DUE		