



INVOICE

No 11408

HOME OWNED & OPERATED

P.O. BOX 506 • BAXLEY, GEORGIA 31515
2174 HATCH PARKWAY SOUTH • BAXLEY, GEORGIA 31513 • Tel. (912) 367-1151

NAME	<u>Kenneth Dawden</u>	ACCOUNT NO.	
MAIL ADDRESS	<u>7454 Satilla Church Rd.</u>	DATE ORDERED	
CITY/STATE/ZIP	<u>Baxley GA 31513</u>	DATE PROMISED	
PHONE	<u>912-682-5335</u>	DATE COMPLETED	<u>7-2-26</u>
LOCATION		TERMS	

INSTRUCTIONS set 250 gallon tank, run all gas lines, install tankless water heater, fire box, & gas logs

QTY.	TAG NO. AND DESCRIPTION OF APPLIANCE/MATERIAL	UNIT PRICE	SALES AMOUNT
1	Rinnai RE160e tankless water heater w/isolation valves, serial # WA.4A-001981		1250 00
1	Rinnai RGBRE recess box		319 00
1	Monessen 42" LCUF42CR-GH, w/trim, blower, liner		1799 95
1	Peterson 30" G10-24/30-15(M)P Charcoal Frontier oak log		1398 50
200	gallon of propane	2 99	598 00
170'	1/2" CTS poly pipe w/metal detecting tape	80	136 00
1	36" X-riser		64 95
1	72" X-riser		69 95
1	Gas Ox-box		39 99

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:

- 1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 ☐
- 2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 ☐

SERVICES PERFORMED

set 250 gallon tank, run all gas lines, installed tankless water heater, fire box, gas logs, hooked up central heat, ran pressure check, lit & checked gas appliances

TOTAL MATERIAL

5676 34

TOTAL TIME _____ HOURS

LABOR

2200 00

THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.

SERVICES PERFORMED

BY

Daniel Sikes

SUBTOTAL

SALES TAX

454 11

X

CUSTOMER'S SIGNATURE

TOTAL DUE

8330 45

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

INSTALLATION OR TURN ON	REMOVAL OR TURN OFF	LEAK AND PRESSURE TEST	
		HIGH	LOW
SIZE: <u>250</u>	SIZE	START LOCK UP:	START LOCK UP:
S/N: <u>1554012</u>	S/N:	TANK OFF PRESSURE:	TANK OFF PRESSURE:
GALLONS OR READING: <u>200 gal</u>	GALLONS OR READING:	AFTER 10 MINUTES:	AFTER 10 MINUTES:
		PRESSURE AS LEFT:	PRESSURE AS LEFT:

RECEIVED BY _____

DATE _____

SERVICES RECEIVED BY _____

GP&A rebate 600.00
AMOUNT RECEIVED \$ 7730.45

WHITE/CUSTOMER'S COPY; YELLOW/POSTING COPY; PINK/FILE COPY

GASCheck - Gas Appliance System Check

Account Name _____ Invoice Number _____ Date 7/2/26
 Name Kenneth Dowden Company Sikes Propane, Inc.
 Address 7454 Satilla Church Rd. Call Taken By _____
 City Baxley State GA Zip 31513 Telephone (Cell) 912-682-5335 (Home) _____

Appliance Check

Appliance	water heater	gas Logs	central heat			
Manufacturer	<u>Rinnai</u>	<u>Peterson</u>	<u>Trane</u>			
Model #	<u>RE160e</u>	<u>G10-24/30-15CM)P</u>	<u>59X12080U 5PSBBA</u>			
Serial #	<u>WA-4A-001 981</u>	<u>2149602</u>	<u>2607559X KG</u>			
BTL's	<u>160,000</u>	<u>37,000</u>	<u>80,000</u>			
Burner / Comb. Chamber	<u>ok</u>	<u>ok</u>	<u>ok</u>			
Main Shutoff / Sed. Trap	<u>installed</u>	<u>installed</u>	<u>installed</u>			
Control / Pilot Safety System	<u>ok</u>	<u>ok</u>	<u>ok</u>			
Venting System	<u>ok</u>	<u>ok</u>	<u>ok</u>			
Age	<u>new</u>	<u>new</u>	<u>new</u>			
Taken Out Of Service Or Operation		<u>30"</u>				

Container Check

Size	Serial #	Manufacturer	MFR. Date	Location	Container Condition	Relief Valve	Fittings Leak Check
<u>250</u>	<u>1554012</u>	<u>Quality Steel</u>	<u>2025</u>	<u>ok</u>	<u>new</u>	<u>02C23</u>	<u>ok</u>

Pressure Test (If Applicable)

Start Pressure	End Pressure	Time Held	Pressure Held	Work Order
<u>140psi.</u>	<u>140psi.</u>	<u>10min.</u>	<u>0</u>	<u>0</u>

Piping Check

Materials	Size	Cover / Protection
<u>poly pipe</u>	<u>1/2" CTS</u>	<u>ok</u>
<u>coated copper</u>	<u>1/2" + 3/8"</u>	<u>ok</u>

System Leak Check

Start Pressure	End Pressure	Time Held	Pressure Held	Work Order
<u>9in.wc.</u>	<u>9in.wc.</u>	<u>10min.</u>	<u>0</u>	<u>0</u>

Regulator Check

Type	Manufacturer	Date / Model	Vent Position / Protection		
<u>First</u>	<u>Rego</u>	<u>03D2025 / LV4403 TR9</u>	<u>u-c</u>		
<u>Second</u>	<u>Rego</u>	<u>12C2024 / LV4403B66R</u>	<u>down</u>		

Safety Information Supplied:

Comments: Please note all repairs and corrections made along with any recommended actions