Confirmed V
CH

10/19/2026 11:36:54 AM

WORK ORDER

Alex Budd

930 Hawkins Road
Homer, GA 30547
(417) 540-4822

Customer #: 205367
Order #: 559647
Location #: 281356
Zone: J-016-TUE-
Terms: Net 30

Tech: _____

Map Code:
Service Code: Propane Service
Description: 10-30-26 Run line and h/u to generator auto pay (417) 540-4822 kpa

Date Ordered: 10/19/2026	Scheduled Date:	Est. Completion:	Start:	Stop:

Name: House
Contract:
Manufact:
Notes:
Instructions:

Last Service: 9/2/2026
SC Renewal:
Model:

Last Tune Up:

Service History:

Date	Invoice #	Tech	Problem Reported	Service Notes

Folger Gas PROPANE

www.folgergas.com

RINNAI WORK ORDER

Customer Acct #: 205367

Name ALEX BUDD

Address 930 HAWKINGS RD

HOMER, GA 30547

Date: 10/30/26

Instructions: SET LEASE 1000UG W/800 GALS

Order #:

DESCRIPTION OF WORK

COMMENTS:

SERVICED BY:

DATE	START TIME	FINISH TIME	TOTAL TIME	LABOR RATE	AMOUNT
				100.00/hr	
				100.00/hr	

FOR OFFICE USE ONLY

Performed leak check _____ Yes _____ No

Gas check attached _____ Yes _____ No

Leak check Initial _____

Start Pressure	End Pressure	Time Held	System OK

% in Tank

AMOUNT REC'D

$_____

☐ CASH ☐ CHECK #_____

☐ CREDIT CARD

#_____

EXP. DATE_____

* I have received the Consumer Safety information & material.
* I am satisfied with the work performed.
* Customer agrees to pay all costs of collection, agency fees, court costs, and reasonable attorney fees in the event of default on payment.
* Signing agrees to _____ year contract for discount.

_____

CUSTOMER SIGNATURE

	Retail Price	Contract Price	
_____ Rinnai	$	$	
Standard Vent Kit	$	$	
Standard Install	$	$	
Total	$	$	
Tank Set		**New Cust Special**	
L.P. Gas /Gal	3.199	L.P. Gas /Gal	2.499
Gallons	800	Gallons	800
FRCC	$9.79	FRCC	$9.79
Fuel Total	2568.99	Fuel Total	2008.99
Tank Lease/YR	179.00	1st yr Lease	FREE
Total Materials			
Sub-Total			
Sales Tax			
Tank Set Fee	$250	Tank Set Fee	20.00
Safety Inspection	$129.95		$29.95
Total Labor			
Total charges			
Prepay Bal On Account			
Safe Appliance Savings			1069.00
Safe Appliance Rebate			1000.00

TOTAL BALANCE DUE

PROPANE GAS PIPING SYSTEM CHECK

Customer Account #: 205367
Name: Alex Budd
Address: 930 Hawkins Rd, Homer, GA 30547

Date: 10-30-26
Instructions:
Order #:

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

Appliance Check:

Appliance	Furnace	Furnace	Generator	Pool heater		
Manufacturer	Lennox	Lennox	Generac	Pentair		
Model #	EL297uH090XV48C15-01	→	XG04845ANAX	460437		
Serial #	5925K04555	5926B05387	3019632154	10023785203		
Burner/Combustion Chamber	☑ Ok	☑ Ok	☑ Ok	☑ Ok	☐ Ok	☐ Ok
Manual Shutoff	☑ Ok ☐ N/A	☑ Ok ☐ N/A	☑ Ok ☐ N/A	☑ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Sediment Trap	☑ Ok	☑ Ok	☑ Ok	☑ Ok	☐ Ok	☐ Ok
Pilot Safety System	☑ Ok ☐ N/A	☑ Ok ☐ N/A	☑ Ok ☐ N/A	☑ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Electronic Ignition System	☑ Ok ☐ N/A	☑ Ok ☐ N/A	☑ Ok ☐ N/A	☑ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Venting System	☑ Ok ☐ N/A	☑ Ok ☐ N/A	☑ Ok ☐ N/A	☑ Ok ☐ N/A	☐ Ok ☐ N/A	☐ Ok ☐ N/A
Combustion Air	☑ Ok	☑ Ok	☑ Ok	☑ Ok	☐ Ok	☐ Ok
Taken Out of Service	☐ Yes ☑ No	☐ Yes ☑ No	☐ Yes ☑ No	☐ Yes ☑ No	☐ Yes ☐ No	☐ Yes ☐ No

Container Check:

Size	Serial #	Container Fitting Leak Test	Manufacturer	Manufacture Date	Location	Tank Condition
1000	1P019086	Good	American	1990	U/G	Good
1000	2P00 3434	Good	American	1992	U/G	Good

Regulator(s):

	Manufacturer	Model	Regulator Date	Regulator Venting	Flow/Delivery Pressure	Lock-Up Pressure
~~Twin~~	~~MEC~~ MEC	1177	15 Apr 26	☑ Correct ☐ Incorrect		
1st	MEC	1177	15 Apr 26	☑ Correct ☐ Incorrect		
2nd	MEC	1177		☑ Correct ☐ Incorrect	11	12

Piping System Leak Test:

Start Pressure	End Pressure	Time Held	Pass
110 PSI / ____ WC	110 PSI / ____ WC	10 Mins / ____ Mins	☑ Yes ☐ No

Pressure Test:

Start Pressure	End Pressure	Time Held	Pass
____ PSI	____ PSI	____ Mins	☐ Yes ☐ No

Comments:

Customer Acknowledgment: I acknowledge, by checking each of the following items, that:
- ☐ I have informed the service technician of all gas-burning appliances, gas lines, and unused piping not connected to any gas appliance on my property.
- ☐ I have been informed of what deficiencies, repairs &/or alterations, if any, were made to my gas system or appliances.
- ☐ I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas supply off at the tank or cylinder.
- ☐ I have smelled propane gas and can detect its odor.
- ☐ I have been told to consider installing one or more gas detectors.
- ☐ I have received safety information and told to read it and share it with all family members.
- ☐ I am satisfied with the service work performed.

Service Technician (Print)	Owen Dills	Service Technician (Signature)	Owen Dills	Date	10/30/26
Customer (Print)	ALEX BUDD	Customer (Signature)	Alex Budd	Date	10-30-26

PROPANE GAS PIPING SYSTEM CHECK

Customer Account #: 205367

Name: ALEX BUDD

Address: 930 HAWKINS RD

HOMER, GA 30547

Date: 10/30/26

Instructions: RUN LINE AND H/U TO GENERATOR

Order #:

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

Appliance Check:

Appliance	Tankless water heater	Tankless water heater	cooktop	Cook Stove	Water heater	Water heater
Manufacturer	N/A	N/A	WOLF	WOLF	Navien	Navien
Model #	N/A	N/A	CG365/6/3/LP	GR486-LP	NPE-240A2(NG)	
Serial #	N/A	N/A	19458579	18965208	20572026J2AA2	20872026J2AA2
Burner/Combustion Chamber	☑ Ok	☑ Ok	☑ Ok	☑ Ok	☑ Ok	☑ Ok
Manual Shutoff	☑ Ok ☐ N/A	☑ Ok ☐ N/A	☑ Ok ☐ N/A	☑ Ok ☐ N/A	☑ Ok ☐ N/A	☑ Ok ☐ N/A
Sediment Trap	☐ Ok	☐ Ok	☐ Ok	☐ Ok	☑ Ok	☑ Ok
Pilot Safety System	☐ Ok ☑ N/A	☐ Ok ☑ N/A	☐ Ok ☑ N/A	☐ Ok ☑ N/A	☑ Ok ☐ N/A	☑ Ok ☐ N/A
Electronic Ignition System	☐ Ok ☑ N/A	☐ Ok ☑ N/A	☑ Ok ☐ N/A	☑ Ok ☐ N/A	☑ Ok ☐ N/A	☑ Ok ☐ N/A
Venting System	☑ Ok ☐ N/A	☑ Ok ☐ N/A	☑ Ok ☐ N/A	☑ Ok ☐ N/A	☑ Ok ☐ N/A	☑ Ok ☐ N/A
Combustion Air	☑ Ok	☑ Ok	☑ Ok	☑ Ok	☑ Ok	☑ Ok
Taken Out of Service	☐ Yes ☑ No	☐ Yes ☑ No	☐ Yes ☑ No	☐ Yes ☑ No	☐ Yes ☑ No	☐ Yes ☑ No

Container Check:

Size	Serial #	Container Fitting Leak Test	Manufacturer	Manufacture Date	Location	Tank Condition
1000	1F019086	Good	American	1990	U/G	Good
1000	2F000034 34	Good	American	1992	U/G	Good

Regulator(s):

	Manufacturer	Model	Regulator Date	Regulator Venting	Flow/Delivery Pressure	Lock-Up Pressure
~~Twin~~ 1st	mec	1122	15APR26	☑ Correct ☐ Incorrect		
1st	mec	1122	15APR26	☑ Correct ☐ Incorrect		
2nd	mec	1222		☑ Correct ☐ Incorrect	11	12

Piping System Leak Test:

Start Pressure	End Pressure	Time Held	Pass
110 PSI	110 PSI	10 Mins	☑ Yes
____ WC	____ WC	____ Mins	☐ No

Pressure Test:

Start Pressure	End Pressure	Time Held	Pass
____ PSI	____ PSI	____ Mins	☐ Yes
			☐ No

Comments: 65% / 75% in tanks

Customer Acknowledgment: I acknowledge, by checking each of the following items, that:

- ☒ I have informed the service technician of all gas-burning appliances, gas lines, and unused piping not connected to any gas appliance on my property.
- ☒ I have been informed of what deficiencies, repairs &/or alterations, if any, were made to my gas system or appliances.
- ☒ I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas supply off at the tank or cylinder.
- ☒ I have smelled propane gas and can detect its odor.
- ☒ I have been told to consider installing one or more gas detectors.
- ☒ I have received safety information and told to read it and share it with all family members.
- ☒ I am satisfied with the service work performed.

Service Technician (Print)	Service Technician (Signature)	Date
Owen Dias	Owen Dias	10/30/26
Customer (Print)	**Customer (Signature)**	**Date**
ALEX BUDD	Alex Budd	10-30-26