

- SALES
- SERVICE
- INSTALLATION



CR

Royce Curtis will try TY

1335 US Hwy 82 W, Leesburg, GA 31763 (229) 435-6116 FAX (229) 435-6719

Order Number 888013	Date Written 10/20/25	Taken By AMN	Schedule Date 10/21/25	Date Completed 10-21-25
Branch - Customer No. 1-04062	Home 229 449-5489	Work	Time Started 8:35 4:30	A.M. P.M. Time Completed 8:59 7:15
Name MICHAEL MULLIS	Address 135 TRAVIS LANE	City LEESBURG, GA	State GA	Zip 31763-3235
Service Address 135 TRAVIS LANE		LEESBURG, GA 31763		HOT WATER & LOGS

Work to be performed:
Deliver & install Rinnai RE160iP water heater w/ venting and plumbing. Haul old water heater. Called in by Michael. Call when on the way.

Work completed:
Removed tank type and installed and vented Rinnai

Qty:	Materials	Price	Amount	Qty:	Materials	Price	Amount
1	Maxitrol Reg 5		82.34	1	WR-RE160iP		745
1	Maxitrol Reg 3		38.98		Water Heater		
3	3/4 mip x lex		12.21	1	WR-RIKF		98
9	3/4 pex EL		26.82	1	WR-184118		82
1	3/4 pex Coupl.		3.12	1	WR-189958		72
23	3/4 pex Rings		9.66	3	224033 99" VENT	59.00	177.00
10'	3/4 pex pipe		10.-	2	224063-90 VENT	15.00	
				1	224030-43 111.45		63.00
				2	10" vent		
				1	45° VENT EL		

DR. RT.	Rt. Seq.	Rate	Deposit
Tank Make	Size 61	Series 92844	Tank Percent
Single Stage	Regular Date	Reg. Condition	Mfr. Model Vent Pos. Protected?
TWO 1st			
STAGE 2nd			

RECO Model: LV404Y39 Internal Relief: Yes UL Listed: Yes
 System Stage(type): Integral 2 PSI Service ID #: 03418202
GASCheck Spring Range: 1-2.6 PSI Mfg. Date: 03 2024 Made in: USA

Less Check		Flow Check		Lock-up Check	
Manometer Reading at Start 2 psi	Manometer Reading After 10 minutes 2 psi	Manometer Reading Under Load		Manometer Reading	
Central Heating	Water Heater	Range		Clothes Dryer	
Manufacturer Rinnai	Model No. RE160iP	Serial No. SL1VA-167139			
Sed. Trap Vent					
Fuel/BTU 000	160	000	N/A	N/A	000
AGE New					
Shut off Installed yes					

SHOP OR TRUCK SUPPLIES	16.50
MATERIAL TOTAL	1486.63
TRIP CHARGE	
LABOR <i>2men/2 1/2 hrs</i>	
SUB-LABOR <i>Rebate</i>	<200.00>
PERMIT	
SHIPPING/FREIGHT	
Thank You	SALES TAX 118.93
	TOTAL 1405.56

CASH CHECK

RECEIVED BY *Curtis Royce TY* Date *10-21-2025*

Work Completed by: *Michael Mullis* Date *10-21-2025*

I ACKNOWLEDGE THAT I HAVE READ AND UNDERSTAND THE IMPORTANT SAFETY INSTALLATION INFORMATION PRINTED ON BACK OF THE CUSTOMER COPY

ANY UNUSED GAS PIPING OUTLETS INDOORS? YES NO

IF YES, IS EACH UNUSED GAS PIPING OUTLET FITTED WITH A GAS TIGHT THREADED PLUG OR CAP? YES NO

CUSTOMER AVAILABLE YES NO

CUSTOMER SMELLED ODORIZED PROPANE AND SHOWN THE SHUTDOWN PROCEDURE YES NO