

R

1335 US Hwy 82 W, Leesburg, GA 31763 (229) 435-6116 FAX (229) 435-6119

Order Number 887403	Date Written 10/06/25	Taken By: MEH	Schedule Date 10/14/25	Date Completed 10/14/25
Branch - Customer No. 1-01569	Home 229 343-5425	Work	Time Started 9:00 A.M. P.M.	Time Completed 1:00 A.M. P.M.
Name SINGLETARY CONSTR #08	Address LOT 117 THE GROVES 10/25 POBX 70815	Cell	2:45 LAST HERE MAX & KIM SMITH 4:30 10/2024	
City ALBANY, GA	State 31708	Zip		
Service Address 177 BELMONT DRIVE 10LEESBURG, GA 31763-1804				

Work to be performed: DELIVER AND INSTALL RINNAI RL75iP, WITH ROOF DISCHARGE TERMINAL, 189951 FLASHING, OTHER VENTING. TAKE CAMCO DRAIN PAN ALSO. IN BY TERRY 343-5425 CELL:	Work completed 184118 Built wall for Rinnai AND installed Rinnai + RIRFKIT Vented Rinnai
---	---

Qty:	Materials	Price	Amount	Qty:	Materials	Price	Amount
1	W-R 11470 CAMCO Drain Pan	39.00	39.00				
1	W-R RE180EP Internal Rinnai	89.50	89.50	1	W-R 184118 Roof Discharge		87.00
1	W-R R7KF Zuswall Kit	98.00	98.00	1	W-R 189958 Flashing		12.00

DR. RT.	Rt. Seq.	Rate	Deposit	(3) 39"			
Tank Make	Size	Serial No.	Tank Percent	(2) 90"			
Single Stage	Regular Date	Reg. Condition	Mfr.	Model	Vent Pos.	Protected?	(1) 18.5"
TWO 1st							
STAGE 2nd							

Less Check Manometer Reading at Start 9.6	Manometer Reading After 10 minutes 9.6	Flow Check Manometer Reading Under Load	Lock-up Check Manometer Reading	SHOP OR TRUCK SUPPLIES	16.50
Central Heating	Water Heater	Range	Clothes Dryer	MATERIAL TOTAL	1207.50
Manufacturer	Rinnai			TRIP CHARGE	
Model No.	RE180EP			LABOR 2w/4w	
Serial No.	TA.0A000950			SUB-LABOR Rebak <200.00>	
Sed. Trap	I T			PERMIT	
Fuel/BTU	000 180 000	N/A	N/A	SHIPPING/FREIGHT	
AGE	25			Thank You	SALES TAX 96.60
Shut off Installed	NRS			TOTAL	1104.10

CASH RECEIVED BY

CHECK

Work Completed by: Ruby H ATC Date: 10/14/25

Customer Signature: [Signature] Date: 10/14/25

I ACKNOWLEDGE THAT I HAVE READ AND UNDERSTAND THE IMPORTANT SAFETY INSTALLATION INFORMATION PRINTED ON BACK OF THE CUSTOMER COPY

ANY UNUSED GAS PIPING OUTLETS INDOORS? YES NO

IF YES, IS EACH UNUSED GAS PIPING OUTLET FITTED WITH A GAS TIGHT THREADED PLUG OR CAP? YES NO

CUSTOMER AVAILABLE YES NO

CUSTOMER SMELLED ODORIZED PROPANE AND SHOWN THE SHUTDOWN PROCEDURE YES NO