

SALES
SERVICE
INSTALLATION

R



25/11 1ST

Mike + 1

1335 US Hwy 82 W, Leesburg, GA 31763 (229) 435-6116 FAX (229) 435-6119

Order Number 886329	Date Written 10/17/25	Taken By: JC	Schedule 10/27/25	Date Completed 10/27/25
Branch - Customer No. 1-89548	Home 229 881-2371	Work	Time Started 9:00-10:10 A.M. P.M.	Time Completed 9:25-4:00 A.M. P.M.
Name BRYAN & MOLLY WILLIS	Address 3603 QUAIL HOLLOW RD ALBANY, GA	Cell	GILLIONVILLE RD RT BEATTIE LFT GROVE FOLLOW CIR TO QUAIL HOLLOW HO ON RT. GATE CODE #2371 2 LOGS, 2 H/W, COOK & 5 LITES	
Service Address 3603 QUAIL HOLLOW RD ALBANY, GA 31721	Zip 31721-2836			

Work to be performed: REMOVE OLD RINNAI & INSTAL RX180iN TO INCLUDE MC-601 CONTROLLER, DRAIN PAN & NECESSARY VENTING PER MS WILLIS; CALL WHEN ON THE WAY

Work completed: Removed old w.H installed VENTING new Rinnai

Up ✓ Copy

Qty:	Materials	Price	Amount	Qty:	Materials	Price	Amount
3	3/4 mip x 3/4 pex adp		12.21	1	WR RX180iN		1,290.-
6	3/4 90°		38.50				
1	3/4 pex tee		3.57	1	WR MC 601		139.-
1	1" PVC 90°		3.82				
18	3/4 pex rings		7.56	1	WR 11470 Drain		39.-
6'	3/4 pex pipe		6.-		Pan		
1	PVC 1 x 3/4		1.28				
DR. RT.	Rt. Seq.	Rate	Deposit	1	184162PP		84.00
Tank Make	Size 325	Serial SW007532	Tank Percent	1	39" vent 224080PP		45.00
Single Stage	Regular Date	Reg. Condition	Mfr.	Model	Vent Pos.	Protected?	
							1 19 vent 224079PP 35.00
							1 termination 184110 87.00
TWO 1st							
STAGE 2nd							

Manometer Reading at Start 10	Manometer Reading After 10 minutes 10	Flow Check Manometer Reading Under Load	Lock-up Check Manometer Reading	SHOP OR TRUCK SUPPLIES	16.50
----------------------------------	--	--	------------------------------------	------------------------	-------

Manufacturer Rinnai	Model No. RX180iN	Serial No. SLBA-205379	Sed. Trap Vent	Fuel/BTU 000 180 000	AGE 24	Shut off Installed Days	MATERIAL TOTAL	1808.52	
<input type="checkbox"/> CASH <input type="checkbox"/> CHECK							TRIP CHARGE		
RECEIVED BY							LABOR	680 -	
Work Completed by: Mike + Ty							SUB-LABOR- Rebate	<200.00>	
Customer Signature: [Signature]							PERMIT		
Date: 10/27/25							SHIPPING/FREIGHT		
Date:							Thank You	SALES TAX	144.68
I ACKNOWLEDGE THAT I HAVE READ AND UNDERSTAND THE IMPORTANT SAFETY INSTALLATION INFORMATION PRINTED ON BACK OF THE CUSTOMER COPY							TOTAL	2433.20	

ANY UNUSED GAS PIPING OUTLETS INDOORS? YES NO

IF YES, IS EACH UNUSED GAS PIPING OUTLET FITTED WITH A GAS TIGHT THREADED PLUG OR CAP? YES NO

CUSTOMER AVAILABLE YES NO

CUSTOMER SMELLED ODORIZED PROPANE AND SHOWN THE SHUTDOWN PROCEDURE YES NO