



10/1/2025 4:34:41 PM

WORK ORDER

MATT MCLELLAN

211 BIG TIMBER RD
MINERAL BLUFF, GA 30559
(386) 237-0265

Customer #: 26250
Order #: 402229
Location #: 266725
Zone: B-014-WED-
Terms: Net 30

Tech: _____

Map Code:

Service Code: Propane Service

Description: 10/10/2025-INSTALL STOVE ON SITE. AND RUN NEW 1/2"
LINES- SEE MIKE FOR DETAILS-CCOF- sn
Call-386-237-3426

Date Ordered: 10/1/2025	Scheduled Date:	Est. Completion:	Start:	Stop:
Name: Heating System	Last Service: 9/19/2025	Last Tune Up:		
Contract:	SC Renewal:			
Manufact:	Model:			
Notes:				
Instructions:				

Service History:

Date	Invoice #	Tech	Problem Reported	Service Notes
------	-----------	------	------------------	---------------



PROPANE GAS PIPING SYSTEM CHECK

Customer Account #: 26250
 Name: MATT MCLELLAN
 Address: 211 BIG TIMBER RD
MINERAL BLUFF GA 30559

Date: 10-10-25
 Instructions: INSTALL STOVE ON SITE RUN NEW 1/2"
LINE. SEE MIKE CCOF SN 386-237-3426
 Order #: 402229

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

Appliance Check:

Appliance	<u>Stove</u>					
Manufacturer	<u>Danuth Forge</u>					
Model #	<u>FDSR25</u>					
Serial #	<u>SH250174</u>					
Burner/Combustion Chamber	<input checked="" type="checkbox"/> Ok	<input type="checkbox"/> Ok				
Manual Shutoff	<input checked="" type="checkbox"/> Ok <input type="checkbox"/> N/A	<input type="checkbox"/> Ok <input type="checkbox"/> N/A				
Sediment Trap	<input checked="" type="checkbox"/> Ok	<input type="checkbox"/> Ok				
Pilot Safety System	<input checked="" type="checkbox"/> Ok <input type="checkbox"/> N/A	<input type="checkbox"/> Ok <input type="checkbox"/> N/A				
Electronic Ignition System	<input checked="" type="checkbox"/> Ok <input type="checkbox"/> N/A	<input type="checkbox"/> Ok <input type="checkbox"/> N/A				
Venting System	<input checked="" type="checkbox"/> Ok <input type="checkbox"/> N/A	<input type="checkbox"/> Ok <input type="checkbox"/> N/A				
Combustion Air	<input checked="" type="checkbox"/> Ok	<input type="checkbox"/> Ok				
Taken Out of Service	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No				

Container Check:

Size	Serial #	Container Fitting Leak Test	Manufacturer	Manufacture Date	Location	Tank Condition
<u>250</u>	<u>m2008445</u>	<u>Good</u>	<u>Arco</u>	<u>2020</u>	<u>UG</u>	<u>Good</u>

Regulator(s):

Manufacturer		Model	Regulator Date	Regulator Venting		Flow/Delivery Pressure	Lock-Up Pressure
Twin	<u>Reso</u>	<u>4041334</u>	<u>9-19</u>	<input checked="" type="checkbox"/> Correct	<input type="checkbox"/> Incorrect	<u>11.5</u>	<u>13.2</u>
1st				<input type="checkbox"/> Correct	<input type="checkbox"/> Incorrect		
2nd				<input type="checkbox"/> Correct	<input type="checkbox"/> Incorrect		

Piping System Leak Test:

Pressure Test:

Start Pressure	End Pressure	Time Held	Pass	Start Pressure	End Pressure	Time Held	Pass
<u>80</u> PSI	<u>80</u> PSI	<u>10</u> Mins	<input checked="" type="checkbox"/> Yes	<u>15</u> PSI	<u>15</u> PSI	<u>10</u> Mins	<input checked="" type="checkbox"/> Yes
___ WC	___ WC	___ Mins	<input type="checkbox"/> No				<input type="checkbox"/> No

Comments:

Customer Acknowledgment:

- I have informed the service technician of all gas-burning appliances, gas lines, and unused piping not connected to any gas appliance on my property.
- I have been informed of what deficiencies, repairs &/or alterations, if any, were made to my gas system or appliances.
- I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas supply off at the tank or cylinder.
- I have smelled propane gas and can detect its odor.
- I have been told to consider installing one or more gas detectors.
- I have received safety information and told to read it and share it with all family members.
- I am satisfied with the service work performed.

Service Technician (Print) <u>Alvin Wilcox</u>	Service Technician (Signature) 	Date <u>10-10-25</u>
Customer (Print)	Customer (Signature) 	Date



INVOICE

Customer #:	26250
Payment Terms:	Net 30
Invoice #:	402229
Invoice Date:	2025-10-10
Total Due	\$0.00

MATT MCLELLAN
 Po Box 868
 McCaysville, GA 30555

Make Check Payable to: Folger Gas, LLC

Amount Enclosed: \$ _____

Remit To:
 Folger Gas, LLC
 PO BOX 2155
 Blue Ridge, GA 30513

Customer Name		Delivery/Service Address		Cust #	Invoice #	Inv Date
MATT MCLELLAN		211 BIG TIMBER RD - MINERAL BLUFF, GA 30559		26250	402229	2025-10-10
Quantity	Item Number	Description	Unit Price	TOTAL		
2.00	R48EF	3/8"X1/2" MALE CON	\$4.7500	\$9.50		
4.00	R48FF	1/2"X1/2" MALE CON	\$4.5000	\$18.00		
3.00	3661	3/8" FLARE NUTS	\$3.2500	\$9.75		
6.00	3708	1/2" FLARE NUTS	\$3.7500	\$22.50		
1.00	42-8	1/2"X1/2" FLARE UN	\$4.2500	\$4.25		
1.00	45050	1/2" TEES	\$4.2500	\$4.25		
1.00	45010	1/2" 90' ELBOWS	\$4.2500	\$4.25		
1.00	303410	3/8"X3/8" CUTOFF	\$29.9500	\$29.95		
1.00	501092	24" X 1/4 ID CONNE	\$24.9500	\$24.95		
3.00	38R50	3/8" COPPER TUBING	\$5.0000	\$15.00		
65.00	12R50	1/2" COPPER TUBING	\$5.5000	\$357.50		
1.00	Shop Supplies	Shop Supplies	\$26.7400	\$26.74		
1.75	Labor	Labor	\$175.0000	\$306.25		
1.00	Labor	Labor	\$0.0000	\$0.00		
		Fannin County Tax:		\$15.82		
		GA State Sales Tax:		\$21.07		

Tank/Equipment: Heating System - Heating System

For Fuel or Service At:

211 BIG TIMBER RD - MINERAL BLUFF, GA 30559

Sub Total	\$832.89
Charges	\$0.00
Tax Total	\$36.89

Your credit card will be charged on 10/10/2025.		\$869.78
ACCOUNT BALANCE	\$0.00	TOTAL DUE \$0.00

10/10/2025 - Technician: Alvin Wilcox - Work Performed: - Ran line to cast iron stove and hooked leak test 80 psi for 10 min no leaks aw/ac/da 68%

Folger Gas, LLC
PO BOX 2155
Blue Ridge, GA 30513
706-632-7606
www.folgergas.com