

Confirmed TB

10/21/2025 3:20:37 PM

# WORK ORDER

## Garrison Sisson

70 Topeka Lane  
Blue Ridge, GA 30513  
(706) 455-2573

Customer #: 204713  
Order #: 409394  
Location #: 280545  
Zone: B-005-TUE-  
Terms: Net 30

Tech: \_\_\_\_\_

**Map Code:**

**Service Code:** Propane Service

**Description:** 10/22/2025 - T/I 250AG W/200G@2.599G - DROP IN. OTHER  
TANK IS EMPTY - T/I MONITOR - CALL 706-455-2573 -  
EMAIL INVOICE - CT

<b>Date Ordered:</b> 10/21/2025	<b>Scheduled Date:</b>	<b>Est. Completion:</b>	<b>Start:</b>	<b>Stop:</b>
---------------------------------	------------------------	-------------------------	---------------	--------------

**Name:**

**Last Service:**

**Last Tune Up:**

**Contract:**

**SC Renewal:**

**Manufact:**

**Model:**

**Notes:**

**Instructions:**

**Service History:**

Date	Invoice #	Tech	Problem Reported	Service Notes
------	-----------	------	------------------	---------------



# PROPANE GAS PIPING SYSTEM CHECK

Customer Account #: 204713  
 Name: GARRISON SISSON  
 Address: 70 TOPEKA LANE  
BLUE RIDGE, GA 30513

Date: 10/22/25  
 Instructions: T/I 250AG W/50G@2.599-DROP IN  
T/I MONITOR. CALL:706-455-2573 INVOICE-JB  
 Order #: 409394

**Disclaimer:** This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

### Appliance Check:

Appliance	Furnace					
Manufacturer	Rheem					
Model #	R92TA0851521MSA					
Serial #	W042241737					
Burner/Combustion Chamber	<input checked="" type="checkbox"/> Ok	<input type="checkbox"/> Ok				
Manual Shutoff	<input checked="" type="checkbox"/> Ok <input type="checkbox"/> N/A	<input type="checkbox"/> Ok <input type="checkbox"/> N/A				
Sediment Trap	<input checked="" type="checkbox"/> Ok	<input type="checkbox"/> Ok				
Pilot Safety System	<input checked="" type="checkbox"/> Ok <input type="checkbox"/> N/A	<input type="checkbox"/> Ok <input type="checkbox"/> N/A				
Electronic Ignition System	<input checked="" type="checkbox"/> Ok <input type="checkbox"/> N/A	<input type="checkbox"/> Ok <input type="checkbox"/> N/A				
Venting System	<input checked="" type="checkbox"/> Ok <input type="checkbox"/> N/A	<input type="checkbox"/> Ok <input type="checkbox"/> N/A				
Combustion Air	<input checked="" type="checkbox"/> Ok	<input type="checkbox"/> Ok				
Taken Out of Service	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No				

### Container Check:

Size	Serial #	Container Fitting Leak Test	Manufacturer	Manufacture Date	Location	Tank Condition
250	250045362	Good	American	1099	AG	Good

### Regulator(s):

Manufacturer	Model	Regulator Date	Regulator Venting	Flow/Delivery Pressure	Lock-Up Pressure
Twin			<input type="checkbox"/> Correct <input type="checkbox"/> Incorrect		
1st	Rheem	3403TR9	4-25	<input checked="" type="checkbox"/> Correct <input type="checkbox"/> Incorrect	
2nd	Rheem	4403	NV	<input checked="" type="checkbox"/> Correct <input type="checkbox"/> Incorrect	11.3

### Piping System Leak Test:

### Pressure Test:

Start Pressure	End Pressure	Time Held	Pass	Start Pressure	End Pressure	Time Held	Pass
55 PSI	56 PSI	10 Mins	<input checked="" type="checkbox"/> Yes	_____ PSI	_____ PSI	_____ Mins	<input type="checkbox"/> Yes
_____ WC	_____ WC	_____ Mins	<input type="checkbox"/> No				<input type="checkbox"/> No

Comments:

### Customer Acknowledgment:

- I have informed the service technician of all gas-burning appliances, gas lines, and unused piping not connected to any gas appliance on my property.
- I have been informed of what deficiencies, repairs &/or alterations, if any, were made to my gas system or appliances.
- I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas supply off at the tank or cylinder.
- I have smelled propane gas and can detect its odor.
- I have been told to consider installing one or more gas detectors.
- I have received safety information and told to read it and share it with all family members.
- I am satisfied with the service work performed.

Service Technician (Print)	Alvin Wilcox	Service Technician (Signature)		Date	10-22-25
Customer (Print)	Garrison Sisson	Customer (Signature)		Date	



www.folgergas.com

# RINNAI WORK ORDER

Customer Acct #: 204713  
 Name GARRISON SISSON  
 Address 70 TOPEKA LANE  
BLUE RIDGE, GA 30513

Date: 10/22/25  
 Instructions: T/I 250AG W/200G@2.599 = DROP IN.  
OTHER TANK IS EMPTY. T/I MONITOR.  
 CALL: 706-4555-2573 EMAIL INVOICE-JB  
 Order #: 409394

DESCRIPTION OF WORK	
COMMENTS:	
SERVICED BY:	

DATE	START TIME	FINISH TIME	TOTAL TIME	LABOR RATE	AMOUNT
				100.00/hr	
				100.00/hr	

**FOR OFFICE USE ONLY**

Performed leak check  Yes  No  
 Gas check attached  Yes  No  
 Leak check Initial \_\_\_\_\_

Start Pressure \_\_\_\_\_ End Pressure \_\_\_\_\_ Time Held \_\_\_\_\_ System OK \_\_\_\_\_

**% in Tank**

**AMOUNT REC'D**

\$ \_\_\_\_\_

CASH     CHECK # \_\_\_\_\_

CREDIT CARD

# \_\_\_\_\_

EXP. DATE \_\_\_\_\_

\* I have received the Consumer Safety information & material.  
 \* I am satisfied with the work performed.  
 \* Customer agrees to pay all costs of collection, agency fees, court costs, and reasonable attorney fees in the event of default on payment.  
 \* Signing agrees to \_\_\_\_\_ year contract for discount.

\_\_\_\_\_  
 CUSTOMER SIGNATURE

Retail Price		Contract Price	
Rinnai \$	\$	\$	\$
Standard Vent Kit \$	\$	\$	\$
Standard Install \$	\$	\$	\$
Total \$	\$	\$	\$
Tank Set		New Cust Special	
L.P. Gas /Gal <b>2.999</b>	L.P. Gas /Gal <b>2.599</b>		
Gallons <b>200</b>	Gallons <b>200</b>		
FRCC \$9.79	FRCC \$9.79	<b>9.79</b>	
Fuel Total <b>599.80</b>	Fuel Total <b>519.80</b>	<b>519.80</b>	
Tank Lease/YR <b>99.00</b>	1st yr Lease <b>FREE</b>	<b>FREE</b>	
Total Materials			
Sub-Total			
Sales Tax			
Tank Set Fee \$250	Tank Set Fee <b>20.00</b>	<b>20.00</b>	
Safety Inspection \$129.95	\$29.95	<b>29.95</b>	
Total Labor			
Total charges			
Prepay Bal On Account			
Safe Appliance Savings		<b>521.53</b>	
<i>Safe Appliance Rebate</i>		<b>400.00</b>	
<b>TOTAL BALANCE DUE</b>			