



146 S. Ridge Ave. Tifton, GA 31794 (229) 386-5574

306 S. Main St. Sylvester, GA 31791 (229) 776-7336

604-B N. Broadfoot Blvd. Vidalia, GA 30474 (912) 537-8722

3117 Veterans Parkway S. Moultrie, GA 31788 (229) 985-6942

2310-B Highway 84 W Valdosta, GA 31602 (229) 469-4250

NAME Robert Clements RT# _____ RT. SEQ. _____ ACCT # 2-23815 DATE 10-16-25 INT _____

MAILING ADDRESS 111 Rosewood Dr CO. _____ CITY _____

ADDRESS _____ APT/LOT NO. _____

CITY Sylvester STATE GA ZIP CODE 31791

NEW CUSTOMER INFORMATION	
S.S. NO. _____	DELV _____
HOME PH _____	RENT _____
WORK PH _____	CREDIT _____
LITE PILOT _____	PC _____
EMPLOYER _____	_____
DR. _____	USE _____ LEASE _____

SERVICE REQUESTED: CASH CHARGE DATE PROMISED _____

Quote: TS, WH, Run lines and stub for stove

email: _____
cell # 404-374-7127
PAY BILL ONLINE @congerlpgas.com

DIRECTIONS: CALL to schedule

TANK PICKUP/SET	TANK SIZE	SERIAL #	TANK %	TANK DESTINATION	DOT PERMANENTLY INSTALLED CONTAINERS				
					MANUFACTURED DATE	LAST TEST DATE	SIZE	SERIAL #	% FULL
Set	120	A103209H		10 Ballons	@ 3.849 =	38.49			

QTY	APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED	MODEL #	SERIAL NUMBER	UNIT PRICE	SALES AMOUNT
1	Rinnai WH	RE18E	THUA-118040	(WH)	1299.95
29'	3/4 Trac			7.95	230.55
2	3/4 Trac Ends			44.95	89.90
1	Assortment of Elct.				108.00
1	Assortment of Water hns				59.95
				01	38.49

WORK PERFORMED: Set Tank Install	REGULATION INFORMATION	APPLIANCES/EQUIP. SOLD (MP)	488.40
WH	MAKE: Rego MODEL: RD404BS	PARTS/MAT. USED (MS)	44.30
	DATE CODE: 6-24 VENT: UC	TANK RENT (TR)	10.00
		CF	18.95

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:

1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 <input type="checkbox"/> 2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A PAMPHLET NUMBER 54 <input type="checkbox"/> I HAVE RECEIVED A SCRATCH AND SNIFF BROCHURE AND THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.	LEAK AND PRESSURE TEST			SALES TAX _____ %	LABOR 250.00 GR (200.00)
	HIGH: 1st Stage	2nd Stage	LOW		
	START LOCK-UP: _____ PSI	START LOCK-UP: 12.9 W.C.	START LOCK-UP: _____ PSI		
	TANK OFF PRESSURE: _____ PSI	TANK OFF PRESSURE: 8.5 W.C.	TANK OFF PRESSURE: _____ PSI		
	AFTER 10 MINUTES: _____ PSI	AFTER 10 MINUTES: 8.5 W.C.			
	PRESSURE AS LEFT: _____ PSI	PRESSURE AS LEFT: 11.0 W.C.			

X _____ CUSTOMER SIGNATURE

PIPING PRESSURE TEST		INV. TOTAL	1994.10
START 6.0 PSIG	FINISH 6.0 PSIG	AMOUNT RECEIVED	

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE.

Service Rep. Signature: [Signature] DATE: 10-24-25

CUSTOMER SIGNATURE: _____