

SALES
SERVICE
INSTALLATION



ENERGY FOR EVERYONE
propane

RH/CH

1335 US Hwy 82 W, Leesburg, GA 31763 (229) 435-6116 FAX (229) 435-6119

Order Number 888312	Date Written 10/26/25	Taken By MEH	Schedule Date 11/06/25	Date Completed 11-6-2025
Branch - Customer No. 1-20312	Home 229 894-3321	Work	Time Started 2:30 P.M.	Time Completed 7:00 P.M.
Name ELLEN DABBS	Address 3701 TRUMPINGTON LANE	City ALBANY, GA	Zip 31721-2058	Cell
Service Address 3701 TRUMPINGTON LANALBANY, GA 31721	OLD DAWSON RD LFT ON WEST ALBERSON RT ON TRUMPINGTN HSE ON RT CRNER OF ALBERS & TRUMPINGTON. BURNS YR RO CL#894-3321 *LOGS ONLY*			

Work to be performed: DELIVER AND INSTALL RINNAI RX160iN WITH RIKF INSTALL KIT, RXOVC OUTDOOR VENT CAP, PCD11-SHS PIPE COVER AND MC-601-W CONTROLLER. CALLED IN BY ELLEN. 229-894-3321 CELL: <i>Up City</i>	Work completed Delivered and installed Rinnai
--	---

Qty:	Materials	Price	Amount	Qty:	Materials	Price	Amount
30'	T-stat		10.50	1	W-R RX160iN/PT		1088.00
1	Pop in Box		6.-		Rinnai Water Hose		
	RX160i			1	W-R RIKF		98.00
	TA,BA-007804				Inst Kit		
				1	W-R RXOVC		51.00
					Outdoor Vent Cap		
				1	W-R PCD11-SHS		183.00
					Pipe Cover		
				1	W-R MC-601-W		148.00
					Contoller		

DR. RT.	Rt. Seq.	Rate	Deposit	Manometer Reading at Start 2 ps	Manometer Reading After 10 minutes 2 ps	Manometer Reading Under Load	Manometer Reading	SHOP OR TRUCK SUPPLIES	16.50				
Tank Make	Size 60	Serial No.	CUST. OWNED	MATERIAL TOTAL		1601.00		TRIP CHARGE					
Single Stage	Regular Date	Reg. Condition	Mfr.	Model	Vent Pos.	Protected?	LABOR						
TWO 1st							SUB-LABOR	Rebak	<200.00>				
STAGE 2nd							PERMIT						
Less Check	Central Heating	Water Heater	Range	Clothes Dryer	Fuel/BTU	000	160	000	N/A	N/A	000	SHIPPING/FREIGHT	
Manufacturer	Rinnai		AGE	Now		Shut off Installed	4	Thank You	SALES TAX	128.08	ANY UNUSED GAS PIPING OUTLETS INDOORS?	<input type="checkbox"/> YES <input type="checkbox"/> NO	
Model No.	RX160iN/PT		Customer Signature	RECEIVED BY		Work Completed by	Curtis Royce	Date	11-6-2025	TOTAL	1529.08	IF YES, IS EACH UNUSED GAS PIPING OUTLET FITTED WITH A GAS TIGHT THREADED PLUG OR CAP?	<input type="checkbox"/> YES <input type="checkbox"/> NO
Serial No.	TA,BA-007804		I ACKNOWLEDGE THAT I HAVE READ AND UNDERSTAND THE IMPORTANT SAFETY INSTALLATION INFORMATION PRINTED ON BACK OF THE CUSTOMER COPY			Customer Available	<input type="checkbox"/> YES <input type="checkbox"/> NO	CUSTOMER SMELLED ODORIZED PROPANE AND SHOWN THE SHUTDOWN PROCEDURE		<input type="checkbox"/> YES <input type="checkbox"/> NO			