

- SALES
- SERVICE
- INSTALLATION



RH/AS

1335 US Hwy 82 W, Leesburg, GA 31763 (229) 435-6116 FAX (229) 435-6119

Order Number 887806	Date Written 11/3/2025	Taken By: WLN	Schedule Date 11/5/2025	Date Completed 11/5/2025
Branch - Customer No. 1-02485	Home 229 288-4276	Work	Time Started 9:00 A.M. P.M.	Time Completed 1:00 A.M. P.M.
Name LAMON COMPANY #1 SHIVER JOB	Address 2808 WILMAR LANE	City ALBANY, GA 31707	State	Zip
Service Address 586 NORTHAMPTON ROAD LEESBURG, GA 31763				

Work to be performed: Deliver & install Rinnai RE180iP & vent w/ 184118, 189951, other venting, & drain pan. Called in by Brian.  COPY ✓	Work completed Built well & installed Rinnai & vented on low voltage for controller
---	--

Qty:	Materials	Price	Amount	Qty:	Materials	Price	Amount
(1)	39"			(1)	WR-RE180iP		876.00
(1)	19.5"				Rinnai High Eff Nox		
(1)	10"			(1)	WR-RIKF-Ins.Kit		9.00
				(1)	WR-#184118 Roof Dis. Tr.		82.00
				(1)	WR-#11470 Combo Drain Pan		39.00

DR. RT.	Rt. Seq.	Rate	Deposit
Tank Make	Size 120	Serial # 81268	Tank Percent
Single Stage	Regular Date	Reg. Condition	Mfr. Model Vent Pos. Protected?
TWO 1st			
STAGE 2nd			

Manometer Reading at Start 9.6	Less Check	Manometer Reading After 10 minutes 9.6	Flow Check	Manometer Reading Under Load	Lock-up Check	Manometer Reading	SHOP OR TRUCK SUPPLIES	16.50
Central Heating	Water Heater	Range	Clothes Dryer				MATERIAL TOTAL	1111.50
Manufacturer	Rinnai						TRIP CHARGE	
Model No.	RE180i						LABOR 2-1/4 hr	
Serial No.	TB UA-027401						SUB-LABOR	
Sed. Trap Vent	I I						PERMIT - Rebate	<200.00
Fuel/BTU	000 180 000	N/A	N/A				SHIPPING/FREIGHT	
AGE	New						Thank You	
Shut off Installed	4						SALES TAX	88.92
<input type="checkbox"/> CASH							TOTAL	1000.42
<input type="checkbox"/> CHECK								

Work Completed by: <u>Ruby H ATC</u>	Date: <u>11/5/25</u>
Customer Signature: <u>[Signature]</u>	Date: <u>11/5/25</u>
I ACKNOWLEDGE THAT I HAVE READ AND UNDERSTAND THE IMPORTANT SAFETY INSTALLATION INFORMATION PRINTED ON BACK OF THE CUSTOMER COPY	
ANY UNUSED GAS PIPING OUTLETS INDOORS?	<input type="checkbox"/> YES <input type="checkbox"/> NO
IF YES, IS EACH UNUSED GAS PIPING OUTLET FITTED WITH A GAS TIGHT THREADED PLUG OR CAP?	<input type="checkbox"/> YES <input type="checkbox"/> NO
CUSTOMER AVAILABLE	<input type="checkbox"/> YES <input type="checkbox"/> NO
CUSTOMER SMELLED ODORIZED PROPANE AND SHOWN THE SHUTDOWN PROCEDURE	<input type="checkbox"/> YES <input type="checkbox"/> NO