

Confirmed  
SN

e

10/23/2025 8:56:04 AM

## WORK ORDER

### Charles Herman

730 Split Creek Road  
Morganton, GA 30560  
(404) 518-0108

Customer #: 204726  
Order #: 409985  
Location #: 280561  
Zone: B-008-WED-  
Terms: Net 30

Tech: \_\_\_\_\_

**Map Code:**

**Service Code:** Propane Service

**Description:** 10/29/25- T/I 325ag w/ 200g @2.599. Lines already ran. Needs to be hooked up w/h and logs onsite. Contact builder Austin Rhodes: 706-455-4544 CCOF- SN

<b>Date Ordered:</b> 10/23/2025	<b>Scheduled Date:</b>	<b>Est. Completion:</b>	<b>Start:</b>	<b>Stop:</b>
---------------------------------	------------------------	-------------------------	---------------	--------------

**Name:**

**Contract:**

**Manufact:**

**Notes:**

**Instructions:**

**Last Service:**

**SC Renewal:**

**Model:**

**Last Tune Up:**

### Service History:

Date	Invoice #	Tech	Problem Reported	Service Notes
------	-----------	------	------------------	---------------



# PROPANE GAS PIPING SYSTEM CHECK

Customer Account #: 204726

Date: 10/29/25

Name: CHARLES HERMAN

Instructions: T/I 325AG W/200 @2.599. LINES ALREADY THERE. H/U W/H AND LOGS ONSITE. AUSTIN RHODES

Address: 730 SPLIT CREEK ROAD MORGANTON, GA. 30560

706-455-4544. CCOF- SN Order #: 409985

**Disclaimer:** This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

### Appliance Check:

Appliance	<u>water heater</u>					
Manufacturer	<u>Rinnah</u>					
Model #	<u><del>BA-07000</del> RX199I</u>					
Serial #	<u>BA-070004</u>					
Burner/Combustion Chamber	<input checked="" type="checkbox"/> Ok	<input type="checkbox"/> Ok				
Manual Shutoff	<input checked="" type="checkbox"/> Ok <input type="checkbox"/> N/A	<input type="checkbox"/> Ok <input type="checkbox"/> N/A				
Sediment Trap	<input checked="" type="checkbox"/> Ok	<input type="checkbox"/> Ok				
Pilot Safety System	<input checked="" type="checkbox"/> Ok <input type="checkbox"/> N/A	<input type="checkbox"/> Ok <input type="checkbox"/> N/A				
Electronic Ignition System	<input checked="" type="checkbox"/> Ok <input type="checkbox"/> N/A	<input type="checkbox"/> Ok <input type="checkbox"/> N/A				
Venting System	<input checked="" type="checkbox"/> Ok <input type="checkbox"/> N/A	<input type="checkbox"/> Ok <input type="checkbox"/> N/A				
Combustion Air	<input checked="" type="checkbox"/> Ok	<input type="checkbox"/> Ok				
Taken Out of Service	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No				

### Container Check:

Size	Serial #	Container Fitting Leak Test	Manufacturer	Manufacture Date	Location	Tank Condition
<u>325</u>	<u><del>1436</del> 1436423</u>	<u>Good</u>	<u>Steel</u>	<u>2022</u>	<u>AG</u>	<u>Good</u>

### Regulator(s):

Manufacturer	Model	Regulator Date	Regulator Venting	Flow/Delivery Pressure	Lock-Up Pressure
Twin			<input type="checkbox"/> Correct <input type="checkbox"/> Incorrect		
1st	<u>Rego</u>	<u>LV3303TR</u>	<u>01/2023</u>		
2nd	<u>Rego</u>	<u>LV3403BY</u>	<u>01/2025</u>	<u>12.0</u>	<u>13.1</u>

### Piping System Leak Test:

### Pressure Test:

Start Pressure	End Pressure	Time Held	Pass	Start Pressure	End Pressure	Time Held	Pass
<u>80</u> PSI	<u>80</u> PSI	<u>10</u> Mins	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<u>15</u> PSI	<u>15</u> PSI	<u>10</u> Mins	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
____ WC	____ WC	____ Mins					

Comments:

### Customer Acknowledgment:

- I have informed the service technician of all gas-burning appliances, gas lines, and unused piping not connected to any gas appliance on my property.
- I have been informed of what deficiencies, repairs &/or alterations, if any, were made to my gas system or appliances.
- I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas supply off at the tank or cylinder.
- I have smelled propane gas and can detect its odor.
- I have been told to consider installing one or more gas detectors.
- I have received safety information and told to read it and share it with all family members.
- I am satisfied with the service work performed.

Service Technician (Print) <u>Alvin Wilcox</u>	Service Technician (Signature) 	Date <u>10-29-25</u>
Customer (Print) <u>Customer not present</u>	Customer (Signature) 	Date



www.folgergas.com

# RINNAI WORK ORDER

Customer Acct #: 204726  
 Name CHARLES HERMAN  
 Address 730 SPLIT CREEK ROAD  
MORGANTON, GA. 30560

Date: 10/29/25  
 Instructions: T/I 325AG W/200G @2.599/  
LINES ALREADY RAN.H/U W/H AND LOGS ONSITE.  
 Order #: 409985 CALL AUSTIN: 706-455-4544  
 GCOF- SN

DESCRIPTION OF WORK	
<b>COMMENTS:</b>	
<b>SERVICED BY:</b>	

DATE	START TIME	FINISH TIME	TOTAL TIME	LABOR RATE	AMOUNT
				100.00/hr	
				100.00/hr	

**FOR OFFICE USE ONLY**

Performed leak check  Yes  No  
 Gas check attached  Yes  No  
 Leak check Initial \_\_\_\_\_

Start Pressure \_\_\_\_\_ End Pressure \_\_\_\_\_ Time Held \_\_\_\_\_ System OK \_\_\_\_\_

Retail Price		Contract Price	
Rinnai \$		\$	
Standard Vent Kit \$		\$	
Standard Install \$		\$	
Total \$		\$	

**% in Tank**

Tank Set		New Cust Special	
L.P. Gas /Gal	<b>2.999</b>	L.P. Gas /Gal	<b>2.599</b>
Gallons	<b>200</b>	Gallons	<b>200</b>
FRCC	\$9.79	FRCC	\$9.79
Fuel Total	<b>599.80</b>	Fuel Total	<b>519.80</b>
Tank Lease/YR	<b>99.00</b>	1st yr Lease	<b>FREE</b>
Total Materials			
Sub-Total			
Sales Tax			
Tank Set Fee	\$250	Tank Set Fee	<b>20.00</b>
Safety Inspection	\$129.95		<b>29.95</b>
Total Labor			
Total charges			
Prepay Bal On Account			

**AMOUNT REC'D**

\$ \_\_\_\_\_

CASH  CHECK # \_\_\_\_\_

CREDIT CARD

# \_\_\_\_\_

EXP. DATE \_\_\_\_\_

\* I have received the Consumer Safety information & material.  
 \* I am satisfied with the work performed.  
 \* Customer agrees to pay all costs of collection, agency fees, court costs, and reasonable attorney fees in the event of default on payment.  
 \* Signing agrees to \_\_\_\_\_ year contract for discount.

\_\_\_\_\_  
 CUSTOMER SIGNATURE

Safe Appliance Savings	521.53
<i>Safe Appliance Rebate</i>	<i>200.00</i>
<b>TOTAL BALANCE DUE</b>	