

Confirmed *FB*  
Yard line est. 20ft

10/30/2025 9:48:02 AM

# WORK ORDER

## Francisco Vazquez Aguilar

1160 Mangums Trail  
Blue Ridge, GA 30513  
(706) 455-6961

Customer #: 204791  
Order #: 412076  
Location #: 280640  
Zone: B-005-TUE-  
Terms: COD

Map Code: 30513

Tech: \_\_\_\_\_

Service Code: Propane Service

Description: 11-5-25 T/I 250ug w/200g. They will bury- hole should be dug. 1  
Anode Bag. Run yard line and connect. 706-455-6961 COD

Date Ordered: 10/30/2025

Scheduled Date:

Est. Completion:

Start:

Stop:

Name:  
Contract:  
Manufact:  
Notes:  
Instructions:

Last Service:  
SC Renewal:  
Model:

Last Tune Up:

### Service History:

Date	Invoice #	Tech	Problem Reported	Service Notes
------	-----------	------	------------------	---------------

✓



# PROPANE GAS PIPING SYSTEM CHECK

Customer Account #: 204791  
 Name: FRANCISCO VAZQUEZ AGUILER  
 Address: 1160 MANGUMS TRAIL  
BLUE RIDGE GA 30513

Date: 11-5-25  
 Instructions: T/I 250UG W/200G @ 2.599 THEY WILL BU  
1 ANODE BAG. RUN YARD LNEE AND CONNECT COD SM  
706-455-6961  
 Order #: 412076

**Disclaimer:** This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components, and cannot be construed to cover future or unforeseen happenings.

**Appliance Check:**

Appliance	Log Set		Log Set		Stove	
Manufacturer	RUE/WORM		EMPIRE		Samsung	
Model #	LSTFXG-P		EW02430V		NSG60685005RAA	
Serial #	VF0417071		AZ1D263621		OLN070AX402778D	
Burner/Combustion Chamber	<input checked="" type="checkbox"/> Ok	<input type="checkbox"/> Ok				
Manual Shutoff	<input checked="" type="checkbox"/> Ok <input type="checkbox"/> N/A	<input type="checkbox"/> Ok <input type="checkbox"/> N/A				
Sediment Trap	<input checked="" type="checkbox"/> Ok	<input type="checkbox"/> Ok				
Pilot Safety System	<input checked="" type="checkbox"/> Ok <input type="checkbox"/> N/A	<input type="checkbox"/> Ok <input type="checkbox"/> N/A				
Electronic Ignition System	<input checked="" type="checkbox"/> Ok <input type="checkbox"/> N/A	<input type="checkbox"/> Ok <input type="checkbox"/> N/A				
Venting System	<input checked="" type="checkbox"/> Ok <input type="checkbox"/> N/A	<input type="checkbox"/> Ok <input type="checkbox"/> N/A				
Combustion Air	<input checked="" type="checkbox"/> Ok	<input type="checkbox"/> Ok				
Taken Out of Service	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No				

**Container Check:**

Size	Serial #	Container Fitting Leak Test	Manufacturer	Manufacture Date	Location	Tank Condition
250	M2529085	good	TRIALC	2025	UG	good

**Regulator(s):**

Manufacturer	Model	Regulator Date	Regulator Venting	Flow/Delivery Pressure	Lock-Up Pressure
Twin			<input type="checkbox"/> Correct <input type="checkbox"/> Incorrect		
1st	Re60	LV3403TR9 0402025	<input checked="" type="checkbox"/> Correct <input type="checkbox"/> Incorrect		
2nd	Re60	LV3403B4 0102025	<input checked="" type="checkbox"/> Correct <input type="checkbox"/> Incorrect	11.2	12.8

**Piping System Leak Test:**

**Pressure Test:**

Start Pressure	End Pressure	Time Held	Pass	Start Pressure	End Pressure	Time Held	Pass
50 PSI	50 PSI	10 Mins	<input checked="" type="checkbox"/> Yes	15 PSI	15 PSI	10 Mins	<input checked="" type="checkbox"/> Yes
WC	WC	Mins	<input type="checkbox"/> No				<input type="checkbox"/> No

Comments: \_\_\_\_\_

**Customer Acknowledgment:** I acknowledge, by checking each of the following items, that:

- I have informed the service technician of all gas-burning appliances, gas lines, and unused piping not connected to any gas appliance on my property.
- I have been informed of what deficiencies, repairs &/or alterations, if any, were made to my gas system or appliances.
- I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas supply off at the tank or cylinder.
- I have smelled propane gas and can detect its odor.
- I have been told to consider installing one or more gas detectors.
- I have received safety information and told to read it and share it with all family members.
- I am satisfied with the service work performed.

Service Technician (Print)	Alex Cash	Service Technician (Signature)	[Signature]	Date
Customer (Print)	CMAP	Customer (Signature)	[Signature]	Date



www.folgergas.com

# RINNAI WORK ORDER

Customer Acct #: 204791  
 Name FRANCISCO VAZQUEZ AGUILAR  
 Address 1160 MANGUMS TRAIL  
BLUE RIDGE GA 30513

Date: 11-5-25  
 Instructions: T/I 250UG W/200G @2.599 THEY WILL BURY. 1 ANODE BAG RUN YARD LINE AND CONNECT.  
 Order #: 412076 COD SM 706-455-6961

DESCRIPTION OF WORK	
COMMENTS:	
SERVICED BY:	

DATE	START TIME	FINISH TIME	TOTAL TIME	LABOR RATE	AMOUNT
				100.00/hr	
				100.00/hr	

**FOR OFFICE USE ONLY**

Performed leak check  Yes  No  
 Gas check attached  Yes  No  
 Leak check Initial \_\_\_\_\_

Start Pressure \_\_\_\_\_ End Pressure \_\_\_\_\_ Time Held \_\_\_\_\_ System OK \_\_\_\_\_

% in Tank \_\_\_\_\_

**AMOUNT REC'D**

\$ \_\_\_\_\_

CASH     CHECK # \_\_\_\_\_

CREDIT CARD

# \_\_\_\_\_

EXP. DATE \_\_\_\_\_

\* I have received the Consumer Safety information & material.  
 \* I am satisfied with the work performed.  
 \* Customer agrees to pay all costs of collection, agency fees, court costs, and reasonable attorney fees in the event of default on payment.  
 \* Signing agrees to \_\_\_\_\_ year contract for discount.

\_\_\_\_\_

CUSTOMER SIGNATURE

Retail Price		Contract Price
_____ Rinnai \$	\$	\$
Standard Vent Kit \$	\$	\$
Standard Install \$	\$	\$
Total \$	\$	\$
Tank Set	New Cust Special	
L.P. Gas /Gal <b>2.999</b>	L.P. Gas /Gal	<b>2.599</b>
Gallons <b>200</b>	Gallons	<b>200</b>
FRCC \$9.79	FRCC \$9.79	<b>9.79</b>
Fuel Total <b>639.80</b>	Fuel Total <b>599.80</b>	<b>599.80</b>
Tank Lease/YR <b>129.00</b>	1st yr Lease <b>FREE</b>	<b>FREE</b>
Total Materials		
Sub-Total		
Sales Tax		
Tank Set Fee \$250	Tank Set Fee <b>20.00</b>	<b>20.00</b>
Safety Inspection \$129.95	\$29.95	<b>29.95</b>
Total Labor		
Total charges		
Prepay Bal On Account		
Safe Appliance Savings		<b>510.83</b>
<i>Safe Appliance Rebate</i>		<b>50.00</b>
<b>TOTAL BALANCE DUE</b>		