



congerlpgas.com

INVOICE / WORK ORDER NO.

116734

146 S. Ridge Ave.  
Tifton, GA 31794  
(229) 386-5574

306 S. Main St.  
Sylvester, GA 31791  
(229) 776-7336

604-B N. Broadfoot Blvd.  
Vidalia, GA 30474  
(912) 537-8722

3117 Veterans Parkway S.  
Moultrie, GA 31788  
(229) 985-6942

2310-B Highway 84 W  
Valdosta, GA 31602  
(229) 469-4250

12-10-25

NAME Jonahmeister RT# \_\_\_\_\_ RT. SEQ. \_\_\_\_\_ ACCT # 03-24598 DATE 12-8-25 INT 10

MAILING ADDRESS \_\_\_\_\_ CO. \_\_\_\_\_ CITY \_\_\_\_\_

ADDRESS 534 US HWY 319 S APT/LOT NO. \_\_\_\_\_

CITY Moultrie STATE GA ZIP CODE 31788

NEW CUSTOMER INFORMATION	
S.S. NO. _____	DELV _____
HOME PH _____	RENT _____
WORK PH _____	CREDIT _____
LITE PILOT _____	PC _____
EMPLOYER _____	
DR. _____	LEASE _____

SERVICE REQUESTED:  CASH  CHARGE DATE PROMISED \_\_\_\_\_

Set 120, Run gas line, install Rinnai

email: Jmeister0621@gmail.com

cell # 229-456-2001

PAY BILL ONLINE @congerlpgas.com

DIRECTIONS:  
  
10 \* 3.849 = 38.49 + 4.40 + 18.95 = 62.04

TANK PICKUP/SET	TANK SIZE	SERIAL #	TANK %	TANK DESTINATION	DOT PERMANENTLY INSTALLED CONTAINERS				
					MANUFACTURED DATE	LAST TEST DATE	SIZE	SERIAL #	% FULL
<u>TS</u>	<u>120</u>	<u>1559401</u>	<u>10 gal</u>	<u>AG on Site</u>					

QTY	APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED	MODEL #	SERIAL NUMBER	UNIT PRICE	SALES AMOUNT
<u>1</u>	<u>Rinnai Water Heater</u>	<u>RE199e</u>	<u>TG.UA.112048</u>		<u>1399 95</u>
<u>25</u>	<u>1/2 Copper</u>				<u>123 75</u>
<u>2</u>	<u>Flare Nuts</u>				<u>6 90</u>
<u>1</u>	<u>Sediment Trap</u>				<u>40 00</u>
<u>1</u>	<u>Cutoff Valve</u>				<u>29 95</u>
<u>1</u>	<u>Block</u>				<u>89 95</u>

WORK PERFORMED: <u>Set tank, Run gas line to Rinnai - No leaks</u>	REGULATION INFORMATION	APPLIANCES/EQUIP. SOLD	CODE	
MAKE: <u>Rego</u>	MODEL: <u>TR9</u>	PARTS/MAT. USED	<u>WH</u>	<u>1399 95</u>
DATE CODE: <u>03C2025</u>	VENT: <u>DOWN</u>	TANK RENT	<u>MP</u>	<u>290 55</u>
SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE				<u>MS</u>
				<u>CF</u>

1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 <input type="checkbox"/> 2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A PAMPHLET NUMBER 54 <input type="checkbox"/> I HAVE RECEIVED A SCRATCH AND SNIFF BROCHURE AND THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.	LEAK AND PRESSURE TEST				SALES TAX _____ % <u>112.00</u> <u>232.4</u> <u>2.60</u> <u>152.80</u> <u>270.00</u> <u>200.00</u> <u>10.00</u>	
	HIGH:	1st Stage	2nd Stage	LOW		
	START LOCK-UP:	<u>10</u> PSI	PSI	START LOCK-UP:		W.C. LABOR
	TANK OFF: PRESSURE	<u>6</u> PSI	PSI	TANK OFF: PRESSURE		W.C.
	AFTER 10 MINUTES: PRESSURE AS LEFT:	<u>6</u> PSI	PSI	AFTER 10 MINUTES: PRESSURE AS LEFT:		W.C.
PIPING PRESSURE TEST				INV. TOTAL		
START _____ PSIG FINISH _____ PSIG				AMOUNT RECEIVED		

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE.

SERVICE REP SIGNATURE \_\_\_\_\_ DATE 12.9.2025 X CUSTOMER SIGNATURE \_\_\_\_\_

222537