



INVOICE
No. 10991 ✓

HOME OWNED & OPERATED

P.O. BOX 506 • BAXLEY, GEORGIA 31515
2174 HATCH PARKWAY SOUTH • BAXLEY, GEORGIA 31513 • Tel. (912) 367-1151

NAME	<u>Chris & Kallie Taylor</u>	ACCOUNT NO.	_____
MAIL ADDRESS	<u>178 Kennedy Rd.</u>	DATE ORDERED	_____
CITY/STATE/ZIP	<u>Baxley GA 31513</u>	DATE PROMISED	_____
PHONE	<u>912-339-2214</u>	DATE COMPLETED	<u>11-12-25</u>
LOCATION	_____	TERMS	_____

INSTRUCTIONS run gas lines, set 250 gallon tank, install appliances

QTY.	TAG NO. AND DESCRIPTION OF APPLIANCE/MATERIAL	UNIT PRICE	SALES AMOUNT
1	Rinnai RE199e tankless water heater w/isolation valves, serial # SG.UA-100909		1500.00
1	Empire DVCT36CBP95P-3 / 36" Rushmore		5900.00
6	5' Duravent 5"x8" pipe	179.00	1074.00
1	4' Duravent 5"x8" pipe		139.00
1	2' Duravent 5"x8" pipe		99.00
1	Empire rear vent kit		419.00
1	Duravent 5"x8" 90° elbow		109.00
117'	1/2" coated copper tubing	3.49	408.33
120'	3/8" coated copper tubing	2.79	334.80

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER: 1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 <input type="checkbox"/> 2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 <input type="checkbox"/>	SERVICES PERFORMED <u>set 250 gallon tank, run gas lines, installed gas appliances, converted generator to dry range to LP, ran pressure check</u>	TOTAL MATERIAL	9,983.13
	TOTAL TIME _____ HOURS	LABOR	2560.00

THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.	SERVICES PERFORMED <u>[Signature]</u>	SUBTOTAL	
X _____		SALES TAX	798.65
CUSTOMER'S SIGNATURE		TOTAL DUE	13,341.78

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE				-GPGA rebate 200.00 AMOUNT 13,341.78 \$ 13,141.78
INSTALLATION OR TURN ON	REMOVAL OR TURN OFF	LEAK AND PRESSURE TEST		
		HIGH	LOW	
SIZE: <u>250</u>	SIZE	START LOCK UP:	START LOCK UP:	
S/N: <u>1548502</u>	S/N:	TANK OFF PRESSURE:	TANK OFF PRESSURE:	
GALLONS OR READING: <u>200gal</u>	GALLONS OR READING:	AFTER 10 MINUTES PRESSURE AS LEFT:	AFTER 10 MINUTES PRESSURE AS LEFT:	

WHITE/CUSTOMER'S COPY; YELLOW/POSTING COPY; PINK/FILE COPY

Total = \$14,672.43



Sikes Propane Safety Check

Customer name: CHRIS & KALLIE TAYLOR

Date: 11-12-2025

Street: 178 Kennedy Rd

City: Badley

State: Ga

Zip: 31513

Account No: 251202145918

Sub Acc. Number 251202145918

Customer Email

Phone Number: 912-339-2214

Salesman Name: Daniel Sikes

Purpose Of Service:

- Public Assembly
- New Appliance Service
- Leak Check
- New Customer Installation Service
- Out Of Gas
- System Repair Service
- Odor Complaint
- Move-in(New Renter/Owner)
- Other Services
- Line Locate
- Outside Visual Inspection

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components and cannot be construed to cover future or unforeseen happenings.

Tank/Cylinder:

	Tank 1
Size:	250 ✓
Serial No:	1548502
Manufacturer:	American Welding
Cap On Relief Valve:	Yes

High Pressure Test:

	Initial	Retest
Start Pressure:	130 P.S.I	P.S.I
End Pressure:	130 P.S.I	P.S.I
Start Time:	03:40:PM	
End Time:	03:50:PM	
Time Held:	10	
Pressure Held:	Yes	Yes

Intermediate Pressure Test:

	Initial	Retest
Start Pressure:	P.S.I	P.S.I
End Pressure:	P.S.I	P.S.I
Start Time:		
End Time:		
Time Held:	10	
Pressure Held:	Yes	Yes

Appliances:

	Indoor Range	Clothes Dryer	Fire Place/Gas Logs	Generator	Water Heater
Ids:					
Manufacturer:	Bosch	Alliance	Empire	Generac	Rinnai
Year Manufactured:	2025	2025	2024	2024	2019
Model:	HDI8056U/09	ADG6ARYS117TB01	DVCT36CBP9SP-3	G0072101	RE199e
Btu:	45000	22500		355000	199000
Serial No:	825100517094000857	2504026871	242916724	3012069180	SG, UA-100909
Manual Shutoff:	Existing	Existing	Existing	Existing	Existing
Sediment Trap:	NA	NA	NA	NA	NA
Vented:	NA	NA	NA	NA	NA
Warning Tag:	NA	NA	NA	NA	NA
Warning Tag Number:					
Warning Tag Comments:					
Images					

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components and cannot be construed to cover future or unforeseen happenings.

- I will notify propane company if propane service is interrupted for any reason, including installation of new appliance, so a leak check and system test can be completed.
 - I have informed the service technician of all gas- burning appliances and gas lines on my property.
 - I have smelled the propane gas and can detect its odor.
 - I have been told what to do if I smell a gas odor or otherwise suspect a gas leak and have been shown how to turn the gas off at the container.
 - I have been told that the odorant giving propane its distinctive smell can fade or diminish in intensity and that certain physical limitations or conditions might prevent me from smelling a gas leak.
 - I have been told to consider installing one or more propane gas detectors and carbon monoxide detectors per manufacturer's instructions listed by Underwriters Laboratories.
 - I have received safety information and been told to read it and share it with all family members.
 - I am satisfied with the service work performed.
- Locked tank out with POL lock?

Disclaimer: This inspection covers gas equipment and appliances visible and readily accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal workings of sealed equipment or structural components and cannot be construed to cover future or unforeseen happenings.

I Benjaminn Griffiths certify that I have completed the system check and installation review as described above.

I CHRIS & KALLIE TAYLOR have read and fully understand this certification.

DANIEL SIKES

CHRIS & KALLIE TAYLOR

Employee Signature

12-02-2025

Customer Signature

12-02-2025