

INVOICE



Sikes Propane

2174 Hatch Parkway South Baxley GA 31513 9123671151

Date: 11/21/2025

Time: 03:40 pm

CHRISTY REESE

Time In: 9:30 AM

Time Out: 11:30 PM

CARTER CAULEY (MIGRANT HOUSE)

Acc# 251121153339

Sub Account# 251121153339

518 Midway Ch. Rd Baxley, Ga 31513

Email:

Phone Number: 912-253-6307

Order #:

Invoice #: 251121154027

Tank Serial #: 2SK001867

Summary (*Itemized list at the back)

Total

Parts & Fittings

\$2174.36

Labor

\$444.00

Subtotal

\$2618.36

Discount

\$200.00

Taxes

\$173.95

Grand Total (\$)

2592.31

* All applicable sales tax will be added at time of final billing unless otherwise specified here.

Job Description: Set 200 gallon tank to Re199ep Water heater. ran lines. run pressure check

We are excited about the possibility of working with you.


By signing this document, the customer agrees to the services and conditions outlined in this document.

Customer Signature:

Signed On: 11-21-2025 03:51 pm

Part #	Category	Description	Price(\$)	Quantity	Hours	Hourly Rate	Total(\$)
NUT12	Parts & Fittings	NUT12-NUT 1/2 Forged Flare Nut	1.60	4	N/A	N/A	\$6.40
CoatedCop1/2	Parts & Fittings	CoatedCop1/2-1/2" Coated Copper	3.49	20	N/A	N/A	\$69.80
MFMP481234	Parts & Fittings	MFMP481234-48 1/2 x 3/4 Male Flare x Male Pipe	3.29	1	N/A	N/A	\$3.29
SC5812	Parts & Fittings	SC5812-58 1/2 Swivel Connector	3.99	1	N/A	N/A	\$3.99
CV5012F	Parts & Fittings	CV5012F-1/2 flare x 1/2 FPT Cut Off Valves	7.68	1	N/A	N/A	\$7.68
REG3403B4	Parts & Fittings	REG3403B4-LV3403B4 Regulator	59.95	1	N/A	N/A	\$59.95
RE199eP	Parts & Fittings	RE199eP-Rinnai 199eP (Propane)	1500.0	1	N/A	N/A	\$1500.00
Res propane	Parts & Fittings	Res propane - residential propane sales	2.99	175	N/A	N/A	\$523.25
LABOR	2 Person Rate(\$120)	N/A	N/A	N/A	3.7	\$120.00	\$444.00
Subtotal							\$2618.36
Discount							\$200.00
Taxes							\$173.95
Grand Total(\$)							\$2592.31

Tank Location:



Approx. distance from the building: 20

SYSTEM LEAK CHECKS: Vapor System Liquid System

	Leak Check			New Piping
	High Press	Intermediate	Low Press	Press Test
Tank Pressure:	130 PSIG	PSIG	11 In W.C	Air
Start Pressure:	110 PSIG	PSIG	9 In W.C	PSIG
End Pressure:	110 PSIG	PSIG	9 In W.C	PSIG
Start Time:	10:50:AM		11:00:AM	
End Time:	11:00:AM		11:10:AM	
Time Held:	10		10	
Pressure Held:	Yes		Yes	
Flow Check: IN W.C	Location Of Flow Check:		All appliances activated for test? Yes	

GAS LINE: AG UG

APPROX LENGTH: 20

MATERIAL: Copper

INSPECTION NOTES:

INSPECTOR / DO NOT CONNECT TAG: YES NO

WORK PERFORMANCE/COMMENTS: