

- SALES
- SERVICE
- INSTALLATION



R

RH/AS

1335 US Hwy 82 W, Leesburg, GA 31763 (229) 435-6116 FAX (229) 435-6119

Order Number 889807	Date Written 11/24/25	Taken By: AMN	Schedule Date 12/02/25	Date Completed 12/2/25
Branch - Customer No. 1-11753	Home 229 288-4276	Work	Time Started 9:00 A.M.	Time Completed 1:15 P.M.
Name LAMON COMPANY #16 AG RESERVES	Address 2808 WILMAR LANE	City ALBANY, GA 31707	State	Zip
Service Address 490 CARTER PLACE RD LEESBURG, GA 31763				

Work to be performed:
Run gas line to external Rinnai water heater and install water heater. Run line from existing propane tank. Called in by Brian. Call when on the way.

Work completed
Run gas line to Rinnai
run low voltage for controller
run line from tank to house
install Rinnai

Copy

Qty:	Materials	Price	Amount	Qty:	Materials	Price	Amount
(1)	Pipe wrap tape		16.96	1	WR-RE199cP		10.94
(1)	Pressure gauge			1	WR-RIKF		9.8
				1	WR-PCD095HS		17.2
				1	WR-MC-601-US-W		14.8
				1	GR LV 4403B66		68.43
				NS	POB		749.10

DR. RT.	Rt. Seq.	Rate	Deposit
Tank Make	Size	Serial No.	Tank Percent
Single Stage	Regular Date	Reg. Condition	Mfr. Model Vent Pos. Protected?
TWO 1st			
STAGE 2nd	05/20/25	New Rego	4403B66 ↓ -

Less Check		Flow Check		Lock-up Check	
Manometer Reading at Start 10	Manometer Reading After 10 minutes 10	Manometer Reading Under Load	Manometer Reading		
Central Heating	Water Heater	Range	Clothes Dryer		
Manufacturer	Rinnai				
Model No.	RE199cP				
Serial No.	TS. UA 139108				
Fuel/BTU	000 199 000	N/A	N/A	000	
AGE	25				

SHOP OR TRUCK SUPPLIES	16.50
MATERIAL TOTAL	2362.99
TRIP CHARGE	
LABOR 2h/4h	
SUB-LABOR Rebate	<200.00
PERMIT	
SHIPPING/FREIGHT	
Thank You	
SALES TAX	189.04
TOTAL	2352.03

CASH
 CHECK

RECEIVED BY
 Work Completed by: Ruby H ATC Date 12/2/25
 Customer Signature _____ Date 12/2/25

I ACKNOWLEDGE THAT I HAVE READ AND UNDERSTAND THE IMPORTANT SAFETY INSTALLATION INFORMATION PRINTED ON BACK OF THE CUSTOMER COPY

ANY UNUSED GAS PIPING OUTLETS INDOORS? YES NO
 IF YES, IS EACH UNUSED GAS PIPING OUTLET FITTED WITH A GAS TIGHT THREADED PLUG OR CAP? YES NO
 CUSTOMER AVAILABLE YES NO
 CUSTOMER SMELLED ODORIZED PROPANE AND SHOWN THE SHUTDOWN PROCEDURE YES NO