



congerlpgas.com

Ga

125654

146 S. Ridge Ave. Tifton, GA 31794 (229) 386-5574

306 S. Main St. Sylvester, GA 31791 (229) 776-7336

604-B N. Broadfoot Blvd. Vidalia, GA 30474 (912) 537-8722

3117 Veterans Parkway S. Moultrie, GA 31788 (229) 985-6942

2310-B Highway 84 W Valdosta, GA 31602 (229) 469-4250

NAME 36 (Michael Barwick) RT# RT. SEQ. ACCT # 03-23492 DATE 12-22-25 INT 10

MAILING ADDRESS 104 Genesis PKWY CO. CITY ADDRESS 117 Salt Lick APT/LOT NO. CITY Thomasville STATE Ga ZIP CODE 31792

NEW CUSTOMER INFORMATION S.S. NO. DELV HOME PH RENT WORK PH CREDIT LITE PILOT PC EMPLOYER DR. USE LEASE email: pay@conglass.com battery save cell # 229-319-1509 PAY BILL ONLINE @congerlpgas.com

SERVICE REQUESTED: [] CASH [] CHARGE DATE PROMISED Tank Set DIRECTIONS: Rebo & Tankset

Table with columns: TANK PICKUP/SET, TANK SIZE, SERIAL #, TANK %, TANK DESTINATION, DOT PERMANENTLY INSTALLED CONTAINERS (MANUFACTURED DATE, LAST TEST DATE, SIZE, SERIAL #, % FULL)

Table with columns: QTY, APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED, MODEL #, SERIAL NUMBER, UNIT PRICE, SALES AMOUNT

WORK PERFORMED: Set tank, Ran gas line to water heater - logs & range to come later REGULATION INFORMATION MAKE: Rego MODEL: TR9 DATE CODE: 05/2025 VENT: Down

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE LEAK AND PRESSURE TEST HIGH: 1st Stage 2nd Stage LOW START LOCK-UP: 10 PSI PSI START LOCK-UP: W.C. LABOR LB 360.00 TANK OFF: PRESSURE 6 PSI PSI TANK OFF: PRESSURE W.C. GPC 200.00 AFTER 10 MINUTES: 6 PSI PSI AFTER 10 MINUTES: W.C. GPC 200.00 PRESSURE AS LEFT: 10 PSI PSI PRESSURE AS LEFT: W.C. INV. TOTAL 1953.05

CUSTOMER SIGNATURE SERVICE REP. SIGNATURE DATE 12.11.2025 CUSTOMER SIGNATURE THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE.