



congerlpgas.com

INVOICE / WORK ORDER NO.

114904

146 S. Ridge Ave. Tifton, GA 31794 (229) 386-5574

306 S. Main St. Sylvester, GA 31791 (229) 776-7336

604-B N. Broadfoot Blvd. Vidalia, GA 30474 (912) 537-8722

3117 Veterans Parkway S. Moultrie, GA 31788 (229) 985-6942

2310-B Highway 84 W Valdosta, GA 31602 (229) 469-4250

NAME Lori Ann Mertz RT# _____ RT. SEQ. _____ ACCT # 7-18457 DATE 10-28-25 INT _____

MAILING ADDRESS _____ CO. _____ CITY _____

ADDRESS 125 Indigo Rd. APT/LOT NO. _____

CITY Lyons STATE GA ZIP CODE _____

NEW CUSTOMER INFORMATION	
S.S. NO. _____	DELV _____
HOME PH _____	RENT _____
WORK PH _____	CREDIT _____
LITE PILOT _____	PC _____
EMPLOYER _____	
DR. _____	USE _____ LEASE _____

SERVICE REQUESTED: CASH CHARGE DATE PROMISED _____

Ready for install
Find out if they want upright tank

email: _____
cell # 912 245 0385

PAY BILL ONLINE @congerlpgas.com

DIRECTIONS: Monday

TANK PICKUP/SET	TANK SIZE	SERIAL #	TANK %	TANK DESTINATION	DOT PERMANENTLY INSTALLED CONTAINERS				
					MANUFACTURED DATE	LAST TEST DATE	SIZE	SERIAL #	% FULL
<u>TS</u>	<u>118</u>	2608513 <u>2668513</u>	<u>80</u>	<u>On Site</u>					

QTY	APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED	MODEL #	SERIAL NUMBER	UNIT PRICE	SALES AMOUNT
<u>1</u>	<u>Pinrai w/lt</u>	<u>Zelwood</u>	<u>TJ.WA-132197</u>	<u>999.95</u>	<u>999.95</u>
<u>1</u>	<u>Sediment trap</u>			<u>75.00</u>	<u>75.00</u>
<u>1</u>	<u>Blde</u>			<u>84.95</u>	<u>84.95</u>
<u>30</u>	<u>3/8 copper</u>			<u>4.95</u>	<u>148.50</u>
<u>1</u>	<u>Cutoff</u>			<u>24.95</u>	<u>24.95</u>
<u>4</u>	<u>MIP/Flare nuts</u>			<u>2.95</u>	<u>11.80</u>

WORK PERFORMED: <u>SET TANK, Run Lines</u>	REGULATION INFORMATION	APPLIANCES/EQUIP. SOLD	CODE	SALES AMOUNT
<u>install w/lt. Gas check ok</u>	MAKE: <u>Fego</u> MODEL: <u>Blde</u>	MP	MP	<u>999.95</u>
<u>No Leaks in system.</u>	DATE CODE: <u>07B2024</u> VENT: <u>Down</u>	TANK RENT	TS	<u>345.20</u>
SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE				<u>10.00</u>
SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:				<u>18.95</u>

1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 <input type="checkbox"/> 2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A PAMPHLET NUMBER 54 <input type="checkbox"/> I HAVE RECEIVED A SCRATCH AND SNIFF BROCHURE AND THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME. X <u>Lori Mertz</u> CUSTOMER SIGNATURE	LEAK AND PRESSURE TEST			SALES TAX _____%	LABOR <u>MS</u>	INVTOTAL <u>1949.23</u>	
	HIGH:	1st Stage	2nd Stage				LOW
	START LOCK-UP:	PSI	PSI				START LOCK-UP: <u>13 W.C.</u>
	TANK OFF: PRESSURE	PSI	PSI				TANK OFF: PRESSURE <u>7 W.C.</u>
AFTER 10 MINUTES: PRESSURE AS LEFT:	PSI	PSI	AFTER 10 MINUTES: PRESSURE AS LEFT: <u>7 W.C.</u>	Gas <u>3.09/gal</u>	<u>311.43</u>		
PIPING PRESSURE TEST				AMOUNT RECEIVED			
START	PSIG	FINISH	PSIG				

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE.

SERVICE REP. SIGNATURE _____ DATE 11/10/25 CUSTOMER SIGNATURE _____