

INVOICE

FITZGERALD WATER LIGHT AND BOND  
P.O. Box 667  
FITZGERALD, GA 31750

(229) 426-5400

TO: RODNEY BULLOCK  
1103 HWY 32 E  
OCILLA, GA 31774

INVOICE NO: 55388  
DATE: 12/09/25

CUSTOMER NO: 3709/3785

TYPE: RR - Residential Irwin Co

QUANTITY	DESCRIPTION	UNIT PRICE	EXTENDED PRICE
1.00	MDSE - Appliances SER# TH UA 118053 Inventory item selected for charge code: AP-60000163010 Quantity: 1.00 TANKLESS WTR HTR R75 LP	1,112.18	1,112.18
1.00	MDSE - Appliances Inventory item selected for charge code: AP-60000163010 Quantity: 1.00 TANKLESS WTR HTR R75 LP	191.70	191.70
1.00	MDSE - Appliances Inventory item selected for charge code: AP-60000163010 Quantity: 1.00 TANKLESS WTR HTR R75 LP	69.90	69.90
1.00	Sales Tax	109.90	109.90
1.00	Tank Lease	60.00	60.00

TOTAL DUE: \$1,543.68

PLEASE DETACH AND SEND THIS COPY WITH REMITTANCE

DATE: 12/09/25 DUE DATE: 12/19/25  
CUSTOMER NO: 3709/3785

NAME: BULLOCK, RODNEY  
TYPE: RR - Residential Irwin Co

REMIT AND MAKE CHECK PAYABLE TO:  
FITZGERALD WATER LIGHT AND BOND  
P.O. Box 667  
FITZGERALD  
GA 31750

INVOICE NO: 55388  
TERMS: NET 10 DAYS

AMOUNT:

GA \$1,543.68  
Rebate - 200.00  
\$1,343.68

Account Number 3709  
 Name Rodney Bullock  
 Address 1103 Hwy 32 E.  
Ocala, GA

Call Date: 12/9/25 Date Requested: 12/23/25  
 Instructions: set tank / mount water heater

Appliance Check Item:	Central Heating 1	Space Heater 2	Water Heater 3	Range 4	Clothes Dryer 5	6	7
Manufacturer			Rinnai				
Model No.			TH-UA-118053				
Serial No.			RE180E				
Location			Exterior				
BTU	000	000	180 000	N/A	N/A	000	000
Age			New				
Manual Shutoff (Installed/Existing)			Installed				
Venting			gd				

TANK/CYLINDER 161Y

SIZE	SERIAL NUMBER	MFR.	MFR. DATE	Last Test Date	Location	Tank Cond.	Paint	Pigtail	Fittings	Gauge	Relief Valve			Fittings Leak Test
											Cond.	Date	Cap	
120	U-239866	CYSA	2025	8/15	Exterior	New	New	New	New	New	New	New	New	5m

PIPING/REGULATOR OPERATION/CONDITION

SINGLE STAGE	PIPING		REGULATOR DATE CODE	REGULATOR CONDITION	MFR.	MODEL	REG. VENT POSITION	HOW PROTECTED	FLOW PRESSURE
	MATERIAL	SIZE							
TWO STAGE	Copper	1/2	03/24	New	Rejo	LV404B4	Level	Done	11 IN. WC

SYSTEM LEAK TEST

SINGLE STAGE	Start Pressure	End Pressure	Time Held	System OK
	(Inches W.C.)	(Inches W.C.)		
TWO STAGE	11	11	5min	✓ OK

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

This inspection covers (propane/LP-Gas) items and equipment visible and accessible to the service technician and represents the conditions existing on the date of inspection. It does not cover latent or manufacturing defects, the internal working of sealed equipment, or structural components, and cannot be construed to cover future defects or unforeseen happenings.

Reference Invoice No. W5548618 Date 12/23/25  
 (Mo. Day Yr)

I, Rodney Bullock  
 (Please Print)

I, Chris Woods  
 (Please Print)

Know how to turn off gas in case of emergency.  
 Have smelled propane and can detect its odor.  
 Have received the Consumer Safety Information.  
 Had gas system deficiencies and / or corrections, if any, clearly explained to me.  
 Am satisfied with the service work performed.

Rodney Bullock  
 Customer's Signature

Certify that I have completed the System Check as prescribed

Performed Odor Test  Yes      Performed Pressure Test  Yes  
 Left Consumer Safety Info  Yes

Chris Woods  
 Delivery Man / Technician Signature