

146 S. Ridge Ave.
Tifton, GA 31794
(229) 386-5574

306 S. Main St.
Sylvester, GA 31791
(229) 776-7336

604-B N. Broadfoot Blvd.
Vidalia, GA 30474
(912) 537-8722

3117 Veterans Parkway S.
Moultrie, GA 31788
(229) 985-6942

2310-B Highway 84 W
Valdosta, GA 31602
(229) 469-4250

NAME Griffin Dunn RT# _____ RT. SEQ. _____ ACCT # 05.19478 DATE 5.21.25 INT CS

MAILING ADDRESS 2022 Wiregrass Circle CO. _____ CITY _____

ADDRESS _____ APT/LOT NO. _____

CITY Moultrie STATE GA ZIP CODE 31768

SERVICE REQUESTED: ☐ CASH ☐ CHARGE DATE PROMISED _____

DIRECTIONS: 0213

NEW CUSTOMER INFORMATION

S.S. NO. _____ DELV _____
HOME PH _____ RENT _____
WORK PH _____ CREDIT _____
LITE PILOT _____ PC _____
EMPLOYER _____
DR. _____ USE _____ LEASE _____

email: griffindaniieldunn@gmail.com

cell # 229 - 873-0212

PAY BILL ONLINE @congerlpgas.com

[illegible][illegible]

WORK PERFORMED:	Mounted water heater		REGULATION INFORMATION		APPLIANCES/EQUIP. SOLD	CODE	WH	1799.95
Set tank & performed leak test	MAKE:	RegO	MODEL:	TR9	PARTS/MAT. USED		MP	219.10
no leaks	DATE CODE:	05D2024	VENT:	down	TANK RENT		ms	23.95
SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE							CE	14.95
SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:		LEAK AND PRESSURE TEST			SALES TAX		1.92	144.00
1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58	☐	HIGH:	1st Stage	2nd Stage	LOW	____ %	1.20	80.17.53
2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A PAMPHLET NUMBER 54	☐	START LOCK-UP:	10 PSI	PSI	START LOCK-UP:	12 W.C.	LB	180.00
I HAVE RECEIVED A SCRATCH AND SNIFF BROCHURE AND THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.		TANK OFF: PRESSURE	9 PSI	PSI	TANK OFF: PRESSURE	9 W.C.	TR	10.00
		AFTER 10 MINUTES:	9 PSI	PSI	AFTER 10 MINUTES:	9 W.C.	GPC	400.00
		PRESSURE AS LEFT:	10 PSI	PSI	PRESSURE AS LEFT:	12 W.C.		
X 		PIPING PRESSURE TEST			INV. TOTAL			2072.70
CUSTOMER SIGNATURE		START	PSIG	FINISH	PSIG	AMOUNT RECEIVED		GPC 400.00

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE.

SERVICE REP. SIGNATURE

DATE _____

CUSTOMER SIGNATURE