



146 S. Ridge Ave.
Tifton, GA 31794
(229) 386-5574

30¢
Sylve:
(22

Application Rinnai GPC
Gas Check Warranty Inv
New Cust Pkg 5 Yr Letter
Lease/Rent/Amt 4/1 N

INVOICE / WORK ORDER NO.

113752

3117 Veterans Parkway S.
Moultrie, GA 31788
(229) 985-6942

NAME Whipple Jack Farms RT# AA RT. SEQ. 0064 ACCT # 1-60135 DATE 5/1/25 INT 2

MAILING ADDRESS _____ CO. _____ CITY _____

ADDRESS 407 Red Oak Rd. APT/LOT NO. _____

CITY Tifton STATE GA ZIP CODE 31794

SERVICE REQUESTED: ☐ CASH ☐ CHARGE DATE PROMISED _____

Run line, Purchase & install Rinnai

DIRECTIONS:

(Formerly under Roger Womack)

TANK PICKUP/SET	TANK SIZE	SERIAL #	TANK %	TANK DESTINATION	DOT PERMANENTLY INSTALLED CONTAINERS				
	250	250030099	0	ON SITE	MANUFACTURED DATE	LAST TEST DATE	SIZE	SERIAL #	% FULL
		30639							
								3	95

QTY	APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED	MODEL #	SERIAL NUMBER	UNIT PRICE	SALES AMOUNT
1	Rinnai	RL75e	RLA045215		999.95
81	3/4 POLY				76.75
2	3/4 TRANSITIONS				89.90
2	3/4 COUPLING				89.90
1	Sediment				50.00
1	B46R Res				87.75
10	1/2 COPPER				49.50
2	1/2 flare nuts				5.75
1	Cutoff Valve				29.75

WORK PERFORMED:	REGULATION INFORMATION	APPLIANCES/EQUIP. SOLD	CODE
<u>Run line & installed Rinnai</u>	MAKE: <u>R660</u> MODEL: <u>7L7</u>	<u>WH</u>	<u>999.95</u>
	DATE CODE: <u>502024</u> VENT: <u>DOWN</u>	<u>MP</u>	<u>486.05</u>
		TANK RENT	

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:

1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 ☐

2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 ☐

I HAVE RECEIVED A SCRATCH AND SNIFF BROCHURE AND THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.

X _____
CUSTOMER SIGNATURE

LEAK AND PRESSURE TEST				French	
HIGH:	1st Stage	2nd Stage	LOW	SALES TAX	
START LOCK-UP:	11 PSI	PSI	START LOCK-UP:	8%	08
TANK OFF: PRESSURE	9 PSI	PSI	TANK OFF: PRESSURE		EQ
AFTER 10 MINUTES:	9 PSI	PSI	AFTER 10 MINUTES:		MS
PRESSURE AS LEFT:	11 PSI	PSI	PRESSURE AS LEFT:		GPC
PIPING PRESSURE TEST				INV. TOTAL	1,770.85
START	PSIG	FINISH	PSIG	AMOUNT RECEIVED	

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE.

Eva Puhara
SERVICE REP. SIGNATURE

5-5-25
DATE

X

CUSTOMER SIGNATURE