



146 S. Ridge Ave.  
Tifton, GA 31794  
(229) 386-5574

306 S. I  
Sylvester,  
(229) 77

Application ℓ Rinnai ℓ GPC  
Gas Check ℓ Warranty ℓ Inv ℓ  
New Cust Pkg ℓ 5 Yr ℓ Letter ℓ  
Lease/Rent/Amt ℓ 1 ℓ 1 ℓ

INVOICE / WORK ORDER NO.

113765

3117 Veterans Parkway S.  
Moultrie, GA 31788  
(229) 985-6942

NAME Cal Carpenter RT# E1 RT. SEQ. ACCT # 1-61024 DATE 5/8/25 INT ℓ

MAILING ADDRESS CO. CITY

ADDRESS 29 Moore Hl. APT/LOT NO.

CITY Tifton STATE GA ZIP CODE 31794

SERVICE REQUESTED: ☐ CASH ☐ CHARGE DATE PROMISED

Run line, Install Rinnai, Hookup generator

NEW CUSTOMER INFORMATION

S.S. NO. DELV  
HOME PH RENT  
WORK PH CREDIT  
LITE PILOT PC  
EMPLOYER   
DR. USE LEASE

email: Wayne Carpenter 58@xal.com

cell # 229-326-9194

PAY BILL ONLINE @congerlpgas.com

DIRECTIONS:

TANK PICKUP/SET	TANK SIZE	SERIAL #	TANK %	TANK DESTINATION	DOT PERMANENTLY INSTALLED CONTAINERS				
	120	25A17458	ℓ	ON SITE	MANUFACTURED DATE	LAST TEST DATE	SIZE	SERIAL #	% FULL

QTY	APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED	MODEL #	SERIAL NUMBER	UNIT PRICE	SALES AMOUNT
1	Rinnai	RE180CP	TBUA022650		1199.95
1	B46R R29				89.95
1	Sediment / Mult Tees				70.00
3	Cutoff Valve				89.85
20-	1/2 COPPER				99.00
1	6 ft hose				19.95
1	1/2 union				3.95
5	1/2 flange Tees				14.75
	misc supplies				44.85

WORK PERFORMED:	REGULATION INFORMATION	APPLIANCES/ EQUIP. SOLD	CODE	SALES AMOUNT
Install Rinnai, run line to grill + portable generator for the future	MAKE: R660 MODEL: TR9 DATE CODE: 5D2024 VENT: DOWN		WH	1199.95
		PARTS/MAT. USED	mp	387.45
		TANK RENT	CF	14.95

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:		LEAK AND PRESSURE TEST		SALES TAX		
1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 <input type="checkbox"/>		HIGH: 1st Stage 2nd Stage LOW		8 %	08	96.00 31.00 1.20 3.59
2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A PAMPHLET NUMBER 54 <input type="checkbox"/>		START LOCK-UP: 11 PSI PSI START LOCK-UP: W.C. LABOR			LB	360.00
I HAVE RECEIVED A SCRATCH AND SNIFF BROCHURE AND THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.		TANK OFF: PRESSURE 9 PSI PSI TANK OFF: PRESSURE W.C.			ms	44.85
		AFTER 10 MINUTES: 9 PSI PSI AFTER 10 MINUTES: W.C. GPC			GR2	(400.00)
		PRESSURE AS LEFT: 11 PSI PSI PRESSURE AS LEFT: W.C.				
X CUSTOMER SIGNATURE		PIPING PRESSURE TEST		INV. TOTAL		1738.99
		START PSIG FINISH PSIG		AMOUNT RECEIVED		

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE.

Eric Pruthi  
SERVICE REP. SIGNATURE

5-16-25  
DATE

x

CUSTOMER SIGNATURE