

- R



1335 US Hwy 82 W, Leesburg, GA 31763 (229) 435-6116 FAX (229) 435-6119

Order Number 881408	Date Written 4/28/2025	Taken By: MEH	Schedule Date 5/2/25	Date Completed 5/2/25
Branch - Customer No. 1-17910	Home 229 328-8036	Work	Time Started 9:20 A.M. P.M.	Time Completed 5:00 A.M. P.M.
Name MORRIS FAIRCLOTH	Address 133 FOWLER DR City LEESBURG, GA	Cell Zip 31763-5013	wh / cook - 30 min lunch	
Service Address 133 FOWLER DR	LEESBURG, GA 31763			
Work to be performed: DELIVER AND INSTALL RINNAI RX160in WITH INSTALL KIT 184162PP CONDENSING ROOF DIS 189958 FLASHING, 11470 CAMCO DRAIN PAN, AND OTHER VENTING. CALLED IN BY MORRIS. 229-328-8036			Work completed Removed old W.H. Installer Rinnai, vented w/drain pan, Run drain line.	

Qty:	Materials	Price	Amount	Qty:	Materials	Price	Amount
①	W-R 11470 CAMCO Drain Pin	7	39.00	①	W-R R4160 IN/P Round Wets - Ht R	7	1088.00
				①	W-R R4160 IN/P Inst full kit	7	98.00
NG	DOB + White Copy		301.89	①	W-R 184162 PP Root Discharge	7	73.00
				①	W-R 189958 Flashing	7	72.00
DR. RT.	Rt. Seq.	Rate	Deposit				
Tank Make	Size 120	Serial No 81261	Tank Percent	1	WR 224077PP		41.-
Single Stage	Regular Date	Reg. Condition	Mfr.		45° elbow		
TWO	1st			2	WR 224080PP	39.-	78.-
STAGE	2nd				39" Venting		

Less Check		Flow Check		Lock-up Check		SHOP OR TRUCK SUPPLIES		14 50	
Manometer Reading at Start 10		Manometer Reading After 10 minutes 10		Manometer Reading Under Load		Manometer Reading		MATERIAL TOTAL 1805 39	
Central Heating		Water Heater		Range		Clothes Dryer		TRIP CHARGE	
Manufacturer		Rinnai						LABOR	
Model No.		RX160iN						SUB-LABOR	
Serial No.		SL-BA-195682						PERMIT Rebate	
Sed. Trap Vent		Yes Yes						SHIPPING/FREIGHT	
Fuel/BTU 000		160, 000		N/A		N/A		SALES TAX	
AGE		2019						Thank You	
Shut off Installed		Yes						144 43	

☐ CASH ☐ CHECK		RECEIVED BY	You TOTAL	1749.82
Work Completed by: <i>Mike & A.J.</i>		Date: <i>5/2/25</i>	ANY UNUSED GAS PIPING OUTLETS INDOORS? ☐ YES ☐ NO	
Customer Signature: <i>[Signature]</i>		Date: <i>5/2/25</i>	IF YES, IS EACH UNUSED GAS PIPING OUTLET FITTED WITH A GAS TIGHT THREADED PLUG OR CAP? ☐ YES ☐ NO	
I ACKNOWLEDGE THAT I HAVE READ AND UNDERSTAND THE IMPORTANT SAFETY INSTALLATION INFORMATION PRINTED ON BACK OF THE CUSTOMER COPY			CUSTOMER AVAILABLE ☐ YES ☐ NO CUSTOMER SMELLED ODORIZED PROPANE AND SHOWN THE SHUTDOWN PROCEDURE ☐ YES ☐ NO	