

SALES
SERVICE
INSTALLATION

MODERN GAS
THE PROS IN PROPANE SINCE 1954

propane

R

2nd Call

Mike / AJ

1335 US Hwy 82 W, Leesburg, GA 31763 (229) 435-6116 FAX (229) 435-6119

Order Number 881946	Date Written 4/29/25	Taken By: JC	Schedule Date 5/01/25	Date Completed 5/1/25
Branch - Customer No. 1-17865	Home 229 886-0815	Work	Time Started 11:00	Time Completed 12:50
Name WILLIE HIGHTOWER	Address LATARIA HIGHTOWER	Cell	OLD DAWSON RT VANCISE RT WINIFRED RT AMBLESIDE RT HAWKSTEAD HO ON LFT WH / LOGS	
City LEESBURG, GA	State 31763	Zip		
Service Address 256 HAWKSTEAD DRIVE LEESBURG, GA 31763				
Work to be performed: REMOVE OLD WATER HEATER AND INSTALL NEW BRADFORD WHITE 50 GALLON WATER HEATER PER MS HIGHTOWER - 229-886-0815			Work completed Removed old Waterheater Installed new Waterheater	

4 ✓ Copy

Qty:	Materials	Price	Amount	Qty:	Materials	Price	Amount
2	3/4 FIP X 3/4 PEX adp		8.14	1	WT Bradford 50 P		899.-
3	3/4 PEX Elbow		8.94				
2	3/4 PEX coup		6.24				
1	3/4 PEX pipe		1.-				
13	3/4 PEX rings		5.46				
			29.78				
DR. RT. Rt. Seq. Rate Deposit							
Tank Make		Size 61	Serial 05A075853	Tank Percent			
Single Stage	Regular Date	Reg. Condition	Mfr.	Model	Vent Pos.	Protected?	
TWO 1st							
STAGE 2nd							

Less Check Manometer Reading at Start 10		Manometer Reading After 10 minutes 10		Flow Check Manometer Reading Under Load		Lock-up Check Manometer Reading		SHOP OR TRUCK SUPPLIES 16 50	
Central Heating		Water Heater		Range		Clothes Dryer		MATERIAL TOTAL 945 28	
Manufacturer Bradford White		Model No. RG250T6X		Serial No. ALS4365091		Sed. Trap Vent yes		TRIP CHARGE	
Fuel/BTU 000		36 000		N/A		N/A		LABOR 340 -	
AGE		yes						SUB-LABOR Rebate <200 00	
Shut off Installed		yes						PERMIT	
☐ CASH ☐ CHECK		RECEIVED BY		Work Completed by: Mike B. / AJC		Date May 1, 25		SHIPPING/FREIGHT	
Customer Signature: Latania Hightower		Date 5/1/25		I ACKNOWLEDGE THAT I HAVE READ AND UNDERSTAND THE IMPORTANT SAFETY INSTALLATION INFORMATION PRINTED ON BACK OF THE CUSTOMER COPY		Thank You		SALES TAX 75 62	
								TOTAL 1160 90	
								ANY UNUSED GAS PIPING OUTLETS INDOORS? ☐ YES ☒ NO	
								IF YES, IS EACH UNUSED GAS PIPING OUTLET FITTED WITH A GAS TIGHT THREADED PLUG OR CAP? ☐ YES ☐ NO	
								CUSTOMER AVAILABLE ☒ YES ☐ NO	
								CUSTOMER SMELLED ODORIZED PROPANE AND SHOWN THE SHUTDOWN PROCEDURE ☒ YES ☐ NO	