



HOME OWNED & OPERATED

P.O. BOX 506 • BAXLEY, GEORGIA 31515
2174 HATCH PARKWAY SOUTH • BAXLEY, GEORGIA 31513 • Tel. (912) 367-1151

INVOICE

No 11256

NAME	Kevin Gillard	ACCOUNT NO.	
MAIL ADDRESS	765 Sugarbrook Rd.	DATE ORDERED	
CITY/STATE/ZIP	Broxton GA 31519	DATE PROMISED	
PHONE	912-309-2198	DATE COMPLETED	4-16-25
LOCATION		TERMS	

INSTRUCTIONS install 500 gallon AG/UG tank, run gas lines, install tankless water heater, hook up generator, run gas line to outdoor kitchen

QTY.	TAG NO. AND DESCRIPTION OF APPLIANCE/MATERIAL	UNIT PRICE	SALES AMOUNT
1	500 gallon, 1984 Quality Steel tank, serial #188656		800 00
1	500 gallon AG/UG, 2024 Quality Steel tank		3800 00
1	17Lb Anode bag		300 00
1	Rinnai RE199e tankless water heater w/isolation valves		1500 00
	serial # SM.UA-177468 / 55' - 3/4" poly pipe	1 00	55 00
98'	1/2" coated copper tubing	3 29	322 42
15'	3/8" coated copper tubing	2 79	41 85
3	3/4" IPS riser	139 00	417 00
	all other gas fittings, water fittings, pex pipe, power wire		
	all other gas fittings, water fittings, pex pipe, power wire		242 80

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:

1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 ☐

2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 ☐

THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.

X CUSTOMER'S SIGNATURE

SERVICES PERFORMED

installed 500 gallon AG/UG tank, tankless water heater, gas lines, regulators, + all fittings, connected generator + converted it to LP, ran pressure check, lit + checked water heater

TOTAL TIME _____ HOURS

TOTAL MATERIAL

LABOR

SUBTOTAL

SALES TAX

TOTAL DUE

- GPA rebate 400.00
AMOUNT

\$ 7869.40

RECEIVED BY _____

DATE _____

SERVICES RECEIVED BY _____

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

INSTALLATION OR TURN ON	REMOVAL OR TURN OFF	LEAK AND PRESSURE TEST	
		HIGH	LOW
SIZE: 500	SIZE	START LOCK UP:	START LOCK UP:
S/N: 1523700	S/N	TANK OFF PRESSURE:	TANK OFF PRESSURE:
GALLONS OR READING: 0%	GALLONS OR READING:	AFTER 10 MINUTES:	AFTER 10 MINUTES:
		PRESSURE AS LEFT:	PRESSURE AS LEFT:

WHITE/CUSTOMER'S COPY; YELLOW/POSTING COPY; PINK/FILE COPY

GASCheck - Gas Appliance System Check

Account Name _____ Invoice Number _____ Date 4/16/25
 Name Kevin Gillard Company Sikes Propane, Inc.
 Address 765 Sugarbrook Rd Call Taken By _____
 City Broxton State GA Zip 31519 Telephone (Cell) 912-309-2198 (Home) _____
 Appliance Check

Appliance	<u>water heater</u>	<u>Generator</u>				
Manufacturer	<u>Rinnai</u>	<u>Generac</u>				
Model #	<u>RE199a</u>	<u>G00720910</u>				
Serial #	<u>SM.UA-177</u>	<u>30153758</u>				
	<u>468</u>	<u>49</u>				
BTU's	<u>199,000</u>	<u>355,000</u>				
Burner / Com. Chamber	<u>ok</u>	<u>ok</u>				
Man. Shutoff / Sed. Trap	<u>installed</u>	<u>installed</u>				
Control / Pilot Safety System	<u>ok</u>	<u>ok</u>				
Venting System	<u>ok</u>	<u>ok</u>				
Age	<u>new</u>	<u>new</u>				
Taken Out Of Service Or Operation						

Container Check

Size	Serial #	Manufacturer	MFR. Date	Location	Container Condition	Relief Valve	Fittings Leak Check
<u>500</u>	<u>1523700</u>	<u>Quality Steel</u>	<u>2024</u>	<u>ok</u>	<u>new</u>	<u>09D22</u>	<u>ok</u>

Pressure Test (If Applicable)

Start Pressure	End Pressure	Time Held	Pressure Held
<u>125psi.</u>	<u>125psi.</u>	<u>10min.</u>	<u>0</u>
			Work Order <u>0</u>

System Leak Check

Start Pressure	End Pressure	Time Held	Pressure Held
<u>9in.wc.</u>	<u>9in.wc.</u>	<u>10min.</u>	<u>0</u>
			Work Order <u>0</u>

Regulator Check

Type	Manufacturer	Date / Model	Vent Position / Protection
<u>first</u>	<u>Rego</u>	<u>08D2024 / LV4403 TR9</u>	<u>u-c</u>
<u>second</u>	<u>Rego</u>	<u>04C2024 / LV4403B66R</u>	<u>down</u>
<u>second</u>	<u>Rego</u>	<u>06C2022 / LV3403B4</u>	<u>down</u>

Safety Information Supplied:

Comments: Please note all repairs and corrections made along with any recommended actions