



INVOICE

No 11261 ✓

HOME OWNED & OPERATED

P.O. BOX 506 • BAXLEY, GEORGIA 31515
2174 HATCH PARKWAY SOUTH • BAXLEY, GEORGIA 31513 • Tel. (912) 367-1151

NAME	<u>Tan Carter</u>	ACCOUNT NO.	
MAIL ADDRESS	<u>3401 Ben Carter Rd.</u>	DATE ORDERED	
CITY/STATE/ZIP	<u>Baxley GA 31513</u>	DATE PROMISED	
PHONE	<u>912-240-1127</u>	DATE COMPLETED	<u>4-15-25</u>
LOCATION		TERMS	

INSTRUCTIONS set 120 gallon tank, ran all gas lines, installed
tankless water heater, fire box, & gas logs

QTY.	TAG NO. AND DESCRIPTION OF APPLIANCE/MATERIAL	UNIT PRICE	SALES AMOUNT
1	Rinnai RL75e tankless water heater w/isolation		1285 00
	valves & T-pad, serial # PD, CA-06 7750		
1	Peterson G10-24/30-15(M)P, 24" v/h remote log set		1248 50
1	BUF 36-T fire box w/ T-stat blower		799 00
100	gallon of propane	2 99	299 00
1	Rego LV3403R4 second stage regulator		59 95
20	1/2" coated copper tubing	3 29	65 80
65	3/8" coated copper tubing	2 79	181 35
1	4' x 3/8" high pressure hose		19 95
all	other gas fittings, cut off valves, thread sealant, T-stat		131 45
TOTAL MATERIAL			4090 00

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:

1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 ☐2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 ☐

SERVICES PERFORMED

set 120 gallon tank,
ran all gas lines, installed tankless
water heater, fire box, logs, ran propane
check, lit & checked out appliances

TOTAL TIME _____ HOURS

LABOR

980 00

THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.

SERVICES PERFORMED

BY

Don Sikes, C.T., Reg.

SUBTOTAL

SALES TAX

327 20

TOTAL DUE

5397 20

X _____
CUSTOMER'S SIGNATURE

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

INSTALLATION OR TURN ON	REMOVAL OR TURN OFF	LEAK AND PRESSURE TEST	
		HIGH	LOW
SIZE: <u>120</u>	SIZE	START LOCK UP:	START LOCK UP:
S/N: <u>1527896</u>	S/N:	TANK OFF PRESSURE:	TANK OFF PRESSURE:
GALLONS OR READING: <u>100 gal</u>	GALLONS OR READING:	AFTER 10 MINUTES: PRESSURE AS LEFT:	AFTER 10 MINUTES: PRESSURE AS LEFT:

-GPA rebate 400.00
AMOUNT
PAID \$ 4,997.20

RECEIVED
BY _____

DATE _____

SERVICES RECEIVED
BY _____

WHITE/CUSTOMER'S COPY; YELLOW/POSTING COPY; PINK/FILE COPY

GASCheck - Gas Appliance System Check

Account Name _____ Invoice Number _____ Date 4/15/25
 Name Tan Carter Company Sikes Propane, Inc.
 Address 3401 Ben Carter Rd. Call Taken By _____
 City Baxley State GA Zip 31513 Telephone (Cell) 912-240-1127 (Home) _____
 Appliance Check

Appliance	<u>water heater</u>	<u>gas Logs</u>				
Manufacturer	<u>Rinnai</u>	<u>Peterson</u>				
Model #	<u>RL75e</u>	<u>G10-24/30</u>				
Serial #	<u>PD.CA-06</u>	<u>75CMP</u>				
	<u>7750</u>	<u>2020264</u>				
BTL's	<u>180,000</u>	<u>37,000</u>				
Burner, Com. Chamber	<u>ok</u>	<u>ok</u>				
Man. Shutoff / Sed. Trap	<u>installed</u>	<u>installed</u>				
Control / Pilot Safety System	<u>ok</u>	<u>ok</u>				
Venting System	<u>ok</u>	<u>ok</u>				
Age	<u>new</u>	<u>new</u>				
Taken Out Of Service Or Operation		<u>24"</u>				

Container Check

Size	Serial #	Manufacturer	MFR. Date	Location	Container Condition	Relief Valve	Fittings Leak Check
<u>120</u>	<u>1527896</u>	<u>Quality Steel</u>	<u>2024</u>	<u>ok</u>	<u>new</u>	<u>09D22</u>	<u>ok</u>

Pressure Test (If Applicable)

Start Pressure	End Pressure	Time Held	Pressure Held
<u>115 psi.</u>	<u>115 psi.</u>	<u>10 min.</u>	<u>0</u>
			<u>0</u>

Piping Check

Materials	Size	Cover / Protection
<u>Coated copper</u>	<u>1/2" & 3/8"</u>	<u>ok</u>

System Leak Check

Start Pressure	End Pressure	Time Held	Pressure Held
<u>9 in. wc.</u>	<u>9 in. wc.</u>	<u>10 min.</u>	<u>0</u>
			<u>0</u>

Regulator Check

Type	Manufacturer	Date	Model	Vent Position Protection
<u>first</u>	<u>MEC</u>	<u>06 Jul 22</u>	<u>MEGR-122H-BGF</u>	<u>n-c</u>
<u>second</u>	<u>Rego</u>	<u>10 D 2023</u>	<u>LV3403B4</u>	<u>down</u>

Safety Information Supplied:

Comments: Please note all repairs and corrections made along with any recommended actions