

SALES
SERVICE
INSTALLATION



RH/CH

1335 US Hwy 82 W, Leesburg, GA 31763 (229) 435-6116 FAX (229) 435-6119

Order Number 881733	Date Written 4/29/25	Taken By: MEH	Schedule Date 5/2/25	Date Completed 5/2/25
Branch - Customer No. 1-16687	Home 772 388-8882	Work	Time Started 9:15	Time Completed 5:30
Name JC WELTON CONSTRUCTION INC	Address JACK & KELLY WELTON	City VERO BEACH, FL	State FL	Zip 32967
Service Address 5645 VENEYS MILL PONPARROTT, GA 39877			US 82 W TO PARROTT LFT VENEYS MILL PND RD HO ON LFT 772-388-8882 Jack 772-473-9529 Kelly	

Work to be performed: DELIVER AND INSTALL (2) RINNAI RXP199IN WITH (2) 107000639 INSTALL KITS, (2) RXOVC OUTDOOR VENT CAPS, AND (2) PCD11-SHS PIPE COVERS. CALLED IN BY KELLY. 772-473-9529 CELL: 772-260-0847

Work completed: Delivered and installed 2 Rinnais and Connected gas line

Qty:	Materials	Price	Amount	Qty:	Materials	Price	Amount
	RXP199:			(2)	W-R RXP199IN/P	712.00	3404.00
	SE.BA-080164			(2)	W-R 107000639	151.00	302.00
	RXP199:			(2)	W-R RXOVC	47.00	94.00
	SE.BA-079132			(2)	W-R PCD11SHS	152.00	304.00
				(2)	W-R MC-195T-45	234.00	468.00

Less Check		Flow Check		Lock-up Check	
Manometer Reading at Start 8	Manometer Reading After 10 minutes 8	Manometer Reading Under Load	Manometer Reading	SHOP OR TRUCK SUPPLIES	14.50
Central Heating	Water Heater	Range	Clothes Dryer	MATERIAL TOTAL	4536.50
Manufacturer	Rinnai			TRIP CHARGE	
Model No.	RXP199IN/P			LABOR	300.00
Serial No.	SEBA-080164			SUB-LABOR Rebate	<400.00
Sed. Trap	I			PERMIT	
Fuel/BTU	199	N/A	N/A	SHIPPING/FREIGHT	
AGE	New			SALES TAX	360.92
Shut off installed	Y			TOTAL	4853.42

ACKNOWLEDGE THAT I HAVE READ AND UNDERSTAND THE IMPORTANT SAFETY INSTALLATION INFORMATION PRINTED ON BACK OF THE CUSTOMER COPY

Customer Signature: *SC Well* Date: 5/2/25

Work completed by: *Curtis Royce* Date: 5/2/25

Thank You

ANY UNUSED GAS PIPING OUTLETS INDOORS? ☐ YES ☐ NO

IF YES, IS EACH UNUSED GAS PIPING OUTLET FITTED WITH A GAS TIGHT THREADED PLUG OR CAP? ☐ YES ☐ NO

CUSTOMER AVAILABLE ☐ YES ☐ NO

CUSTOMER SMELLED ODORIZED PROPANE AND SHOWN THE SHUTDOWN PROCEDURE ☐ YES ☐ NO