



146 S. Ridge Ave.
Tifton, GA 31794
(229) 386-5574

306 S. I
Sylvester,
(229) 71

Application ☒ Rinnai ☒ GPC
Gas Check ☒ Warranty ☒ Inv
New Cust Pkg ☐ 5 Yr ☐ Letter
Lease/Rent/Amt ☐

INVOICE / WORK ORDER NO.

113779

3117 Veterans Parkway S.
Moultrie, GA 31788
(229) 985-6942

NAME 1312 WMR Properties RT# A03 RT. SEQ. ACCT # 1-23523 DATE 5/20/25 INT Ln

MAILING ADDRESS _____ CO. _____ CITY _____

ADDRESS 1330 Whidden Mill Rd. APT/LOT NO. _____

CITY Tifton STATE GA ZIP CODE 31793

NEW CUSTOMER INFORMATION

S.S. NO. _____ DELV _____
HOME PH _____ RENT _____
WORK PH _____ CREDIT _____
LITE PILOT _____ PC _____
EMPLOYER _____
DR. _____ USE _____ LEASE _____

email: mcatpeck@gmail.com
cell # 229-251-8833

PAY BILL ONLINE @congerlpgas.com

SERVICE REQUESTED: ☐ CASH ☐ CHARGE DATE PROMISED _____

Set 120, Run Line & install Rinnai

DIRECTIONS:

Renters will set up own acct for gas

TANK PICKUP/SET	TANK SIZE	SERIAL #	TANK %	TANK DESTINATION	DOT PERMANENTLY INSTALLED CONTAINERS				
<u>TS</u>	<u>120</u>	<u>1528509</u>	<u>1</u>	<u>ON SITE</u>	MANUFACTURED DATE	LAST TEST DATE	SIZE	SERIAL #	% FULL

QTY	APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED	MODEL #	SERIAL NUMBER	UNIT PRICE	SALES AMOUNT
<u>20</u>	<u>gasoline</u>			<u>3.999</u>	<u>79.98</u>
<u>1</u>	<u>Rinnai</u>	<u>REP160</u>	<u>PKUA112510</u>		<u>999.95</u>
<u>20</u>	<u>3/8 LOPPER</u>				<u>79.00</u>
<u>1</u>	<u>Butt Regulator</u>				<u>89.95</u>
<u>1</u>	<u>Sediment</u>				<u>50.00</u>
<u>2</u>	<u>3/8 flare nuts</u>				<u>5.95</u>
<u>1</u>	<u>MIP</u>				<u>3.95</u>
<u>1</u>	<u>Cutoff Valve</u>				<u>29.95</u>
<u>1</u>	<u>Electrical Pigtail</u>				<u>19.95</u>

WORK PERFORMED:	REGULATION INFORMATION	APPLIANCES/EQUIP. SOLD	CODE
<u>Set tank, install</u>	MAKE: <u>Reyo</u> MODEL: <u>TR9</u>	PARTS/MAT. USED	
<u>Rinnai. Run line</u>	DATE CODE: <u>182025</u> VENT: <u>DOWN</u>	TANK RENT	

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:		LEAK AND PRESSURE TEST			SALES TAX	
1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 <input type="checkbox"/>		HIGH:	1st Stage	2nd Stage	LOW	%
2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 <input type="checkbox"/>		START LOCK-UP:	<u>11</u> PSI	PSI	START LOCK-UP:	W.C.
I HAVE RECEIVED A SCRATCH AND SNIFF BROCHURE AND THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.		TANK OFF: PRESSURE	<u>9</u> PSI	PSI	TANK OFF: PRESSURE	W.C.
		AFTER 10 MINUTES: PRESSURE	<u>9</u> PSI	PSI	AFTER 10 MINUTES: PRESSURE	W.C.
		AS LEFT:	<u>11</u> PSI	PSI	AS LEFT:	W.C.
		PIPING PRESSURE TEST			INV. TOTAL	
X _____ CUSTOMER SIGNATURE		START	PSIG	FINISH	PSIG	AMOUNT RECEIVED

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE.

Eric Pritchard
SERVICE REP. SIGNATURE

5-30-25
DATE

X

CUSTOMER SIGNATURE