



congerlpgas.com

INVOICE / WORK ORDER NO.

146 S. Ridge Ave.  
Tifton, GA 31794  
(229) 386-5574306 S. Main St.  
Sylvester, GA 31791  
(229) 776-7336604-B N. Broadfoot Blvd.  
Vidalia, GA 30474  
(912) 537-87223117 Veterans Parkway S.  
Moultrie, GA 31788  
(229) 985-6942

10328

110465

NAME Classic Homes By Weaver RT# \_\_\_\_\_ RT. SEQ. \_\_\_\_\_ ACCT # \_\_\_\_\_ DATE 6-10-25 VT \_\_\_\_\_MAILING ADDRESS 112 Bear Trace CO. \_\_\_\_\_ CITY \_\_\_\_\_

ADDRESS \_\_\_\_\_ APT/LOT NO. \_\_\_\_\_

CITY Mableton STATE GA ZIP CODE \_\_\_\_\_SERVICE REQUESTED: ☐ CASH ☐ CHARGE DATE PROMISED \_\_\_\_\_\_\_\_\_\_ Register \_\_\_\_\_

DIRECTIONS:

10 Gallons Gas

## NEW CUSTOMER INFORMATION

S.S. NO. \_\_\_\_\_ DELV \_\_\_\_\_  
HOME PH \_\_\_\_\_ RENT \_\_\_\_\_  
WORK PH \_\_\_\_\_ CREDIT \_\_\_\_\_  
LTE PILOT \_\_\_\_\_ PC \_\_\_\_\_  
EMPLOYER \_\_\_\_\_  
DR. \_\_\_\_\_ USE \_\_\_\_\_ LEASE \_\_\_\_\_

email: \_\_\_\_\_

cell # \_\_\_\_\_

PAY BILL ONLINE @congerlpgas.com

TANK PICKUP/SET	TANK SIZE	SERIAL #	TANK %	TANK DESTINATION	DOT PERMANENTLY INSTALLED CONTAINERS				
<u>Set</u>	<u>120</u>	<u>25A0289</u>			MANUFACTURED DATE	LAST TEST DATE	SIZE	SERIAL #	% FULL

QTY	APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED	MODEL #	SERIAL NUMBER	UNIT PRICE	SALES AMOUNT
<u>1</u>	<u>REP 160e</u>		<u>PLWA-119883</u>		<u>899.99</u>
<u>10</u>	<u>gal gas</u>				
<u>1</u>	<u>5 shut off</u>				<u>13.11</u>
<u>1</u>	<u>Misc Iron</u>	<u>Prp leg</u>			<u>21.83</u>
<u>2</u>	<u>Flare nuts</u>				<u>2.16</u>
<u>1</u>	<u>Reg</u>				<u>58.11</u>
<u>15</u>	<u>copper</u>				<u>33.60</u>
<u>1</u>	<u>Permit</u>				<u>77.62</u>
<u>1</u>	<u>3/4 x 1/2 mfp</u>				<u>1.99</u>

WORK PERFORMED:	REGULATION INFORMATION	APPLIANCES/EQUIP. SOLD	CODE
<u>TS gas ck no</u>	MAKE: <u>Reco</u> MODEL: <u>TR9</u>	PARTS/MAT. USED	
<u>Leak test</u>	DATE CODE: <u>1-34</u> VENT: <u>Nov</u>	TANK RENT	

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:

1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 ☐2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 ☐

I HAVE RECEIVED A SCRATCH AND SNIFF BROCHURE AND THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.

X

CUSTOMER SIGNATURE

## LEAK AND PRESSURE TEST

HIGH:	1st Stage	2nd Stage	LOW
START LOCK-UP:	PSI	PSI	START LOCK-UP: <u>13.7</u> W.C.
TANK OFF: PRESSURE	PSI	PSI	TANK OFF: PRESSURE <u>9</u> W.C.
AFTER 10 MINUTES: PRESSURE	PSI	PSI	AFTER 10 MINUTES: <u>9</u> W.C.
AS LEFT:	PSI	PSI	PRESSURE AS LEFT: <u>13.7</u> W.C.

SALES TAX \_\_\_\_\_ %

LABOR

GPC <400.00

## PIPING PRESSURE TEST

INV. TOTAL

START \_\_\_\_\_ PSIG FINISH \_\_\_\_\_ PSIG AMOUNT RECEIVED \_\_\_\_\_

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE.

SERVICE-REP. SIGNATURE

DATE

X

CUSTOMER SIGNATURE

WHITE/FILE COPY; YELLOW/CUSTOMER COPY; PINK/POSTING COPY; BLUE/OFFICE COPY