



congerlpgas.com

120877

146 S. Ridge Ave.
Tifton, GA 31794
(229) 386-5574

306 S. Main St.
Sylvester, GA 31791
(229) 776-7336

604-B N. Broadfoot Blvd.
Vidalia, GA 30474
(912) 537-8722

3117 Veterans Parkway S.
Moultrie, GA 31788
(229) 985-6942

2310-B Highway 84 W
Valdosta, GA 31602
(229) 469-4250

NAME Ed Souther (mom's hse) RT# _____ RT. SEQ. _____ ACCT # 02-11073 DATE 6-9-25 INT 18

MAILING ADDRESS _____ CO. _____ CITY _____

ADDRESS 108 Ed's Drive APT/LOT NO. _____

CITY Sumner STATE GA ZIP CODE 31789

NEW CUSTOMER INFORMATION	
S.S. NO.	DELV
HOME PH	RENT
WORK PH	CREDIT
LITE PILOT	PC
EMPLOYER	
DR.	USE LEASE

email:

cell # 776-4795

PAY BILL ONLINE @congerlpgas.com

SERVICE REQUESTED: ☐ CASH ☐ CHARGE DATE PROMISED _____

DIRECTIONS:

Install tankless w/h

TANK PICKUP/SET	TANK SIZE	SERIAL #	TANK %	TANK DESTINATION	DOT PERMANENTLY INSTALLED CONTAINERS				
					MANUFACTURED DATE	LAST TEST DATE	SIZE	SERIAL #	% FULL

QTY	APPLIANCES / EQUIP. SOLD-PARTS/MATERIAL USED	MODEL #	SERIAL NUMBER	UNIT PRICE	SALES AMOUNT
	Rinnai REPI60e	REPI60e	PKUA-113459	(WH)	999.95
	Sediment trap with auto ff valve				44.95
	B44R regulator				79.95
2	3/4" trace ends			44.95	89.90
12'	1/2" copper			4.95	59.40
4	1/2" flare nuts			2.95	11.80
	1/2" auto ff valve				19.95
	pipe fittings				24.95
3	1/2 x 1/2 msp			3.95	11.85

WORK PERFORMED:	REGULATION INFORMATION	APPLIANCES/ EQUIP. SOLD
Installed tankless	MAKE: Rego MODEL: TR9	(MP) 342.75
	DATE CODE: 12B2023 VENT: AL	(MS) 42.17
		TANK RENT

SERVICEMAN MUST COMPLETE BELOW SECTION FOR NEW INSTALLATIONS OR SERVICE

SERVICEMAN TO COMPLETE IN PRESENCE OF CUSTOMER:		LEAK AND PRESSURE TEST		SALES TAX
1) STORAGE SYSTEM INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 58 ☐	HIGH:	1st Stage	2nd Stage	_____ %
2) ALL APPLIANCES INSTALLED IN COMPLIANCE WITH N.F.P.A. PAMPHLET NUMBER 54 ☐	START LOCK-UP:	9.3 PSI	PSI	
I HAVE RECEIVED A SCRATCH AND SNIFF BROCHURE AND THE ODOR CHARACTERISTICS HAVE BEEN DEMONSTRATED TO ME.	TANK OFF:	4.0 PSI	PSI	LABOR
	PRESSURE	4.0 PSI	PSI	GR (400.00)
	AFTER 10 MINUTES:	4.0 PSI	PSI	
	PRESSURE AS LEFT:	9.0 PSI	PSI	
X _____ CUSTOMER SIGNATURE	PIPING PRESSURE TEST			INV. TOTAL
	START	6.0 PSIG	FINISH	4.0 PSIG
				AMOUNT RECEIVED

THE USE AND CARE OF THE APPLIANCES AND EQUIPMENT HAVE BEEN EXPLAINED TO MY SATISFACTION. I ALSO ACKNOWLEDGE RECEIPT OF THE CUSTOMER COPY EXPLAINING THE SAFETY FEATURES OF SUCH EQUIPMENT ON THE REVERSE SIDE.

SERVICE REP. SIGNATURE

DATE

CUSTOMER SIGNATURE

WHITE/FILE COPY; YELLOW/CUSTOMER COPY; PINK/POSTING COPY